

SINAIT, Philippines

WMO: 982220

Lat: 17.8903N

Lon: 120.4598E

Elev: 58

StdP: 100.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.5	21.4	14.7	10.5	23.3	15.9	11.3	23.7	7.0	26.6	6.3	26.5	1.8	40	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.2	33.1	27.0	32.6	26.9	32.2	26.7	28.2	31.6	27.9	31.4	27.6	31.1	3.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.2	30.8	26.9	22.7	30.6	26.6	22.3	30.3	91.2	31.7	89.7	31.5	88.3	31.2	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.8	5.8	5.1	DB	18.6	35.2	1.6	1.5	17.4	36.3	16.5	37.2	15.6	38.1	14.4	39.2	(4)
			WB	16.2	29.2	1.5	0.6	15.1	29.6	14.3	30.0	13.4	30.3	12.4	30.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	25.8	26.2	27.3	28.5	28.9	28.3	27.7	27.3	27.4	27.4	26.6		
		DBStd	1.44	1.23	1.32	1.19	0.96	1.15	1.10	1.04	1.16	0.98	1.09	1.16		
		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0		
		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0		
		CDD10.0	6352	489	454	535	555	584	550	548	536	523	540	522	515	(10)
		CDD18.3	3311	231	221	277	305	326	300	289	278	273	282	272	257	(11)
		CDH23.3	34544	1788	1903	2859	3712	4108	3511	3084	2820	2836	2902	2758	2262	(12)
		CDH26.7	11842	481	548	967	1519	1788	1362	997	792	866	953	898	672	(13)
(14)	Wind	WSAvg	2.1	2.2	2.3	2.2	2.1	2.1	2.1	2.3	1.9	2.2	2.1	2.2		
(15)	Precipitation	PrecAvg	2459	8	2	3	29	184	287	533	688	460	158	49	9	(15)
		PrecMax	3258	65	11	6	200	378	660	1112	1110	921	699	268	49	(16)
		PrecMin	1844	0	0	0	7	38	17	114	259	111	27	3	0	(17)
		PrecStd	421	14	3	2	42	94	181	319	274	183	151	68	11	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	31.8	32.0	32.9	33.4	34.1	33.4	32.7	32.1	32.1	32.6	32.7	32.3		
		0.4% MCWB	24.2	24.6	25.6	26.5	27.6	27.5	27.6	27.5	27.3	26.4	26.0	24.9		
		2% DB	30.7	31.0	31.9	32.7	33.2	32.6	31.8	31.3	31.3	31.8	31.8	31.3		
		2% MCWB	24.2	24.5	25.5	26.6	27.4	27.5	27.3	27.2	27.1	26.4	26.2	25.1		
		5% DB	29.8	30.3	31.2	32.2	32.7	32.0	31.2	30.8	30.8	31.2	31.2	30.6		
		5% MCWB	24.1	24.4	25.4	26.5	27.2	27.4	27.2	27.0	26.9	26.4	26.0	25.0		
		10% DB	29.2	29.7	30.6	31.7	32.1	31.4	30.7	30.1	30.3	30.6	30.6	30.0		
		10% MCWB	23.9	24.2	25.2	26.4	27.0	27.2	27.0	26.8	26.8	26.3	25.9	24.9		
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	26.2	26.6	27.2	28.0	28.8	28.6	28.4	28.2	28.2	28.1	27.7	27.1		
		0.4% MCDB	29.8	30.5	31.3	32.1	32.6	32.0	31.3	31.0	30.9	31.0	31.1	30.5		
		2% WB	25.5	25.8	26.6	27.4	28.1	28.1	27.9	27.7	27.6	27.5	27.2	26.4		
		2% MCDB	29.2	29.7	30.7	31.6	32.2	31.6	31.1	30.5	30.5	30.6	30.6	30.1		
		5% WB	25.0	25.3	26.1	27.0	27.7	27.7	27.5	27.2	27.2	27.1	26.7	25.9		
		5% MCDB	28.8	29.2	30.3	31.4	31.8	31.2	30.7	30.1	30.2	30.3	30.2	29.6		
		10% WB	24.5	24.8	25.6	26.7	27.2	27.4	27.1	26.9	26.9	26.6	26.3	25.3		
		10% MCDB	28.3	28.7	29.7	30.9	31.4	30.9	30.3	29.6	29.8	29.8	29.8	29.0		
(35)	Mean Daily Temperature Range	MDBR	6.9	6.8	6.7	6.5	6.2	5.9	5.5	4.8	5.4	6.2	6.2	6.5		
		5% DB MCDBR	7.5	7.3	7.1	6.8	6.9	6.6	6.5	6.0	6.1	7.0	7.0	7.2		
		5% DB MCWBR	4.4	4.0	3.9	3.6	3.5	3.5	3.6	3.4	3.5	4.0	3.9	4.2		
		5% WB MCDBR	6.8	6.7	6.7	6.4	6.6	6.2	6.1	5.6	5.8	6.2	6.3	6.7		
		5% WB MCWBR	4.3	4.2	4.0	3.7	3.7	3.7	3.7	3.4	3.5	3.9	3.9	4.4		
(40)	Clear-Sky Solar Irradiance	taub	0.391	0.403	0.463	0.491	0.457	0.454	0.453	0.457	0.452	0.441	0.418	0.412		
		taud	2.478	2.431	2.269	2.207	2.354	2.376	2.375	2.353	2.357	2.374	2.452	2.447		
		Ebn at Noon	893	900	853	827	845	840	842	845	851	851	859	859		
		Edh at Noon	105	115	139	149	127	123	123	127	125	120	107	105		
(44)	All-Sky Solar Radiation	RadAvg	4.71	5.42	6.14	6.61	5.95	5.72	5.22	4.77	5.03	5.02	4.55	4.22		
		RadStd	0.20	0.32	0.26	0.30	0.43	0.58	0.59	0.54	0.43	0.39	0.39	0.27		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	-0.33	-0.24	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page