

IBA, Philippines

WMO: 983240

Lat: 15.3262N

Lon: 119.9690E

Elev: 16

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	69.5	71.3	61.8	82.6	74.5	63.7	88.5	74.8	18.5	80.9	16.1	82.6	4.9	90	0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.2	92.3	81.7	91.4	81.5	90.5	81.2	83.8	89.5	83.2	89.0	82.6	88.6	8.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.2	167.9	88.4	81.5	164.1	87.8	80.9	160.5	87.3	48.0	89.6	47.2	89.2	46.5	88.7	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.5	16.3	13.8	DB	66.6	94.3	3.5	0.7	64.1	94.8	62.0	95.2	60.1	95.6	57.6	96.2
			WB	63.9	84.8	2.5	1.0	62.1	85.5	60.6	86.1	59.2	86.6	57.3	87.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.9	80.0	80.3	82.0	84.1	84.4	82.7	81.4	81.0	81.3	81.8	82.4	81.3	(6)
	DBStd	2.47	1.99	1.98	1.99	1.89	2.31	2.50	2.56	2.30	1.96	1.77	1.69	2.15	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD50	11643	931	850	991	1024	1066	982	972	962	938	985	972	970	(10)
	CDD65	6168	466	430	526	574	601	532	507	497	488	520	522	505	(11)
	CDH74	67842	4426	4215	5875	7341	7716	6122	5267	5096	5014	5616	5879	5275	(12)
	CDH80	24058	1347	1342	2159	3277	3507	2287	1583	1396	1448	1862	2128	1722	(13)
(14) Wind	WSAvg	5.6	5.6	5.6	5.5	5.2	5.4	6.0	6.2	6.8	5.6	5.4	4.8	5.0	(14)
(15) Precipitation	PrecAvg	149.7	0.0	0.1	0.3	1.3	10.2	25.7	31.2	43.7	21.7	10.8	3.3	1.3	(15)
	PrecMax	213.8	0.2	0.7	1.2	5.1	42.2	45.6	78.0	85.6	47.6	28.3	9.8	8.1	(16)
	PrecMin	78.0	0.0	0.0	0.0	0.1	0.4	4.1	9.2	17.6	5.3	0.6	0.2	0.0	(17)
	PrecStd	36.9	0.0	0.2	0.4	1.5	10.9	12.4	17.9	20.6	12.6	9.8	3.3	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.5	90.2	91.5	93.2	93.7	92.7	90.4	89.3	89.6	90.7	91.2	90.8	(19)
		MCWB	78.6	78.4	79.7	81.3	82.3	82.4	81.8	82.1	81.5	80.8	80.8	79.0	(20)
	2%	DB	87.9	88.3	89.8	91.8	92.5	90.9	89.0	87.9	88.1	89.1	89.8	89.0	(21)
		MCWB	78.1	78.5	79.9	81.2	82.3	82.2	81.5	81.5	81.3	80.6	80.4	79.4	(22)
	5%	DB	86.8	87.3	88.8	90.9	91.6	89.6	87.9	86.9	87.3	88.2	88.8	87.9	(23)
		MCWB	77.8	78.2	79.6	81.1	82.1	82.1	81.2	81.1	81.0	80.4	80.2	79.3	(24)
	10%	DB	85.9	86.3	87.8	89.9	90.5	88.4	86.7	85.7	86.3	87.2	87.9	86.8	(25)
		MCWB	77.5	77.8	79.2	80.9	81.8	81.5	80.8	80.7	80.7	80.1	79.9	78.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.4	81.9	83.0	84.1	84.6	84.3	83.6	83.5	83.6	82.8	83.4	82.6	(27)
		MCDB	87.0	87.8	89.1	90.2	91.0	89.9	88.3	87.4	87.7	87.9	88.6	87.7	(28)
	2%	WB	80.2	80.6	81.9	83.0	83.9	83.3	82.5	82.4	82.3	82.0	82.3	81.3	(29)
		MCDB	86.1	86.7	88.2	89.7	90.5	89.1	87.6	86.6	86.9	87.4	88.1	87.0	(30)
	5%	WB	79.3	79.7	81.0	82.2	83.0	82.5	81.7	81.7	81.5	81.4	81.5	80.5	(31)
		MCDB	85.5	85.8	87.4	89.3	89.9	88.6	86.7	85.8	86.2	86.9	87.4	86.4	(32)
	10%	WB	78.4	78.8	80.0	81.5	82.3	81.8	80.9	80.9	80.8	80.7	80.6	79.6	(33)
		MCDB	84.7	85.0	86.6	88.6	89.3	87.6	85.9	85.0	85.6	86.3	86.8	85.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.4	12.5	12.3	11.9	11.2	10.2	8.8	8.1	9.1	10.8	11.5	11.6	(35)
		MCDDBR	12.9	13.2	12.8	12.7	12.5	11.8	10.8	10.0	10.7	12.0	12.5	12.3	(36)
	5% WB	MCWBR	8.1	8.2	7.6	7.0	6.5	6.6	6.3	6.2	6.4	6.9	7.5	7.5	(37)
		MCDWBR	12.2	12.3	12.1	12.1	11.9	11.2	10.2	9.1	10.2	11.1	11.9	11.7	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.416	0.425	0.470	0.514	0.483	0.471	0.472	0.478	0.471	0.491	0.435	0.429	(40)
		taud	2.427	2.387	2.269	2.155	2.280	2.331	2.325	2.298	2.308	2.227	2.409	2.409	(41)
	Ebn at Noon	Ebn at Noon	278	280	270	257	261	261	262	263	266	258	270	270	(42)
		Edh at Noon	36	38	44	50	43	41	41	43	42	45	36	36	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1561	1786	1989	2116	1869	1652	1457	1414	1518	1591	1512	1424	(44)
	RadStd	RadStd	69	99	83	94	157	210	217	166	160	128	117	86	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (14 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.58	+1.03	N/A	+0.72	+0.65	+0.76	N/A	N/A	+284	+284

Nomenclature: See separate page