

IBA, Philippines

WMO: 983240

Lat: 15.3262N

Lon: 119.9690E

Elev: 5

StdP: 101.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.8	21.8	16.6	11.8	23.6	17.6	12.6	23.8	8.3	27.2	7.2	28.1	2.2	90	0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.2	33.5	27.6	33.0	27.5	32.5	27.3	28.8	32.0	28.4	31.7	28.1	31.4	3.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.9	24.0	31.3	27.5	23.4	31.0	27.2	22.9	30.7	93.7	32.0	91.9	31.8	90.2	31.5	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.2	7.3	6.2	DB	19.2	34.6	1.9	0.4	17.8	34.9	16.7	35.1	15.6	35.4	14.2	35.6
			WB	17.7	29.3	1.4	0.6	16.7	29.7	15.9	30.0	15.1	30.4	14.1	30.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	26.7	26.9	27.8	29.0	29.1	28.2	27.4	27.2	27.4	27.7	28.0	27.4
	DBStd	1.37	1.11	1.10	1.11	1.05	1.28	1.39	1.42	1.28	1.09	0.99	0.94	1.19
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6468	517	472	551	569	592	546	540	534	521	547	540	539
	CDD18.3	3427	259	239	292	319	334	296	282	276	271	289	290	281
	CDH23.3	37690	2459	2342	3264	4078	4287	3401	2926	2831	2786	3120	3266	2931
(14) Wind	WSAvg	2.5	2.5	2.5	2.5	2.3	2.4	2.7	2.8	3.0	2.5	2.4	2.1	2.2
	PrecAvg	3802	1	3	8	32	258	654	792	1111	552	274	84	32
	PrecMax	5431	4	19	30	130	1073	1157	1980	2175	1208	718	250	207
	PrecMin	1980	0	0	0	2	11	103	233	446	134	15	5	0
	PrecStd	937	1	6	10	39	278	316	455	522	320	248	84	51
	DB	31.9	32.4	33.1	34.0	34.3	33.7	32.5	31.8	32.0	32.6	32.9	32.6	32.6
	MCWB	25.9	25.8	26.5	27.4	28.0	28.0	27.7	27.9	27.5	27.1	27.1	26.1	26.1
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	31.0	31.3	32.1	33.2	33.6	32.7	31.7	31.1	31.2	31.7	32.1	31.6	31.6
	MCWB	25.6	25.8	26.6	27.4	27.9	27.5	27.5	27.5	27.4	27.0	26.9	26.3	26.3
	DB	30.5	30.7	31.6	32.7	33.1	32.0	31.0	30.5	30.7	31.2	31.6	31.0	31.0
	MCWB	25.4	25.7	26.4	27.3	27.8	27.8	27.3	27.3	27.2	26.9	26.8	26.3	26.3
	DB	30.0	30.1	31.0	32.2	32.5	31.3	30.4	29.9	30.1	30.7	31.1	30.4	30.4
	MCWB	25.3	25.5	26.2	27.2	27.7	27.5	27.1	27.1	27.0	26.7	26.6	26.0	26.0
	WB	27.4	27.7	28.3	28.9	29.2	29.1	28.7	28.6	28.7	28.2	28.6	28.1	28.1
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	30.6	31.0	31.7	32.3	32.8	32.2	31.3	30.8	30.9	31.0	31.4	30.9	30.9
	WB	26.8	27.0	27.7	28.3	28.8	28.5	28.0	28.0	27.9	27.8	27.9	27.4	27.4
	MCDB	30.1	30.4	31.2	32.0	32.5	31.7	30.9	30.4	30.5	30.8	31.2	30.5	30.5
	WB	26.3	26.5	27.2	27.9	28.4	28.1	27.6	27.6	27.5	27.4	27.5	26.9	26.9
	MCDB	29.7	29.9	30.8	31.8	32.2	31.4	30.4	29.9	30.1	30.5	30.8	30.2	30.2
	WB	25.8	26.0	26.7	27.5	27.9	27.6	27.2	27.2	27.1	27.0	27.0	26.5	26.5
	MCDB	29.3	29.5	30.3	31.4	31.8	30.9	30.0	29.4	29.8	30.1	30.4	29.8	29.8
(35) Mean Daily Temperature Range	MDBR	6.9	7.0	6.8	6.6	6.2	5.7	4.9	4.5	5.1	6.0	6.4	6.4	6.4
	5% DB	7.2	7.3	7.1	7.1	7.0	6.6	6.0	5.6	5.9	6.6	7.0	6.9	6.9
	MCWBR	4.5	4.6	4.2	3.9	3.6	3.6	3.5	3.5	3.5	3.8	4.1	4.2	4.2
	5% WB	6.8	6.8	6.7	6.7	6.6	6.2	5.6	5.1	5.7	6.2	6.6	6.5	6.5
	MCWBR	4.7	4.7	4.6	4.1	4.0	3.8	3.6	3.4	3.7	4.0	4.4	4.4	4.4
	taub	0.416	0.425	0.470	0.514	0.483	0.471	0.472	0.478	0.471	0.491	0.435	0.429	0.429
	taud	2.427	2.387	2.269	2.155	2.280	2.331	2.325	2.298	2.308	2.227	2.409	2.409	2.409
(42) Clear-Sky Solar Irradiance	Ebn at Noon	876	884	851	810	823	824	825	828	837	812	851	852	852
	Edh at Noon	112	121	140	157	136	128	129	134	133	141	113	112	112
	RadAvg	4.92	5.63	6.27	6.67	5.89	5.21	4.59	4.46	4.78	5.02	4.77	4.49	4.49
(45) All-Sky Solar Radiation	RadStd	0.22	0.31	0.26	0.30	0.49	0.66	0.69	0.52	0.51	0.41	0.37	0.27	0.27

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (14 neighbors)		+0.32	+0.57	N/A	+0.40	+0.36	+0.42	N/A	N/A	+158

Nomenclature: See separate page