

CLARK INTL, Philippines

WMO: 983270

Lat: 15.1851N

Lon: 120.5490E

Elev: 148

StdP: 99.57

Time Zone: 8.00 (E08)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.1	20.0	14.0	10.2	25.5	15.1	10.9	25.7	7.8	27.5	6.9	27.2	2.9	300	0.323

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.2	35.1	24.6	34.2	24.6	33.7	24.6	27.2	31.5	26.7	30.9	26.4	30.4	3.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	22.0	29.3	25.8	21.4	28.7	25.2	20.7	28.1	87.2	31.8	85.1	31.3	83.4	30.6	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.0	6.0	5.2	17.8	36.7	1.4	0.7	16.9	37.2	16.1	37.6	15.3	38.1	14.3	38.6		
			15.3	28.7	1.2	1.2	14.4	29.6	13.7	30.2	13.1	30.9	12.2	31.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.2	25.4	26.1	27.4	28.9	28.9	28.0	27.2	26.9	27.1	27.3	27.0	26.3	(6)
(7)		DBStd	1.63	1.36	1.28	1.29	1.20	1.44	1.48	1.35	1.26	1.24	1.16	1.05	1.27	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6275	477	449	539	567	587	539	532	524	513	535	509	504	(10)
(11)		CDD18.3	3233	218	216	281	317	328	289	274	266	263	277	259	246	(11)
(12)		CDH23.3	30704	1678	1879	2869	3773	3719	2907	2414	2214	2293	2570	2339	2048	(12)
(13)		CDH26.7	11512	492	679	1217	1835	1695	1104	788	634	729	889	797	651	(13)
(14)	Wind	WSAvg	2.4	2.8	2.6	2.6	2.5	2.3	2.3	2.2	2.2	2.1	2.3	2.5	2.8	(14)
(15)	Precipitation	PrecAvg	2121	14	16	23	41	191	272	453	452	330	199	72	50	(15)
(16)		PrecMax	2904	111	80	75	180	406	604	1068	878	562	564	175	284	(16)
(17)		PrecMin	1517	0	0	0	3	17	87	163	212	60	30	0	0	(17)
(18)		PrecStd	410	24	18	21	49	109	154	204	173	122	125	54	63	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.9	33.2	34.8	36.0	36.0	35.1	33.7	33.2	33.3	33.1	32.7	32.2	(19)
(20)			MCWB	23.7	23.4	23.9	24.3	24.6	26.2	25.9	26.0	26.0	25.1	24.7	24.0	(20)
(21)		2%	DB	30.9	32.1	33.9	35.1	35.1	33.8	32.7	32.0	32.2	32.2	32.0	31.5	(21)
(22)			MCWB	23.1	22.9	23.5	24.2	24.8	25.9	25.6	25.7	25.7	25.0	24.4	23.9	(22)
(23)		5%	DB	30.1	31.2	33.0	34.2	34.2	32.8	31.8	31.1	31.4	31.8	31.2	30.9	(23)
(24)			MCWB	22.9	22.7	23.4	24.2	25.0	25.7	25.5	25.6	25.5	24.8	24.2	23.7	(24)
(25)		10%	DB	29.2	30.4	32.0	33.7	33.1	31.7	30.8	30.0	30.5	30.9	30.7	30.0	(25)
(26)			MCWB	22.4	22.5	23.2	24.2	25.1	25.6	25.5	25.6	25.5	24.6	24.1	23.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.5	25.2	27.5	28.6	27.4	27.5	27.1	27.2	27.2	26.9	26.2	26.0	(27)
(28)			MCDWB	29.9	30.0	31.6	33.0	32.5	31.8	31.0	30.5	31.1	30.8	30.2	30.1	(28)
(29)		2%	WB	24.7	24.5	25.6	27.0	26.7	26.8	26.5	26.6	26.5	26.2	25.6	25.2	(29)
(30)			MCDWB	29.1	29.5	30.2	32.0	31.7	31.1	30.2	29.8	30.3	30.0	29.6	29.1	(30)
(31)		5%	WB	23.8	23.9	24.7	25.9	26.3	26.4	26.1	26.1	26.1	25.7	25.2	24.7	(31)
(32)			MCDWB	27.9	29.0	29.8	30.7	31.0	30.5	29.7	29.2	29.7	29.4	29.1	28.5	(32)
(33)		10%	WB	23.2	23.4	24.0	25.2	25.8	26.0	25.7	25.7	25.7	25.3	24.7	24.2	(33)
(34)			MCDWB	27.4	28.3	29.1	30.3	30.3	29.9	29.1	28.6	29.1	28.9	28.6	28.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	9.3	9.6	10.2	8.8	7.4	6.8	6.2	6.8	7.4	7.6	7.8	(35)
(36)			MCDBR	9.0	10.2	10.7	10.8	9.8	8.8	8.5	7.9	8.2	8.4	8.5	8.6	(36)
(37)			MCWBR	3.3	3.6	3.3	3.1	3.0	3.1	3.3	3.2	3.3	3.1	3.1	3.2	(37)
(38)		5% WB	MCDWB	7.6	8.8	9.4	9.4	8.6	7.7	7.3	6.8	7.4	7.4	7.4	7.3	(38)
(39)			MCWBR	3.3	3.6	3.6	3.6	3.2	3.1	3.2	3.1	3.3	3.1	3.1	3.1	3.3
(40)	Clear-Sky Solar Irradiance	taub	0.402	0.409	0.448	0.489	0.472	0.459	0.457	0.463	0.459	0.471	0.422	0.418	(40)	
(41)		taud	2.440	2.407	2.302	2.194	2.277	2.328	2.335	2.311	2.314	2.262	2.423	2.418	(41)	
(42)		Ebn at Noon	891	900	871	830	831	834	837	841	848	829	864	863	(42)	
(43)		Edh at Noon	111	119	135	151	137	128	128	132	132	136	112	111	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.65	5.35	5.96	6.40	5.74	5.15	4.55	4.25	4.68	4.77	4.50	4.25	(44)	
(45)		RadStd	0.21	0.35	0.29	0.29	0.52	0.60	0.63	0.48	0.47	0.39	0.38	0.28	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.81	+1.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)		+0.32	+0.57	N/A	+0.40	+0.36	+0.42	N/A	N/A	+158	+158

Nomenclature: See separate page