

BAGUIO, Philippines

WMO: 983280

Lat: 16.4040N

Lon: 120.6015E

Elev: 1501

StdP: 84.55

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.0	12.9	10.0	9.2	13.6	10.9	9.8	14.1	6.3	18.3	5.6	17.9	1.9	110	0.259

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	7.7	26.4	21.4	25.5	21.2	24.8	21.0	23.0	24.9	22.3	24.3	21.8	23.9	2.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	20.6	24.4	21.7	19.7	23.9	21.1	19.0	23.5	77.1	24.9	74.1	24.4	72.0	24.0	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.9	5.7	4.8	10.4	30.1	1.3	2.5	9.5	31.9	8.7	33.3	8.0	34.7	7.0	36.5
			9.4	26.0	1.2	1.8	8.5	27.2	7.8	28.3	7.2	29.3	6.3	30.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	18.2	18.8	19.6	20.7	20.7	20.4	19.7	19.3	19.7	19.8	19.7	19.1
	DBStd	1.48	1.45	1.44	1.21	1.05	1.24	1.31	1.38	1.38	1.29	1.18	1.16	1.38
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	63	19	11	3	0	1	2	4	6	3	3	3	8
	CDD10.0	3520	254	245	298	321	330	313	301	289	291	303	292	281
	CDD18.3	541	16	23	43	71	73	64	47	36	44	47	45	31
	CDH23.3	735	18	42	85	163	114	82	39	26	30	41	54	39
	CDH26.7	31	2	2	1	3	4	4	4	2	3	2	1	2
Wind	WSAvg	2.0	2.0	1.9	1.8	1.7	1.8	2.2	2.2	2.3	1.9	2.2	2.0	2.2
Precipitation	PrecAvg	3799	16	18	32	104	310	430	753	873	592	406	98	36
	PrecMax	7166	160	129	121	407	764	1418	4774	1908	1695	2273	636	167
	PrecMin	2131	0	0	0	8	18	131	117	242	179	31	8	0
	PrecStd	1329	28	32	38	85	150	270	745	438	397	476	121	41
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.0	25.9	26.3	27.0	27.0	26.7	26.4	25.6	25.8	25.9	25.7	25.8
		MCWB	20.0	20.6	21.0	21.7	22.3	21.7	21.5	21.2	21.1	21.1	21.0	20.4
	2%	DB	23.6	24.5	25.1	25.9	25.4	25.1	24.2	23.9	24.0	24.3	24.7	24.2
		MCWB	19.8	20.3	20.6	21.4	21.7	21.4	21.2	20.9	21.0	20.9	20.5	20.1
	5%	DB	22.7	23.6	24.2	25.1	24.6	24.2	23.3	22.9	23.2	23.5	23.9	23.4
		MCWB	19.3	19.8	20.2	21.2	21.3	21.2	20.8	20.6	20.7	20.6	20.3	19.8
	10%	DB	21.9	22.6	23.4	24.3	23.7	23.4	22.4	21.8	22.3	22.7	23.0	22.6
		MCWB	18.9	19.3	19.9	20.9	20.9	20.8	20.3	20.0	20.2	20.2	19.9	19.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	22.5	22.9	23.7	23.7	23.3	22.8	22.5	22.6	22.8	22.5	22.6
		MCDB	23.8	24.4	25.1	25.6	25.4	25.1	24.3	24.0	24.3	24.5	24.4	24.3
	2%	WB	20.7	21.2	21.7	22.5	22.5	22.2	21.7	21.3	21.6	21.6	21.5	21.2
		MCDB	22.8	23.7	24.0	24.8	24.6	24.1	23.6	23.1	23.4	23.5	23.8	23.4
	5%	WB	19.9	20.3	20.9	21.8	21.7	21.5	21.0	20.6	20.9	21.0	20.8	20.3
		MCDB	22.2	22.9	23.6	24.3	24.0	23.6	23.0	22.5	22.8	23.1	23.2	22.7
	10%	WB	19.2	19.6	20.2	21.1	21.0	20.8	20.4	20.0	20.3	20.3	20.1	19.6
		MCDB	21.4	22.2	22.9	23.8	23.4	23.1	22.2	21.7	22.1	22.3	22.5	22.0
Mean Daily Temperature Range	5% DB	MDBR	8.2	8.6	8.3	7.7	6.7	6.2	5.4	4.6	5.6	6.3	7.1	7.7
		MCDBR	9.0	9.6	9.3	8.8	8.0	7.6	7.3	7.0	7.2	7.7	8.4	8.8
		MCWBR	6.5	6.6	6.2	5.8	5.3	4.9	4.9	4.7	4.8	5.2	5.5	6.0
	5% WB	MCDBR	8.7	9.1	8.8	8.3	7.6	7.1	6.9	6.5	6.8	7.2	7.9	8.3
		MCWBR	7.0	7.0	6.6	6.2	5.6	5.2	5.0	4.8	4.9	5.5	5.8	6.5
Clear-Sky Solar Irradiance	taub	0.325	0.338	0.378	0.420	0.403	0.388	0.387	0.390	0.389	0.381	0.345	0.334	
	taud	2.546	2.495	2.390	2.286	2.377	2.443	2.449	2.431	2.421	2.421	2.537	2.549	
	Ebn at Noon	969	969	934	889	891	896	899	904	910	912	940	949	
	Edh at Noon	98	108	123	137	124	115	114	117	118	115	98	95	
All-Sky Solar Radiation	RadAvg	4.62	5.26	5.84	6.26	5.75	5.34	4.78	4.50	4.79	4.79	4.43	4.17	
	RadStd	0.22	0.36	0.29	0.29	0.43	0.56	0.58	0.45	0.38	0.37	0.42	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	-0.29	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page