

MUNOZ, Philippines

WMO: 983290

Lat: 15.7359N

Lon: 120.9368E

Elev: 250

StdP: 14.56

Time Zone: 8.00 (E08)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	70.1	71.4	63.4	88.1	75.5	65.0	93.5	76.1	18.8	80.4	17.5	81.0	5.1	40	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	16.2	95.3	81.5	93.6	81.6	92.2	81.3	84.3	91.6	83.4	90.8	82.6	90.1	5.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
82.3	169.8	89.9	81.3	164.2	89.1	80.5	159.7	88.4	48.7	91.8	47.6	90.9	46.8	90.4	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	17.1	13.9	12.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)				N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.6	79.3	79.5	80.5	83.6	84.8	83.5	81.6	81.6	81.5	81.6	81.2	80.3	(6)
(7)		DBStd	2.61	1.77	1.68	1.63	2.22	2.26	2.11	2.48	2.18	2.13	1.91	2.23	2.10	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11532	910	825	947	1007	1077	1006	981	979	944	978	937	941	(10)
(11)		CDD65	6057	445	405	482	557	612	556	516	514	494	513	487	476	(11)
(12)		CDH74	58498	3510	3253	4317	6308	7010	6033	4904	4867	4562	4904	4623	4207	(12)
(13)		CDH80	20594	961	937	1401	2726	3188	2393	1563	1434	1370	1642	1651	1328	(13)
(14)	Wind	WSAvg	5.1	6.5	6.0	6.0	5.6	4.1	3.7	4.2	4.0	3.7	5.1	5.9	6.8	(14)
(15)	Precipitation	PrecAvg	96.3	0.5	0.6	0.9	1.9	8.4	12.5	20.7	21.7	16.2	8.7	2.8	1.5	(15)
(16)		PrecMax	127.2	4.4	3.2	3.0	7.8	22.9	29.1	46.3	42.2	29.0	19.6	8.7	10.9	(16)
(17)		PrecMin	70.1	0.0	0.0	0.1	0.2	1.1	4.0	6.7	10.1	4.0	1.7	0.0	0.0	(17)
(18)		PrecStd	15.6	0.9	0.7	0.9	1.7	5.0	6.9	8.4	8.2	5.7	5.4	2.1	2.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.6	89.8	91.9	97.2	97.9	94.9	93.5	92.0	91.8	92.1	92.5	91.3	(19)
(20)			MCWB	79.3	79.7	79.4	81.4	82.1	83.5	82.7	82.8	82.3	81.0	80.4	78.4	(20)
(21)		2%	DB	87.9	88.1	89.3	94.9	95.9	93.4	91.6	90.0	90.0	90.5	90.9	89.4	(21)
(22)			MCWB	77.9	78.7	79.5	80.9	81.3	83.0	82.2	82.1	81.7	80.8	79.3	78.5	(22)
(23)		5%	DB	86.4	86.8	87.9	92.7	94.1	91.9	89.9	88.6	88.6	89.2	89.5	87.9	(23)
(24)			MCWB	76.8	77.9	78.9	80.7	81.2	82.3	81.5	81.4	81.2	80.4	78.7	77.7	(24)
(25)		10%	DB	85.0	85.6	86.6	90.7	92.2	90.4	88.0	86.9	87.1	87.7	87.9	86.4	(25)
(26)			MCWB	75.9	77.2	78.2	80.1	81.0	81.7	80.8	80.6	80.5	79.6	78.2	77.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.6	82.0	82.5	84.5	85.8	85.1	84.0	84.5	83.7	84.1	82.6	81.5	(27)
(28)			MCDWB	88.1	88.0	88.6	92.1	93.2	92.6	90.9	90.2	89.7	89.5	90.2	88.7	(28)
(29)		2%	WB	79.1	80.1	80.8	83.0	83.8	83.7	82.8	82.8	82.5	82.4	80.9	79.9	(29)
(30)			MCDWB	86.4	86.7	87.9	91.7	92.6	91.7	89.8	89.0	88.7	88.8	88.8	87.2	(30)
(31)		5%	WB	78.1	78.9	79.8	81.8	82.6	82.8	81.9	81.8	81.5	81.1	79.9	78.7	(31)
(32)			MCDWB	84.9	85.8	86.9	90.9	91.7	90.7	88.6	87.8	87.6	87.7	87.6	85.9	(32)
(33)		10%	WB	77.0	77.7	78.7	80.7	81.5	81.9	80.9	80.9	80.6	80.1	78.9	77.7	(33)
(34)			MCDWB	83.3	84.5	85.7	89.6	90.3	89.3	87.2	86.5	86.5	86.5	86.3	84.7	(34)
(35)	Mean Daily Temperature Range	MDBR	12.7	12.8	13.6	15.6	16.2	13.9	11.8	10.9	11.8	12.8	14.4	13.2	(35)	
(36)		5% DB	MCDBR	14.2	14.8	15.0	18.2	18.7	16.4	15.4	13.7	14.3	15.2	16.5	15.4	(36)
(37)			MCWBR	6.9	8.3	8.1	8.2	8.0	7.8	7.5	7.4	7.6	7.7	7.5	7.5	(37)
(38)		5% WB	MCDBR	13.5	14.2	14.3	16.7	17.2	15.6	14.1	13.0	13.5	14.3	15.6	14.4	(38)
(39)			MCWBR	7.6	9.0	8.7	8.8	8.9	8.2	7.8	7.6	7.7	8.2	8.2	8.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.402	0.409	0.451	0.494	0.483	0.463	0.459	0.470	0.467	0.467	0.422	0.417	(40)	
(41)		taud	2.435	2.403	2.290	2.179	2.240	2.309	2.323	2.286	2.287	2.275	2.421	2.416	(41)	
(42)		Ebn at Noon	282	285	275	262	261	264	265	265	266	264	273	273	(42)	
(43)		Edh at Noon	35	38	43	49	45	42	41	43	43	43	36	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1361	1581	1770	1958	1824	1672	1497	1397	1513	1453	1329	1236	(44)	
(45)		RadStd	70	127	107	99	149	173	174	136	131	121	132	91	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.58	+1.03	N/A	+0.72	+0.65	+0.76	N/A	N/A	+284	+284

Nomenclature: See separate page