

BALER RADAR, PhilippinesWMO: **983340**Lat: **15.7491N**Lon: **121.6320E**Elev: **584**StdP: **14.39**Time Zone: **8.00 (E08)**Period: **98-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	69.1	70.2	62.8	87.5	70.8	64.5	93.0	71.8	18.3	68.9	15.0	69.4	6.6	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	9.4	91.1	82.7	89.8	82.3	88.8	82.0	84.5	89.0	83.6	88.2	82.8	87.5	6.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.3	178.1	88.3	82.4	172.5	87.7	81.6	167.8	87.0	49.4	89.2	48.3	88.3	47.4	87.7	88.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.8	17.5	14.3	67.5	94.4	1.2	1.9	66.7	95.8	66.0	97.0	65.4	98.1	64.5	99.5		
			63.8	86.2	2.2	1.0	62.2	86.9	61.0	87.5	59.7	88.0	58.2	88.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.1	75.8	76.8	78.4	80.7	82.4	83.1	81.9	82.5	82.1	80.9	79.5	77.4	
	DBStd	3.38	2.80	2.73	2.65	2.13	1.96	2.16	2.34	2.35	2.27	2.41	2.28	2.62	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11000	800	750	882	920	1006	993	987	1007	963	958	884	850	
	CDD65	5525	335	330	417	470	541	543	522	542	513	493	434	385	
	CDH74	47199	1309	1538	2600	4029	5678	6075	5321	5641	5212	4414	3261	2121	
	CDH80	12237	166	243	522	965	1727	2070	1471	1675	1502	1039	572	285	
Wind	WSAvg	5.7	4.7	4.1	3.9	3.7	4.9	7.1	7.3	8.8	7.8	6.5	4.5	5.1	
Precipitation	PrecAvg	129.9	7.7	7.2	7.6	7.7	11.3	9.5	10.9	7.8	12.0	14.9	14.4	15.0	
	PrecMax	166.7	20.3	15.1	17.6	18.8	24.9	21.6	24.4	15.0	25.1	25.6	32.0	37.6	
	PrecMin	90.8	1.5	0.6	0.3	0.6	4.3	2.3	2.8	2.6	3.9	3.0	4.3	2.6	
	PrecStd	20.6	4.4	3.8	4.1	3.9	4.3	4.4	5.6	2.6	4.8	6.0	8.2	9.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.3	86.8	89.1	89.4	90.9	92.9	91.2	92.9	91.3	90.8	88.6	87.1	
		MCWB	78.8	79.8	80.0	82.1	83.4	84.2	82.8	82.4	82.3	81.8	80.9	80.6	
	2%	DB	83.6	84.8	86.5	87.8	89.4	90.8	89.3	90.3	89.7	88.6	86.5	85.0	
		MCWB	77.5	78.6	80.0	81.8	82.9	83.5	82.2	81.9	81.9	81.0	80.2	79.2	
	5%	DB	81.8	83.1	84.9	86.4	88.1	89.3	87.8	88.7	88.3	87.0	85.2	83.2	
		MCWB	76.5	77.5	79.2	81.3	82.4	82.8	81.7	81.4	81.4	80.5	79.6	78.0	
	10%	DB	79.8	81.3	83.1	85.2	86.9	87.8	86.3	87.0	86.8	85.3	83.5	81.3	
		MCWB	75.3	76.5	78.0	80.5	81.8	82.2	81.0	80.8	80.8	79.7	78.8	76.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	80.9	82.1	83.7	85.5	86.0	84.6	84.6	84.5	83.5	82.6	81.4
			MCDB	84.4	85.3	86.5	87.5	89.4	90.7	88.8	89.9	89.1	87.9	86.4	85.8
2%		WB	78.3	79.3	80.7	82.6	84.0	84.5	83.4	83.2	83.0	82.2	81.3	79.8	
		MCDB	82.6	83.6	85.8	86.8	88.0	89.3	87.9	88.5	88.1	87.3	85.3	84.0	
5%		WB	77.0	78.1	79.5	81.7	82.9	83.5	82.4	82.2	82.1	81.1	80.2	78.5	
		MCDB	81.0	82.2	84.4	85.9	87.2	88.4	87.0	87.6	87.3	86.0	84.2	82.2	
10%		WB	75.6	76.8	78.1	80.6	82.0	82.4	81.2	81.0	81.0	80.0	79.0	77.3	
		MCDB	78.9	80.6	82.6	85.0	86.4	87.4	85.8	86.4	86.2	84.7	82.7	80.4	
Mean Daily Temperature Range	5% DB	MDBR	8.0	9.1	9.3	9.7	9.7	9.4	8.6	9.2	9.4	9.2	8.2	7.5	
		MCDBR	11.2	11.7	12.1	10.9	10.8	11.2	10.4	11.4	11.3	11.5	10.8	10.5	
		MCWBR	7.5	8.0	8.1	7.6	7.6	8.2	7.6	7.7	7.9	7.7	6.9	7.1	
	5% WB	MCDBR	10.2	11.1	11.5	10.5	10.4	10.7	10.0	10.6	10.9	10.8	10.1	10.0	
		MCWBR	7.3	8.1	8.1	8.0	8.0	8.5	8.1	8.1	8.1	7.8	7.0	7.2	
Clear-Sky Solar Irradiance	taub	0.412	0.410	0.441	0.455	0.455	0.439	0.435	0.444	0.446	0.447	0.432	0.440		
	taud	2.440	2.441	2.349	2.325	2.350	2.407	2.419	2.385	2.375	2.368	2.414	2.359		
	Ebn at Noon	279	285	278	272	268	270	272	272	272	270	270	266		
	Edh at Noon	35	36	41	42	40	38	37	39	39	39	36	37		
All-Sky Solar Radiation	RadAvg	1192	1433	1634	1917	1867	1734	1563	1485	1564	1368	1203	1069		
	RadStd	87	155	140	115	145	150	148	122	123	117	148	103		