

CASIGURAN, Philippines

WMO: 983360

Lat: 16.2651N

Lon: 122.1288E

Elev: 13

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	67.6	68.8	61.5	81.6	72.0	63.6	87.9	72.2	20.6	74.3	18.3	76.1	4.7	0	0.303

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	12.8	92.9	83.9	91.7	83.5	90.8	83.1	85.8	90.9	84.7	90.1	84.0	89.5	6.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
84.4	180.8	90.0	83.4	174.4	89.2	82.5	169.3	88.4	50.3	91.1	49.1	90.1	48.2	89.7	90.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.0	15.2	13.5	63.4	97.1	3.8	4.6	60.7	100.4	58.5	103.1	56.4	105.7	53.6	109.0		
(5)			62.1	88.0	2.8	1.8	60.1	89.3	58.5	90.3	56.9	91.3	54.9	92.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.3	75.3	76.4	77.9	80.9	83.3	84.1	82.7	83.1	82.6	80.9	79.0	77.3
	DBStd	3.58	2.44	2.64	2.44	2.24	1.95	1.85	2.04	1.79	1.82	1.96	1.95	2.29
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11061	786	738	865	926	1033	1023	1015	1026	977	957	870	845
	CDD65	5585	321	318	400	476	568	573	550	561	526	492	420	380
	CDH74	52824	1440	1842	2814	4638	6553	6961	6161	6390	5681	4704	3294	2346
	CDH80	17699	171	368	692	1594	2673	2992	2290	2418	2004	1406	714	377
Wind	WSAvg	5.4	6.9	5.3	5.1	4.1	4.0	4.2	4.8	6.1	4.7	6.2	6.2	7.3
Precipitation	PrecAvg	137.4	8.6	5.8	7.0	4.9	8.9	9.5	10.7	9.3	11.2	15.4	27.0	18.4
	PrecMax	271.0	18.3	30.0	23.7	10.9	42.7	23.5	26.0	18.1	26.8	43.2	70.0	51.1
	PrecMin	53.3	1.5	0.6	2.1	0.9	1.0	3.8	2.8	4.1	2.4	2.9	5.2	2.2
	PrecStd	54.1	4.8	7.0	5.6	2.8	10.3	5.8	6.7	4.4	7.4	11.1	16.9	13.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.3	87.5	89.0	91.1	94.2	94.6	93.3	93.0	91.9	90.7	88.2	87.3
		MCWB	77.9	80.0	80.8	82.8	84.6	85.0	83.9	83.7	82.9	82.3	80.6	79.3
	2%	DB	83.5	85.8	87.2	89.9	92.5	92.8	91.6	91.4	90.6	89.1	86.8	85.5
		MCWB	77.6	78.6	80.1	82.1	84.0	84.1	83.2	83.3	82.5	81.3	80.0	79.3
	5%	DB	81.9	84.3	85.8	88.8	91.1	91.6	90.2	90.1	89.5	87.9	85.6	83.8
		MCWB	76.7	77.9	79.5	81.5	83.5	83.8	82.8	82.7	82.1	80.9	79.6	78.3
	10%	DB	80.3	82.5	84.1	87.5	89.8	90.4	88.8	88.8	88.2	86.5	84.2	82.2
		MCWB	75.7	76.9	78.7	81.0	82.8	83.3	82.3	82.2	81.6	80.2	78.9	77.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.0	81.4	82.6	85.2	87.1	87.0	85.7	86.0	85.4	84.1	82.3	81.8
		MCDB	83.8	86.1	87.1	89.5	91.6	92.2	91.1	90.8	89.9	89.0	86.4	85.4
	2%	WB	78.5	80.0	81.1	83.5	85.6	85.6	84.3	84.4	83.9	82.6	81.1	80.3
		MCDB	82.2	84.6	85.8	88.5	90.7	91.2	90.0	89.8	89.0	87.6	85.2	84.0
	5%	WB	77.4	78.8	80.1	82.3	84.3	84.5	83.3	83.4	82.8	81.6	80.3	79.1
		MCDB	80.8	83.3	84.8	87.8	89.8	90.3	89.0	88.9	88.1	86.6	84.4	82.6
	10%	WB	76.3	77.5	79.0	81.3	83.3	83.6	82.5	82.5	81.9	80.7	79.2	78.0
		MCDB	79.4	81.4	83.6	86.7	88.8	89.4	88.1	87.9	87.1	85.4	83.1	81.2
Mean Daily Temperature Range	5% DB	MDBR	9.4	11.2	11.6	13.1	13.4	12.8	11.5	11.3	11.7	11.3	9.8	9.0
		MCDBR	12.4	14.2	14.6	15.1	15.2	14.7	14.1	13.6	13.5	13.7	12.2	12.1
		MCWBR	8.1	9.1	9.0	8.8	8.9	8.3	7.9	7.8	7.5	8.0	7.7	7.7
	5% WB	MCDBR	11.1	13.2	13.5	14.3	14.6	14.1	13.4	13.0	13.0	12.8	11.2	10.7
	MCWBR	7.9	9.1	9.1	9.4	9.5	8.9	8.3	8.3	8.1	8.3	7.6	7.6	
Clear-Sky Solar Irradiance	taub	0.435	0.428	0.462	0.463	0.457	0.441	0.439	0.445	0.454	0.460	0.457	0.471	
	taud	2.369	2.394	2.294	2.308	2.355	2.410	2.414	2.388	2.358	2.331	2.329	2.243	
	Ebn at Noon	271	279	272	270	268	270	270	272	270	266	262	255	
	Edh at Noon	37	38	43	43	40	37	37	39	40	40	39	42	
All-Sky Solar Radiation	RadAvg	1131	1389	1611	1919	1920	1835	1629	1595	1592	1367	1176	1011	
	RadStd	105	175	155	125	148	145	143	114	112	101	153	117	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page