

CASIGURAN, Philippines

WMO: 983360

Lat: 16.2651N

Lon: 122.1288E

Elev: 4

StdP: 101.28

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.8	20.5	16.4	11.7	22.2	17.5	12.6	22.3	9.2	23.5	8.2	24.5	2.1	0	0.303

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.1	33.8	28.8	33.2	28.6	32.7	28.4	29.9	32.7	29.3	32.3	28.9	31.9	3.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.1	25.8	32.2	28.5	24.9	31.8	28.0	24.2	31.4	99.2	32.9	96.3	32.3	94.2	32.1	32.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	6.8	6.0	17.5	36.2	2.1	2.6	16.0	38.0	14.7	39.5	13.5	40.9	12.0	42.8		
(5)			16.7	31.1	1.5	1.0	15.6	31.8	14.7	32.4	13.8	32.9	12.7	33.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	24.1	24.7	25.5	27.1	28.5	28.9	28.2	28.4	28.1	27.2	26.1	25.2
	DBStd	1.99	1.35	1.46	1.36	1.25	1.09	1.03	1.13	0.99	1.01	1.09	1.08	1.27
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6145	437	410	481	514	574	568	564	570	543	532	483	469
	CDD18.3	3103	178	177	222	264	316	318	306	312	292	273	233	211
	CDH23.3	29347	800	1023	1563	2577	3641	3867	3423	3550	3156	2613	1830	1303
	CDH26.7	9833	95	204	384	886	1485	1662	1272	1343	1113	781	397	209
Wind	WSAvg	2.4	3.1	2.4	2.3	1.8	1.8	1.9	2.2	2.7	2.1	2.8	2.8	3.3
Precipitation	PrecAvg	3489	218	147	177	125	227	241	273	235	284	392	687	467
	PrecMax	6884	466	763	602	277	1084	598	661	459	680	1098	1777	1297
	PrecMin	1354	39	14	53	24	26	97	71	103	61	73	131	57
	PrecStd	1374	123	178	143	71	262	148	171	113	189	282	428	332
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.6	30.8	31.6	32.8	34.5	34.8	34.1	33.9	33.3	32.6	31.2	30.7
		MCWB	25.5	26.7	27.1	28.2	29.2	29.4	28.8	28.7	28.3	27.9	27.0	26.3
	2%	DB	28.6	29.9	30.7	32.2	33.6	33.8	33.1	33.0	32.6	31.7	30.4	29.7
		MCWB	25.3	25.9	26.7	27.8	28.9	28.9	28.5	28.5	28.1	27.4	26.7	26.3
	5%	DB	27.7	29.1	29.9	31.5	32.8	33.1	32.3	32.3	32.0	31.1	29.8	28.8
		MCWB	24.8	25.5	26.4	27.5	28.6	28.8	28.2	28.2	27.9	27.1	26.4	25.7
	10%	DB	26.8	28.0	29.0	30.8	32.1	32.4	31.6	31.5	31.2	30.3	29.0	27.9
		MCWB	24.3	25.0	25.9	27.2	28.2	28.5	27.9	27.9	27.5	26.8	26.1	25.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	27.4	28.1	29.6	30.6	30.6	29.8	30.0	29.7	29.0	28.0	27.7
		MCDB	28.8	30.1	30.6	31.9	33.1	33.5	32.8	32.6	32.2	31.7	30.2	29.7
	2%	WB	25.9	26.6	27.3	28.6	29.8	29.8	29.0	29.1	28.8	28.1	27.3	26.9
		MCDB	27.9	29.2	29.9	31.4	32.6	32.9	32.2	32.1	31.6	30.9	29.6	28.9
	5%	WB	25.2	26.0	26.7	28.0	29.1	29.2	28.5	28.6	28.2	27.6	26.8	26.2
		MCDB	27.1	28.5	29.3	31.0	32.1	32.4	31.7	31.6	31.2	30.3	29.1	28.1
	10%	WB	24.6	25.3	26.1	27.4	28.5	28.7	28.0	28.0	27.7	27.1	26.2	25.6
		MCDB	26.4	27.5	28.7	30.4	31.5	31.9	31.2	31.1	30.6	29.7	28.4	27.4
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.2	6.4	7.3	7.4	7.1	6.4	6.3	6.5	6.3	5.5	5.0
		MCDBR	6.9	7.9	8.1	8.4	8.5	8.2	7.9	7.6	7.5	7.6	6.8	6.7
		MCWBR	4.5	5.0	5.0	4.9	4.9	4.6	4.4	4.3	4.2	4.4	4.3	4.3
	5% WB	MCDBR	6.2	7.3	7.5	7.9	8.1	7.8	7.5	7.2	7.2	7.1	6.2	5.9
		MCWBR	4.4	5.1	5.0	5.2	5.3	5.0	4.6	4.6	4.5	4.6	4.2	4.2
Clear-Sky Solar Irradiance	taub	0.435	0.428	0.462	0.463	0.457	0.441	0.439	0.445	0.454	0.460	0.457	0.471	
	taud	2.369	2.394	2.294	2.308	2.355	2.410	2.414	2.388	2.358	2.331	2.329	2.243	
	Ebn at Noon	853	879	856	851	844	850	852	856	851	837	825	803	
	Edh at Noon	118	120	136	135	126	118	118	122	126	126	122	122	131
All-Sky Solar Radiation	RadAvg	3.57	4.38	5.08	6.05	6.05	5.79	5.14	5.03	5.02	4.31	3.71	3.19	
	RadStd	0.33	0.55	0.49	0.39	0.47	0.46	0.45	0.36	0.35	0.32	0.48	0.37	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page