

SUBIC BAY WEATHER, Philippines

WMO: 984260

Lat: 14.800N

Lon: 120.267E

Elev: 62

StdP: 14.66

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 41231

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	70.9	71.8	58.9	74.3	79.6	60.6	79.2	80.0	23.4	82.2	21.3	82.9	5.1	70	0.405

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	15.6	95.4	76.5	93.7	76.7	92.4	77.0	81.7	89.0	80.9	87.9	80.1	87.0	11.4	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.6	154.0	86.2	79.0	150.9	85.4	78.6	148.6	84.9	45.6	89.2	44.6	88.5	44.0	87.8	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.4	19.0	16.7	67.4	99.1	1.7	1.8	66.2	100.4	65.2	101.4	64.2	102.5	63.0	103.8		
(5)			61.9	84.6	2.0	1.3	60.5	85.5	59.3	86.3	58.2	87.0	56.7	88.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.3	80.2	81.2	83.3	85.5	84.9	83.0	81.5	81.2	81.4	82.1	82.0	81.0		
	DBStd	2.55	1.95	1.95	1.92	2.01	2.74	2.33	2.09	1.86	1.89	1.67	1.73	1.96		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	11781	936	875	1034	1065	1081	990	976	968	941	994	961	960		
	CDD65	6306	471	455	569	615	616	540	511	503	491	529	511	495		
	CDH74	67047	4150	4329	6292	7753	7719	6144	5208	5104	4876	5525	5250	4697		
	CDH80	25029	1349	1608	2709	3744	3567	2351	1620	1453	1459	1905	1787	1477		
	WSAvg	7.7	8.8	8.8	8.4	8.0	7.1	6.9	7.4	8.0	6.5	6.7	7.5	8.7		
	PrecAvg	145.1	0.1	0.1	0.1	0.6	10.3	23.4	28.5	44.5	22.7	9.2	2.9	0.4		
(15) Precipitation	PrecMax	212.6	1.0	1.0	0.8	3.5	55.5	81.7	74.4	96.9	42.9	28.2	14.1	1.3		
	PrecMin	84.5	0.0	0.0	0.0	0.0	0.0	2.8	6.9	13.1	0.8	0.2	0.0	0.0		
	PrecStd	33.6	0.2	0.2	0.2	0.8	12.5	17.9	14.5	20.2	11.5	8.0	3.2	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.2	93.0	95.3	97.2	98.3	95.1	91.8	90.8	91.4	91.7	91.5	91.0		
		MCWB	74.5	74.0	75.1	76.1	77.5	79.4	79.4	79.5	79.5	77.8	76.9	75.6		
	2%	DB	89.3	91.2	93.5	95.7	95.4	92.1	89.9	89.2	89.5	90.2	89.9	89.5		
		MCWB	74.3	73.8	74.5	76.0	77.4	79.7	79.0	79.1	78.7	77.7	76.6	75.7		
	5%	DB	87.8	89.6	91.7	94.4	93.3	90.0	88.2	87.6	88.0	89.4	89.3	88.0		
		MCWB	73.9	73.7	74.5	76.1	78.6	79.5	79.0	78.7	78.9	77.8	76.6	75.3		
	10%	DB	86.3	87.9	90.0	92.3	91.3	89.0	87.0	86.0	86.4	87.9	87.8	86.5		
		MCWB	73.4	73.6	74.8	76.7	78.9	79.3	78.8	78.3	78.7	77.8	76.6	74.7		
	0.4%	WB	77.9	78.8	80.6	82.2	82.9	82.8	81.1	81.5	81.5	81.3	80.1	79.2		
		MCDB	85.9	86.9	89.9	91.3	91.3	90.3	87.1	85.7	87.5	87.5	86.9	86.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	76.5	77.3	78.9	80.6	81.5	81.3	80.1	80.3	80.1	80.0	79.1	77.9		
		MCDB	85.2	85.9	87.7	89.5	89.8	88.7	86.4	84.9	86.0	86.8	86.2	85.5		
	5%	WB	75.6	76.2	77.7	79.7	80.5	80.3	79.7	79.8	79.6	79.2	78.3	76.9		
		MCDB	84.3	85.1	86.7	88.7	88.7	87.5	85.8	84.5	85.4	86.0	85.6	85.2		
	10%	WB	74.8	75.2	76.8	78.9	79.8	79.7	79.1	79.2	79.0	78.6	77.5	75.9		
		MCDB	83.5	84.3	85.9	87.9	88.0	86.6	85.1	84.0	84.8	85.4	85.0	84.0		
	5% DB	MDBR	14.0	15.2	16.2	15.6	13.3	11.6	10.4	9.4	10.6	12.3	12.4	12.5		
		MCDBR	15.2	16.6	17.7	17.9	16.5	13.9	13.2	12.0	12.9	14.2	14.0	14.0		
		MCWBR	6.1	6.2	6.3	6.5	6.4	5.9	5.9	5.6	5.9	6.0	5.8	5.9		
		MCWBR	14.2	14.9	15.6	15.0	13.7	12.3	11.2	9.8	11.3	12.5	12.6	12.8		
(35) Mean Daily Temperature Range	5% WB	MCWBR	6.4	6.7	6.9	6.5	6.2	5.9	5.6	5.3	5.9	6.0	6.1	6.0		
(40) Clear-Sky Solar Irradiance	taub		0.414	0.421	0.458	0.497	0.476	0.468	0.468	0.473	0.468	0.484	0.433	0.428		
	taud		2.448	2.411	2.313	2.208	2.303	2.344	2.340	2.317	2.324	2.256	2.423	2.421		
	Ebn at Noon		279	282	273	261	263	262	263	264	267	260	271	271		
	Edh at Noon		35	38	43	47	42	40	40	42	42	43	36	35		
(44) All-Sky Solar Radiation	RadAvg		1524	1758	1969	2114	1865	1640	1442	1380	1509	1556	1482	1383		
	RadStd		74	112	94	94	170	202	215	166	165	127	119	94		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+1.30	+0.72	+0.54	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)	+0.47	N/A	N/A	N/A	+0.61	+0.76	N/A	N/A	+284	+284

Nomenclature: See separate page