

TAYABAS, Philippines

WMO: 984270

Lat: 14.0184N

Lon: 121.5967E

Elev: 518

StdP: 14.42

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	70.3	71.3	66.0	97.5	72.6	67.1	101.7	73.1	16.3	75.8	14.5	76.2	5.4	0	0.291

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.4	91.2	81.2	90.1	81.0	89.2	80.8	83.1	88.5	82.4	88.1	81.8	87.5	4.4	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.7	168.1	87.4	80.9	163.4	86.9	80.1	159.2	86.3	47.7	88.9	46.8	88.2	46.1	87.7	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.0	12.2	11.1	DB	65.9	94.9	4.5	3.2	62.6	97.2	60.0	99.1	57.4	100.9	54.1	103.2
			WB	62.8	84.6	3.8	1.1	60.1	85.3	57.8	85.9	55.7	86.5	53.0	87.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.0	76.6	77.4	79.1	81.8	82.8	82.1	80.9	81.1	80.7	80.1	79.4	77.6	(6)
	DBStd	2.73	2.14	2.21	2.17	2.02	1.88	1.80	1.92	1.75	1.76	1.74	1.84	2.22	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD50	10945	825	768	902	955	1017	962	957	965	922	933	883	856	(10)
	CDD65	5470	360	348	437	505	552	512	492	500	472	468	433	391	(11)
	CDH74	47546	1752	2048	3339	5094	6043	5456	4707	4897	4328	4056	3440	2386	(12)
	CDH80	13172	187	345	805	1718	2219	1883	1355	1472	1255	981	650	302	(13)
(14) Wind	WSAvg	3.9	5.8	5.0	4.7	3.6	2.6	2.2	2.6	2.9	2.5	3.5	4.8	6.1	(14)
(15) Precipitation	PrecAvg	96.0	3.6	3.0	2.1	2.5	5.6	8.2	8.7	7.4	11.0	14.1	15.6	14.2	(15)
	PrecMax	143.2	9.0	10.6	6.0	13.6	19.5	16.9	18.4	18.1	24.9	31.7	33.5	35.2	(16)
	PrecMin	38.7	0.9	0.1	0.7	0.1	0.0	2.0	2.2	3.1	3.8	5.0	4.1	3.2	(17)
	PrecStd	32.2	2.8	3.1	1.7	3.3	5.4	4.3	4.6	3.4	5.8	7.0	9.0	9.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.4	86.9	89.0	91.8	92.7	91.8	90.9	90.9	90.6	89.3	88.0	86.6	(19)
		MCWB	78.3	79.6	79.8	80.3	81.1	81.6	81.8	81.6	81.7	81.0	80.5	79.6	(20)
	2%	DB	83.7	85.3	87.3	90.3	91.2	90.4	89.1	89.5	89.1	87.8	86.6	84.9	(21)
		MCWB	77.6	78.4	79.0	80.1	81.0	81.5	81.2	81.2	81.2	80.3	79.9	78.7	(22)
	5%	DB	82.2	83.9	86.1	88.9	89.9	89.2	87.8	88.1	87.7	86.6	85.3	83.2	(23)
		MCWB	76.6	77.5	78.7	79.8	80.8	81.3	80.7	80.6	80.8	79.9	79.3	77.8	(24)
	10%	DB	80.6	82.4	84.7	87.6	88.6	87.9	86.3	86.5	86.2	85.1	83.8	81.6	(25)
		MCWB	75.5	76.5	77.9	79.4	80.6	80.8	80.1	80.1	80.2	79.2	78.6	76.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.9	81.0	81.6	83.0	83.9	84.1	83.4	83.6	83.4	82.7	81.8	80.8	(27)
		MCDB	83.9	85.3	86.5	88.1	89.2	89.3	88.7	88.8	88.6	87.4	86.2	85.0	(28)
	2%	WB	78.2	79.4	80.2	81.5	82.6	82.7	82.2	82.4	82.2	81.5	80.7	79.3	(29)
		MCDB	82.6	84.1	85.9	87.9	88.8	88.6	87.7	87.9	87.6	86.4	85.5	83.7	(30)
	5%	WB	77.1	78.1	79.1	80.6	81.7	81.8	81.2	81.2	81.2	80.5	79.8	78.3	(31)
		MCDB	81.3	82.8	85.0	87.7	88.1	87.8	86.7	86.8	86.6	85.5	84.4	82.4	(32)
	10%	WB	76.1	76.9	78.2	79.8	80.9	81.0	80.4	80.3	80.3	79.5	78.8	77.3	(33)
		MCDB	79.8	81.6	83.8	86.7	87.4	86.9	85.8	85.8	85.7	84.3	83.2	80.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	9.3	10.4	12.0	12.4	12.0	11.0	11.2	11.6	10.3	8.7	7.3	(35)
		MCDBR	10.0	11.7	12.8	13.7	14.0	14.1	13.4	13.7	13.8	12.7	11.1	9.7	(36)
	5% WB	MCWBR	6.1	6.8	7.0	6.6	7.1	8.0	8.0	8.0	8.6	7.6	6.7	5.8	(37)
		MCWBR	9.4	11.1	12.2	12.8	13.2	13.0	12.6	12.7	13.2	11.8	10.4	9.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.429	0.419	0.442	0.447	0.448	0.445	0.441	0.448	0.446	0.462	0.443	0.452	(40)
		taud	2.384	2.405	2.343	2.335	2.362	2.385	2.398	2.371	2.372	2.307	2.365	2.312	(41)
	Ebn at Noon		275	283	278	275	270	268	270	271	273	267	269	264	(42)
		Edh at Noon	37	38	41	42	40	38	38	40	40	41	38	39	(43)
(44) All-Sky Solar Radiation	RadAvg		1242	1500	1707	1956	1803	1657	1494	1471	1496	1369	1270	1102	(44)
	RadStd		100	161	148	119	155	120	146	106	131	97	118	110	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (16 neighbors)	+0.56	+0.88	N/A	+0.81	+0.67	+0.85	N/A	N/A	+284	+284

Nomenclature: See separate page