

SANGLEY POINT, Philippines

WMO: 984280

Lat: 14.495N

Lon: 120.904E

Elev: 8

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	73.9	75.0	67.0	99.3	77.4	68.3	103.8	78.0	18.0	82.3	16.3	82.4	5.8	0	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.0	95.6	83.4	94.4	83.1	93.4	82.8	84.5	93.3	84.0	92.5	83.5	91.7	8.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.9	166.2	90.8	81.6	164.4	90.4	81.1	161.5	89.9	48.6	93.8	48.1	93.2	47.6	92.2	90.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	15.8	14.0	69.0	99.3	5.6	1.9	65.0	100.6	61.7	101.7	58.6	102.8	54.6	104.2		
(5)			65.7	86.0	3.9	1.6	62.9	87.1	60.7	88.1	58.5	89.0	55.7	90.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	84.0	81.0	82.1	84.0	86.9	87.2	85.6	83.9	83.6	83.6	84.2	83.5	81.9	(6)
(7)		DBStd	2.95	2.06	2.03	2.11	2.04	2.72	2.75	2.75	2.57	2.45	2.09	2.08	2.24	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	12402	962	899	1055	1106	1154	1067	1052	1043	1009	1061	1004	990	(10)
(11)		CDD65	6927	497	479	590	656	689	617	587	578	559	596	554	525	(11)
(12)		CDH74	81856	4805	4936	6928	8706	9289	7898	6913	6763	6503	7161	6412	5542	(12)
(13)		CDH80	33291	1277	1574	2772	4435	4911	3722	2734	2575	2472	2847	2336	1636	(13)
(14)	Wind	WSAvg	6.9	6.9	7.7	8.0	8.1	7.0	6.5	6.6	7.0	6.3	6.1	6.4	6.7	(14)
(15)	Precipitation	PrecAvg	76.9	0.7	0.7	0.7	0.6	5.1	8.4	15.6	17.1	13.0	7.6	4.1	3.3	(15)
(16)		PrecMax	127.6	2.6	3.7	3.5	5.6	13.1	26.5	51.7	41.3	30.8	18.9	10.2	11.0	(16)
(17)		PrecMin	50.6	0.0	0.0	0.0	0.0	0.2	3.0	2.6	5.3	4.3	1.4	0.4	0.0	(17)
(18)		PrecStd	20.5	0.8	1.1	0.9	1.1	3.5	4.8	9.6	9.5	5.9	4.1	2.7	2.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.8	91.8	94.0	96.8	97.3	96.1	94.2	93.6	93.3	93.5	92.4	90.9	(19)
(20)			MCWB	80.3	81.2	82.6	83.5	83.8	84.3	83.8	83.7	83.7	83.0	82.3	81.0	(20)
(21)		2%	DB	88.2	90.0	92.4	95.1	95.9	94.2	92.5	91.7	91.7	91.7	90.8	89.3	(21)
(22)			MCWB	79.5	80.2	81.8	83.1	83.4	83.5	83.3	83.0	83.0	82.4	81.8	80.6	(22)
(23)		5%	DB	87.0	88.7	91.1	94.0	94.7	92.7	91.0	90.2	90.3	90.3	89.6	87.9	(23)
(24)			MCWB	78.9	79.4	80.9	82.5	83.2	83.1	82.6	82.4	82.4	81.9	81.2	80.0	(24)
(25)		10%	DB	85.7	87.3	89.7	92.7	93.3	91.3	89.4	88.7	88.8	89.1	88.2	86.4	(25)
(26)			MCWB	78.0	78.7	80.1	81.9	82.7	82.6	82.0	81.7	81.8	81.4	80.5	79.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	82.8	83.8	84.8	85.5	85.2	84.5	84.4	84.3	84.1	83.7	82.6	(27)
(28)			MCD B	88.3	90.1	92.5	94.6	95.1	94.3	92.5	92.1	91.7	91.7	90.5	88.9	(28)
(29)		2%	WB	80.7	81.4	82.8	83.9	84.4	84.1	83.6	83.5	83.4	83.2	82.7	81.5	(29)
(30)			MCD B	87.1	88.8	91.1	93.6	94.0	92.6	91.2	90.6	90.5	90.4	89.5	87.9	(30)
(31)		5%	WB	79.6	80.3	81.8	83.3	83.7	83.5	82.8	82.7	82.7	82.5	81.8	80.6	(31)
(32)			MCD B	85.9	87.6	89.8	92.7	93.0	91.5	90.0	89.4	89.4	89.3	88.4	86.9	(32)
(33)		10%	WB	78.6	79.2	80.8	82.4	83.1	82.8	82.1	81.9	82.0	81.7	80.9	79.7	(33)
(34)			MCD B	84.7	86.1	88.6	91.6	91.9	90.4	88.7	88.0	88.1	88.0	87.2	85.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.7	10.8	11.7	12.5	12.0	10.7	9.6	9.1	9.6	9.7	9.3	8.8	(35)
(36)			MCDBR	11.2	12.5	13.4	13.9	13.6	12.5	12.2	11.6	11.7	11.5	11.2	10.6	(36)
(37)			MCWBR	6.1	6.5	6.8	6.6	6.0	5.8	6.0	5.8	5.8	5.7	5.7	5.5	(37)
(38)		5% WB	MCD BR	10.6	11.9	12.8	13.5	12.9	12.0	11.6	11.0	11.1	11.0	10.6	10.1	(38)
(39)			MCWBR	6.4	7.1	7.4	7.0	6.2	6.0	6.0	5.9	5.9	5.8	6.1	5.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.421	0.420	0.451	0.478	0.475	0.468	0.465	0.471	0.467	0.479	0.439	0.439	(40)	
(41)		taud	2.425	2.413	2.329	2.258	2.295	2.330	2.339	2.311	2.317	2.265	2.397	2.379	(41)	
(42)		Ebn at Noon	277	283	276	266	263	262	263	265	267	261	270	268	(42)	
(43)		Edh at Noon	36	38	42	45	43	41	40	42	42	43	36	37	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1366	1613	1821	2032	1827	1630	1434	1386	1476	1434	1351	1219	(44)	
(45)		RadStd	82	134	120	105	165	168	190	148	152	117	117	103	45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	+0.58	+0.85	N/A	+0.81	+0.72	+0.97	N/A	N/A	+284	+284

Nomenclature: See separate page