

SANGLEY POINT, Philippines

WMO: 984280

Lat: 14.495N

Lon: 120.904E

Elev: 2

StdP: 101.30

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.3	23.9	19.4	14.2	25.2	20.1	14.8	25.6	8.1	27.9	7.3	28.0	2.6	0	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.6	35.3	28.6	34.7	28.4	34.1	28.2	29.2	34.0	28.9	33.6	28.6	33.2	3.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.7	23.7	32.7	27.6	23.5	32.5	27.3	23.1	32.2	95.1	34.4	93.9	34.0	92.8	33.5	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.1	6.3	DB	20.6	37.4	3.1	1.1	18.3	38.1	16.5	38.7	14.8	39.3	12.5	40.1	(4)
(5)			WB	18.7	30.0	2.2	0.9	17.2	30.6	15.9	31.1	14.7	31.7	13.1	32.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.9	27.2	27.8	28.9	30.5	30.7	29.8	28.9	28.7	28.7	29.0	28.6	27.7		
	DBStd	1.64	1.14	1.13	1.17	1.13	1.51	1.53	1.53	1.43	1.36	1.16	1.16	1.24		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6890	534	499	586	614	641	593	584	579	561	589	558	550		
	CDD18.3	3848	276	266	328	364	383	343	326	321	311	331	308	292		
	CDH23.3	45476	2669	2742	3849	4837	5161	4388	3841	3757	3613	3978	3562	3079		
	CDH26.7	18495	709	874	1540	2464	2728	2068	1519	1431	1373	1582	1298	909		
(14) Wind	WSAvg	3.1	3.1	3.4	3.6	3.6	3.1	2.9	2.9	3.1	2.8	2.7	2.8	3.0		
(15) Precipitation	PrecAvg	1954	17	18	19	16	130	214	396	434	330	192	104	83		
	PrecMax	3240	66	95	89	142	332	673	1313	1050	782	480	259	280		
	PrecMin	1285	0	0	0	0	5	76	65	135	110	36	9	0		
	PrecStd	520	20	27	24	28	90	123	243	241	151	103	69	74		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	33.2	34.4	36.0	36.3	35.6	34.6	34.2	34.1	34.2	33.6	32.7		
		MCWB	26.8	27.3	28.1	28.6	28.8	29.1	28.8	28.7	28.7	28.3	28.0	27.2		
	2%	DB	31.2	32.2	33.5	35.1	35.5	34.5	33.6	33.2	33.1	33.2	32.7	31.9		
		MCWB	26.4	26.8	27.7	28.4	28.6	28.6	28.5	28.3	28.3	28.0	27.7	27.0		
	5%	DB	30.6	31.5	32.8	34.4	34.8	33.7	32.8	32.4	32.4	32.4	32.0	31.0		
		MCWB	26.0	26.3	27.2	28.1	28.4	28.4	28.1	28.0	28.0	27.7	27.4	26.6		
	10%	DB	29.8	30.7	32.0	33.7	34.1	32.9	31.9	31.5	31.5	31.7	31.2	30.2		
		MCWB	25.6	25.9	26.7	27.7	28.2	28.1	27.8	27.6	27.7	27.4	27.0	26.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	28.2	28.8	29.3	29.7	29.5	29.1	29.1	29.0	29.0	28.7	28.1		
		MCDB	31.3	32.3	33.6	34.8	35.1	34.6	33.6	33.4	33.2	33.2	32.5	31.6		
	2%	WB	27.0	27.5	28.2	28.8	29.1	29.0	28.7	28.6	28.6	28.4	28.2	27.5		
		MCDB	30.6	31.5	32.8	34.2	34.5	33.7	32.9	32.6	32.5	32.5	31.9	31.0		
	5%	WB	26.5	26.9	27.6	28.5	28.7	28.6	28.2	28.2	28.2	28.0	27.7	27.0		
		MCDB	30.0	30.9	32.1	33.7	33.9	33.1	32.2	31.9	31.9	31.9	31.3	30.5		
	10%	WB	25.9	26.2	27.1	28.0	28.4	28.2	27.8	27.7	27.8	27.6	27.2	26.5		
		MCDB	29.3	30.0	31.4	33.1	33.3	32.4	31.5	31.1	31.2	31.1	30.7	29.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	6.0	6.5	7.0	6.6	5.9	5.4	5.0	5.3	5.4	5.2	4.9		
		MCDBR	6.2	7.0	7.4	7.7	7.5	6.9	6.8	6.4	6.5	6.4	6.2	5.9		
	5% WB	MCWBR	3.4	3.6	3.8	3.6	3.3	3.2	3.3	3.2	3.2	3.1	3.2	3.0		
		MCWBR	5.9	6.6	7.1	7.5	7.2	6.7	6.4	6.1	6.2	6.1	5.9	5.6		
(40) Clear-Sky Solar Irradiance	taub	taub	0.421	0.420	0.451	0.478	0.475	0.468	0.465	0.471	0.467	0.479	0.439	0.439		
		taud	2.425	2.413	2.329	2.258	2.295	2.330	2.339	2.311	2.317	2.265	2.397	2.379		
	Ebn at Noon	Ebn at Noon	874	891	869	840	829	826	830	834	842	824	850	844		
		Edh at Noon	113	119	132	141	134	128	127	132	132	136	115	116		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	4.30	5.08	5.74	6.41	5.76	5.14	4.52	4.37	4.65	4.52	4.26	3.84		
	RadStd	RadStd	0.26	0.42	0.38	0.33	0.52	0.53	0.60	0.47	0.48	0.37	0.37	0.33		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)		+0.32	+0.47	N/A	+0.45	+0.40	+0.54	N/A	N/A	+158	+158

Nomenclature: See separate page