

AMBULONG, Philippines

WMO: 984320

Lat: 14.0877N

Lon: 121.0625E

Elev: 36

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 71.3	(c) 73.0	(d) 66.2	(e) 96.6	(f) 74.3	(g) 67.5	(h) 101.2	(i) 75.5	(j) 15.6	(k) 78.4	(l) 14.1	(m) 80.2	(n) 3.1	(o) 40	(p) 0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.5	94.8	82.8	93.6	82.4	92.5	82.1	84.9	91.8	84.1	91.0	83.5	90.2	4.8	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.0	172.5	90.3	82.3	168.2	89.4	81.6	164.6	88.6	49.2	92.3	48.3	91.2	47.5	90.4	95.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 13.4	(b) 11.8	(c) 10.5	(e) 67.0	(f) 98.3	(g) 4.5	(h) 2.6	(i) 63.8	(j) 100.2	(k) 61.2	(l) 101.7	(m) 58.6	(n) 103.1	(o) 55.4	(p) 105.0		
(a) 13.4	(b) 11.8	(c) 10.5	(e) 65.9	(f) 87.4	(g) 3.6	(h) 2.7	(i) 63.3	(j) 89.3	(k) 61.2	(l) 90.9	(m) 59.1	(n) 92.3	(o) 56.5	(p) 94.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.7	79.9	80.5	82.6	85.1	85.4	84.4	83.0	82.9	82.8	82.6	82.5	81.0	
	DBStd	2.59	2.26	2.27	2.22	1.96	1.91	1.99	1.98	1.93	2.06	1.84	1.88	1.95	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11946	925	855	1011	1053	1098	1032	1022	1021	984	1009	974	962	
	CDD65	6471	460	435	546	603	633	582	557	556	534	544	524	497	
	CDH74	70432	3835	3893	5862	7523	8029	7057	6154	6258	5809	5843	5524	4645	
CDH80	25562	879	1161	2218	3538	3753	2969	2108	2140	1949	1979	1753	1115		
Wind	WSAvg	4.1	5.5	4.9	4.5	3.5	3.0	3.0	3.5	4.3	3.4	3.5	4.3	5.5	
Precipitation	PrecAvg	74.8	1.1	0.4	0.6	1.4	5.3	10.8	12.4	11.7	11.1	7.8	7.6	4.5	
	PrecMax	98.9	6.3	2.1	1.8	4.1	20.5	21.3	43.1	25.0	32.2	16.9	13.7	12.5	
	PrecMin	46.4	0.1	0.0	0.0	0.0	1.5	4.3	3.1	3.5	1.7	1.9	0.7	0.3	
	PrecStd	17.4	1.8	0.6	0.6	1.2	5.1	5.4	10.0	5.6	6.8	5.4	4.1	3.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.5	91.4	94.3	96.3	96.4	95.1	92.9	92.6	92.6	92.0	91.6	89.9	
		MCWB	80.3	80.0	81.9	82.6	83.5	83.9	83.6	82.4	83.3	82.4	82.1	80.5	
	2%	DB	87.6	89.2	92.1	94.8	94.7	93.3	91.1	90.6	90.7	90.5	89.8	88.2	
		MCWB	79.2	79.3	81.0	81.9	83.1	83.5	82.7	82.4	82.6	81.5	81.1	79.9	
	5%	DB	86.2	87.9	90.7	93.6	93.3	91.7	89.6	89.1	89.3	89.2	88.7	87.0	
		MCWB	78.2	78.3	80.3	81.6	82.7	83.0	81.9	81.7	81.9	80.9	80.5	79.2	
	10%	DB	84.7	86.4	89.3	92.3	91.8	90.3	88.1	87.6	87.8	87.9	87.5	85.5	
		MCWB	77.3	77.7	79.5	81.2	82.4	82.5	81.3	81.1	81.3	80.4	79.9	78.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.4	83.3	84.5	85.3	85.9	85.5	85.0	84.6	85.1	84.2	83.6	82.1
			MCDB	87.7	88.4	91.0	93.8	93.3	93.0	91.1	90.3	90.5	90.2	90.0	87.8
2%		WB	80.0	81.2	82.7	83.7	84.5	84.4	83.7	83.4	83.5	82.8	82.2	80.8	
		MCDB	86.4	87.0	90.1	92.5	92.1	91.5	89.5	88.8	89.1	88.8	88.5	86.8	
5%		WB	78.9	79.6	81.3	82.8	83.6	83.6	82.7	82.4	82.5	81.8	81.3	79.8	
		MCDB	85.1	86.1	89.3	91.6	91.1	90.3	88.4	87.7	88.2	87.6	87.3	85.5	
10%		WB	77.9	78.2	80.0	81.8	82.8	82.8	81.8	81.6	81.7	81.0	80.5	79.0	
		MCDB	83.4	84.8	87.9	90.5	90.0	89.2	87.0	86.4	86.9	86.4	86.2	84.3	
Mean Daily Temperature Range		5% DB	MDBR	10.0	12.4	13.7	15.1	13.5	11.8	10.3	9.5	10.3	11.1	10.6	9.1
			MCDBR	12.1	14.7	16.1	17.1	15.6	14.0	12.9	12.4	12.8	13.3	12.6	11.5
	MCWBR		6.1	7.0	7.4	7.3	6.8	6.6	6.5	6.1	6.4	6.4	5.8	5.5	
	5% WB	MCDBR	11.5	12.9	15.3	16.1	14.0	13.3	12.1	11.1	12.1	12.1	11.8	10.7	
		MCWBR	6.5	7.4	8.2	8.0	7.3	7.1	6.9	6.2	6.6	6.6	6.2	5.6	
Clear-Sky Solar Irradiance	taub	0.427	0.423	0.450	0.467	0.467	0.463	0.459	0.466	0.462	0.477	0.443	0.447		
	taud	2.396	2.398	2.325	2.281	2.310	2.339	2.349	2.320	2.325	2.263	2.371	2.342		
	Ebn at Noon	276	282	276	269	265	263	265	266	269	262	269	266		
	Edh at Noon	37	38	42	44	42	40	40	42	42	43	38	38		
All-Sky Solar Radiation	RadAvg	1353	1606	1812	2025	1826	1639	1458	1421	1487	1434	1351	1205		
	RadStd	93	146	131	110	165	153	180	133	152	112	120	108		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)	+0.56	+0.88	N/A	+0.81	+0.67	+0.85	N/A	N/A	+284	+284

Nomenclature: See separate page