

TANAY, Philippines

WMO: 984330

Lat: 14.5812N

Lon: 121.3690E

Elev: 2136

StdP: 13.60

Time Zone: 8.00 (E08)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	64.1	65.3	59.9	83.2	65.9	61.3	87.7	67.0	27.9	65.9	25.9	67.2	11.6	40	0.278

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	10.9	85.4	76.6	84.0	76.2	82.7	76.0	78.3	82.7	77.3	81.9	76.7	81.2	6.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.0	152.5	81.4	76.0	147.2	80.6	75.3	143.6	80.1	43.6	83.0	42.6	82.3	41.9	81.6	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	18.4	16.1	62.5	88.5	2.5	2.5	60.7	90.3	59.3	91.7	57.9	93.1	56.1	94.9
			60.2	81.0	1.4	2.1	59.2	82.5	58.3	83.7	57.5	84.9	56.5	86.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.1	70.4	71.3	73.2	76.0	77.7	76.5	74.9	74.4	74.7	74.3	73.6	72.0
	DBStd	2.92	2.29	2.16	2.17	2.31	2.12	2.21	2.23	2.14	1.95	1.72	1.61	1.86
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1	1	0	0	0	0	0	0	0	0	0	0	0
	CDD50	8790	631	596	718	779	858	796	772	758	741	753	707	681
	CDD65	3316	167	176	253	329	393	346	307	293	291	288	257	216
	CDH74	10677	126	264	700	1619	2258	1646	982	787	859	724	476	236
	CDH80	1221	1	4	37	267	458	227	82	59	54	24	7	1
Wind	WSAvg	7.9	10.3	9.5	8.7	7.6	6.4	6.5	6.8	7.7	6.7	7.2	8.7	9.5
Precipitation	PrecAvg	107.5	4.2	3.7	3.4	2.0	6.7	8.6	14.9	15.5	14.4	11.6	11.0	10.7
	PrecMax	141.5	10.5	11.9	9.2	11.0	14.0	19.9	35.4	33.1	33.0	20.4	17.8	18.8
	PrecMin	71.6	1.2	0.0	0.2	0.0	0.9	3.8	6.9	7.9	6.9	3.5	3.0	1.4
	PrecStd	23.8	2.8	3.3	2.3	2.5	4.1	4.4	7.6	6.1	6.2	3.6	5.0	5.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.8	80.5	82.8	86.4	87.6	86.0	84.1	83.7	83.4	82.0	81.0	79.6
		MCWB	73.0	73.6	74.7	76.3	76.9	77.6	77.3	77.3	76.7	75.7	75.7	74.4
	2%	DB	76.8	78.6	80.9	84.5	85.8	84.0	82.1	81.6	81.5	80.7	79.3	77.9
		MCWB	72.1	72.3	73.6	75.4	76.5	77.3	76.3	76.1	76.1	75.2	74.6	73.2
	5%	DB	75.4	77.1	79.5	83.0	84.4	82.6	80.6	80.0	80.1	79.4	78.0	76.5
		MCWB	71.1	71.5	72.9	74.8	76.2	76.9	75.9	75.4	75.5	74.6	73.8	72.5
	10%	DB	73.9	75.6	78.0	81.5	82.7	81.2	79.1	78.3	78.6	77.9	76.8	75.2
		MCWB	70.3	70.6	72.1	74.3	75.9	76.2	75.1	74.6	74.8	73.8	73.1	71.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.9	75.0	76.2	78.0	79.5	80.7	78.5	78.7	77.7	77.1	76.5	75.3
		MCDB	77.0	78.9	81.0	83.6	84.0	83.1	82.1	81.8	81.2	80.4	79.9	78.4
	2%	WB	72.7	73.4	74.7	76.8	77.9	78.2	77.0	76.7	76.6	76.0	75.2	74.0
		MCDB	75.6	77.3	79.6	82.7	83.2	82.5	81.1	80.4	80.4	79.3	78.4	76.8
	5%	WB	71.7	72.2	73.5	75.7	77.0	77.1	76.1	75.6	75.8	75.0	74.3	73.0
		MCDB	74.6	75.9	78.4	81.6	82.6	81.6	79.9	79.1	79.3	78.4	77.3	75.5
	10%	WB	70.7	71.1	72.5	74.7	76.2	76.2	75.2	74.6	74.9	74.1	73.4	72.0
		MCDB	73.3	74.5	77.0	80.3	81.5	80.4	78.6	77.5	78.1	77.1	76.2	74.3
Mean Daily Temperature Range	5% DB	MDBR	6.6	8.5	9.6	11.1	10.9	9.0	7.7	6.8	7.5	7.6	6.9	6.1
		MCDBR	8.5	10.8	11.8	13.1	13.1	11.2	10.5	10.1	9.9	9.6	8.7	8.2
		MCWBR	5.6	6.6	6.9	6.8	6.4	6.6	6.4	6.2	6.1	6.1	5.7	5.5
	5% WB	MCDBR	8.0	9.8	11.0	12.2	11.6	10.5	9.9	9.3	9.2	8.9	8.2	7.4
		MCWBR	5.8	6.8	7.1	7.3	6.8	6.7	6.4	6.1	6.1	6.1	5.8	5.5
Clear-Sky Solar Irradiance	taub	0.385	0.380	0.404	0.417	0.425	0.420	0.416	0.424	0.421	0.427	0.404	0.406	
	taud	2.475	2.476	2.408	2.377	2.388	2.421	2.436	2.405	2.410	2.377	2.451	2.426	
	Ebn at Noon	289	295	289	283	276	275	277	277	280	277	280	278	
	Edh at Noon	34	35	39	40	39	37	37	38	38	38	35	35	
All-Sky Solar Radiation	RadAvg	1228	1472	1668	1929	1778	1621	1437	1393	1446	1332	1232	1080	
	RadStd	83	149	136	118	152	139	160	123	131	109	117	106	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	+0.58	+0.85	N/A	+0.81	+0.72	+0.97	N/A	N/A	+284	+284

Nomenclature: See separate page