

TANAY, Philippines

WMO: 984330

Lat: 14.5812N

Lon: 121.3690E

Elev: 651

StdP: 93.74

Time Zone: 8.00 (E08)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.9	18.5	15.5	11.9	18.8	16.3	12.5	19.4	12.5	18.8	11.6	19.6	5.2	40	0.278

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.1	29.7	24.8	28.9	24.6	28.2	24.4	25.7	28.2	25.2	27.7	24.8	27.3	3.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.0	21.8	27.5	24.4	21.0	27.0	24.1	20.5	26.7	83.6	28.3	81.3	28.0	79.6	27.5	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.2	7.2	DB	16.9	31.4	1.4	1.4	15.9	32.4	15.1	33.2	14.4	34.0	13.4	35.0	(4)
(5)			WB	15.7	27.2	0.8	1.2	15.1	28.1	14.6	28.7	14.2	29.4	13.6	30.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.4	21.3	21.8	22.9	24.4	25.4	24.7	23.8	23.6	23.7	23.5	23.1	22.2
	DBStd	1.62	1.27	1.20	1.21	1.28	1.18	1.23	1.24	1.19	1.08	0.96	0.89	1.03
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	1	1	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	4883	351	331	399	433	477	442	429	421	412	418	393	378
	CDD18.3	1842	93	98	141	183	218	192	171	163	162	160	143	120
	CDH23.3	5932	70	147	389	899	1254	914	546	437	477	402	264	131
	CDH26.7	678	1	2	21	148	254	126	46	33	30	13	4	1
Wind	WSAvg	3.6	4.6	4.2	3.9	3.4	2.9	2.9	3.0	3.4	3.0	3.2	3.9	4.2
Precipitation	PrecAvg	2731	107	93	86	50	171	218	378	394	367	295	280	272
	PrecMax	3595	266	302	234	279	355	505	900	840	839	517	452	478
	PrecMin	1818	30	0	6	0	24	97	175	201	174	89	77	36
	PrecStd	604	70	85	58	64	104	111	193	156	158	92	127	127
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	27.0	28.2	30.2	30.9	30.0	29.0	28.7	28.5	27.8	27.2	26.4
		MCWB	22.8	23.1	23.7	24.6	24.9	25.3	25.2	25.1	24.8	24.3	24.3	23.6
	2%	DB	24.9	25.9	27.2	29.2	29.9	28.9	27.8	27.6	27.5	27.0	26.3	25.5
		MCWB	22.3	22.4	23.1	24.1	24.7	25.1	24.6	24.5	24.5	24.0	23.6	22.9
	5%	DB	24.1	25.1	26.4	28.3	29.1	28.1	27.0	26.7	26.7	26.3	25.6	24.7
		MCWB	21.7	22.0	22.7	23.8	24.5	24.9	24.4	24.1	24.2	23.6	23.2	22.5
	10%	DB	23.3	24.2	25.6	27.5	28.2	27.3	26.1	25.7	25.9	25.5	24.9	24.0
		MCWB	21.3	21.5	22.3	23.5	24.4	24.6	23.9	23.6	23.8	23.2	22.8	22.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.3	23.9	24.6	25.6	26.4	27.1	25.8	25.9	25.4	25.0	24.7	24.0
		MCDB	25.0	26.1	27.2	28.7	28.9	28.4	27.9	27.7	27.3	26.9	26.6	25.8
	2%	WB	22.6	23.0	23.7	24.9	25.5	25.7	25.0	24.8	24.8	24.4	24.0	23.3
		MCDB	24.2	25.2	26.4	28.2	28.5	28.0	27.3	26.9	26.9	26.3	25.8	24.9
	5%	WB	22.1	22.3	23.1	24.3	25.0	25.1	24.5	24.2	24.3	23.9	23.5	22.8
		MCDB	23.7	24.4	25.8	27.5	28.1	27.5	26.6	26.1	26.3	25.8	25.2	24.2
	10%	WB	21.5	21.7	22.5	23.7	24.5	24.6	24.0	23.7	23.9	23.4	23.0	22.2
		MCDB	22.9	23.6	25.0	26.8	27.5	26.9	25.9	25.3	25.6	25.0	24.6	23.5
Mean Daily Temperature Range	5% DB	MDBR	3.7	4.7	5.3	6.2	6.1	5.0	4.3	3.8	4.2	4.2	3.8	3.4
		MCDBR	4.7	6.0	6.6	7.3	7.3	6.2	5.8	5.6	5.5	5.3	4.8	4.6
		MCWBR	3.1	3.7	3.8	3.8	3.6	3.6	3.5	3.4	3.4	3.4	3.2	3.0
	5% WB	MCDBR	4.4	5.4	6.1	6.8	6.4	5.8	5.5	5.1	5.1	4.9	4.6	4.1
		MCWBR	3.2	3.8	3.9	4.0	3.8	3.7	3.6	3.4	3.4	3.4	3.2	3.0
Clear-Sky Solar Irradiance	taub	0.385	0.380	0.404	0.417	0.425	0.420	0.416	0.424	0.421	0.427	0.404	0.406	
	taud	2.475	2.476	2.408	2.377	2.388	2.421	2.436	2.405	2.410	2.377	2.451	2.426	
	Ebn at Noon	910	930	911	892	871	866	872	874	883	872	884	877	
	Edh at Noon	107	111	122	126	122	117	116	121	120	121	109	110	
All-Sky Solar Radiation	RadAvg	3.87	4.64	5.26	6.08	5.61	5.11	4.53	4.39	4.56	4.20	3.88	3.40	
	RadStd	0.26	0.47	0.43	0.37	0.48	0.44	0.51	0.39	0.41	0.34	0.37	0.33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	+0.32	+0.47	N/A	+0.45	+0.40	+0.54	N/A	N/A	+158	+158

Nomenclature: See separate page