

DAET, Philippines

WMO: 984400

Lat: 14.1286N

Lon: 122.9825E

Elev: 3

StdP: 101.29

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.6	23.3	20.4	15.0	24.5	21.1	15.8	24.7	13.5	23.9	10.5	24.8	3.4	40	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.2	33.2	29.8	32.7	29.6	32.2	29.3	31.6	32.2	31.0	31.8	30.4	31.3	3.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.4	29.7	32.1	30.7	28.4	31.5	30.2	27.5	31.1	108.7	32.2	105.2	31.8	102.0	31.4	36.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.0	6.7	20.0	35.7	2.7	1.7	18.1	36.9	16.5	37.9	15.0	38.8	13.0	40.0		
(5)			19.3	32.1	2.6	1.7	17.4	33.4	15.9	34.4	14.5	35.3	12.6	36.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	26.0	26.1	26.9	28.1	28.8	28.7	28.2	28.3	28.0	27.5	27.5	26.8
	DBStd	1.36	1.12	1.13	1.13	1.03	0.91	1.04	1.00	1.10	0.98	0.97	0.96	0.94
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6421	496	452	525	543	582	561	565	568	539	543	526	521
	CDD18.3	3379	238	218	267	293	324	311	307	309	289	285	276	262
	CDH23.3	36082	1908	1841	2639	3455	4002	3705	3461	3508	3139	3037	2918	2471
	CDH26.7	11043	208	272	608	1232	1673	1498	1229	1255	1049	885	736	398
Wind	WSAvg	3.1	4.1	3.6	3.4	2.7	2.4	2.4	2.6	2.7	2.5	3.0	3.7	4.1
Precipitation	PrecAvg	3563	284	177	158	133	145	194	211	250	299	513	516	682
	PrecMax	5062	570	404	415	294	473	451	349	569	417	932	1410	1480
	PrecMin	1871	63	31	41	19	1	49	72	69	131	307	234	206
	PrecStd	844	137	114	109	87	146	107	73	141	73	175	293	381
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.6	30.1	31.1	32.7	34.1	34.2	33.2	33.5	33.2	32.2	31.2	30.3
		MCWB	27.5	28.2	28.3	30.0	30.0	30.1	30.1	29.7	29.6	28.6	28.5	27.8
	2%	DB	29.0	29.4	30.5	31.9	33.0	33.2	32.4	32.6	32.2	31.2	30.7	29.7
		MCWB	26.9	27.5	28.1	29.0	29.8	29.7	29.7	29.5	29.2	28.5	28.3	27.5
	5%	DB	28.5	28.9	30.0	31.2	32.4	32.6	31.8	31.9	31.5	30.7	30.1	29.1
		MCWB	26.5	26.9	27.9	28.7	29.5	29.5	29.4	29.1	28.8	28.3	28.1	27.2
	10%	DB	27.9	28.3	29.4	30.8	31.8	31.9	31.2	31.2	30.9	30.0	29.5	28.6
		MCWB	26.0	26.4	27.4	28.4	29.1	29.3	28.9	28.8	28.5	27.9	27.7	26.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.6	29.2	30.1	31.4	32.2	32.3	32.0	31.7	31.7	30.7	30.2	29.2
		MCDB	28.9	29.6	30.4	31.9	32.7	32.8	32.5	32.3	32.2	31.0	30.5	29.5
	2%	WB	27.7	28.5	29.4	30.5	31.1	31.4	31.0	30.8	30.6	29.7	29.3	28.2
		MCDB	28.4	29.0	29.9	31.2	32.0	32.2	31.7	31.6	31.2	30.4	29.9	28.9
	5%	WB	27.0	27.6	28.5	29.8	30.4	30.5	30.1	29.8	29.6	28.7	28.5	27.6
		MCDB	27.9	28.3	29.4	30.6	31.6	31.8	31.1	31.0	30.7	29.9	29.5	28.6
	10%	WB	26.4	26.8	27.7	29.0	29.7	29.6	29.1	29.0	28.7	28.1	27.9	27.0
		MCDB	27.4	27.8	28.8	30.2	31.1	31.3	30.7	30.8	30.3	29.6	29.2	28.2
Mean Daily Temperature Range	5% DB	MDBR	3.3	4.0	4.4	5.1	6.2	6.3	5.7	5.7	5.8	4.8	3.9	3.3
		MCDBR	4.0	4.6	5.3	5.8	7.1	7.3	6.7	6.7	6.7	5.9	4.8	4.1
		MCWBR	3.1	3.6	4.0	4.5	5.2	5.2	4.9	4.7	4.8	4.2	3.6	3.0
	5% WB	MCDBR	3.9	4.5	5.0	5.6	6.7	6.8	6.4	6.2	6.2	5.5	4.7	3.9
		MCWBR	3.4	4.2	4.5	5.3	5.9	6.1	5.7	5.4	5.6	4.6	4.0	3.3
Clear-Sky Solar Irradiance	taub	0.449	0.431	0.446	0.435	0.438	0.437	0.436	0.445	0.445	0.458	0.458	0.477	
	taud	2.339	2.395	2.357	2.398	2.418	2.431	2.435	2.397	2.391	2.348	2.331	2.239	
	Ebn at Noon	847	881	874	876	860	851	854	856	862	845	831	807	
	Edh at Noon	123	121	128	123	119	116	116	122	122	125	123	134	
All-Sky Solar Radiation	RadAvg	3.90	4.81	5.44	6.28	6.01	5.59	5.00	5.10	5.05	4.45	4.12	3.56	
	RadStd	0.39	0.55	0.55	0.39	0.50	0.37	0.42	0.27	0.39	0.33	0.45	0.40	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.34	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page