

LEGAZPI, Philippines

WMO: 984440

Lat: 13.1508N

Lon: 123.7283E

Elev: 15

StdP: 101.14

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.7	23.3	19.8	14.6	24.3	20.6	15.2	24.6	8.4	26.0	7.9	25.8	2.4	40	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.1	33.5	27.9	33.0	27.8	32.5	27.7	28.7	32.2	28.3	31.9	28.1	31.7	2.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.7	23.7	31.3	27.2	23.1	31.0	27.0	22.8	30.9	93.0	32.4	91.3	32.2	90.0	31.9	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.5	6.3	5.4	20.7	35.2	1.7	1.4	19.5	36.2	18.5	37.0	17.6	37.7	16.3	38.7		
			19.4	29.7	1.6	0.8	18.3	30.2	17.3	30.7	16.5	31.1	15.3	31.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	26.2	26.6	27.3	28.4	29.1	28.9	28.3	28.4	28.2	27.9	27.6	26.9
	DBStd	1.35	1.07	1.02	1.01	0.93	1.00	1.09	1.07	1.06	1.01	0.96	0.99	1.09
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6502	503	465	535	551	592	568	567	570	546	555	528	524
	CDD18.3	3461	244	232	277	301	333	318	308	312	296	297	278	266
	CDH23.3	36802	1936	1989	2730	3477	4127	3859	3472	3518	3223	3168	2859	2443
CDH26.7	11975	336	439	751	1272	1751	1589	1214	1244	1080	1012	779	507	
Wind	WSAvg	2.4	3.0	2.8	2.6	2.3	2.0	1.9	2.1	2.3	2.1	2.0	2.4	2.9
Precipitation	PrecAvg	3286	304	209	174	160	195	217	278	244	277	324	448	478
	PrecMax	4235	869	1082	497	591	603	519	723	479	681	694	863	1208
	PrecMin	2090	22	11	23	28	19	51	67	65	35	61	128	125
	PrecStd	568	190	188	112	127	123	106	123	91	122	145	165	272
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.7	31.1	31.8	33.1	34.1	34.4	33.6	33.5	33.3	32.9	32.1	31.4
		MCWB	26.6	26.5	26.9	27.6	28.0	28.2	28.1	27.8	27.7	27.8	27.5	27.1
	2%	DB	30.0	30.4	31.2	32.3	33.3	33.5	32.7	32.6	32.5	32.1	31.4	30.6
		MCWB	26.1	26.1	26.7	27.4	27.9	28.0	27.7	27.5	27.6	27.5	27.2	26.8
	5%	DB	29.3	29.9	30.6	31.8	32.7	32.7	32.0	32.0	31.9	31.5	30.8	30.0
		MCWB	25.7	25.8	26.4	27.3	27.8	27.9	27.5	27.3	27.4	27.3	27.0	26.5
	10%	DB	28.6	29.2	30.0	31.2	32.1	32.1	31.2	31.2	31.1	30.8	30.2	29.2
		MCWB	25.3	25.5	26.2	27.0	27.7	27.7	27.2	27.1	27.2	27.0	26.8	26.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.4	27.5	28.1	28.6	29.1	29.1	28.7	28.7	28.5	28.4	28.2	27.8
		MCDB	30.0	30.2	30.7	31.8	32.8	32.8	32.4	32.2	31.9	31.8	31.0	30.4
	2%	WB	26.6	26.8	27.3	28.0	28.5	28.6	28.1	28.1	28.0	28.0	27.7	27.2
		MCDB	29.2	29.6	30.3	31.6	32.3	32.4	31.9	31.7	31.7	31.4	30.6	29.8
	5%	WB	26.1	26.3	26.9	27.6	28.1	28.2	27.7	27.6	27.6	27.6	27.3	26.8
		MCDB	28.7	29.1	30.0	31.1	31.9	32.0	31.3	31.1	31.1	30.8	30.2	29.4
	10%	WB	25.6	25.8	26.4	27.2	27.8	27.8	27.3	27.2	27.2	27.2	27.0	26.4
		MCDB	27.9	28.5	29.4	30.7	31.5	31.5	30.6	30.5	30.5	30.2	29.8	28.7
Mean Daily Temperature Range	5% DB	MDBR	4.4	5.1	5.4	5.9	6.1	6.1	5.6	5.6	5.8	5.8	5.0	4.3
		MCDBR	5.6	6.0	6.2	6.5	6.9	7.1	6.8	6.7	6.9	6.9	6.1	5.5
		MCWBR	3.0	3.1	3.2	3.1	3.1	3.2	3.1	3.0	3.3	3.4	3.1	2.9
	5% WB	MCDBR	5.2	5.6	5.8	6.2	6.5	6.8	6.5	6.4	6.5	6.4	5.6	5.1
		MCWBR	3.1	3.2	3.4	3.2	3.2	3.4	3.3	3.3	3.4	3.4	3.1	2.9
Clear-Sky Solar Irradiance	taub	0.455	0.437	0.443	0.436	0.440	0.445	0.444	0.475	0.477	0.462	0.454	0.469	
	taud	2.307	2.359	2.346	2.374	2.392	2.390	2.395	2.291	2.275	2.318	2.334	2.263	
	Ebn at Noon	844	877	877	876	858	844	847	831	835	843	839	819	
	Edh at Noon	128	126	130	126	122	120	120	135	138	129	124	131	
All-Sky Solar Radiation	RadAvg	3.85	4.81	5.36	6.09	5.76	5.30	4.77	4.93	4.86	4.46	4.18	3.63	
	RadStd	0.42	0.56	0.58	0.39	0.49	0.34	0.38	0.26	0.44	0.27	0.43	0.36	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only			+0.34	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)			+0.18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page