

SAN JOSE, Philippines

WMO: 985310

Lat: 12.3596N

Lon: 121.0478E

Elev: 4

StdP: 101.27

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	22.2	23.2	17.3	12.4	26.8	18.3	13.2	27.0	11.6	27.0	8.4	27.0	1.5	90	0.384

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	7.8	35.2	26.7	34.4	26.8	33.8	26.8	29.0	32.6	28.7	32.3	28.3	31.9	5.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.0	24.2	31.7	27.7	23.6	31.3	27.4	23.2	31.0	94.6	32.8	93.1	32.4	91.4	32.0	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.4	8.0	6.9	20.4	37.1	1.7	1.1	19.2	37.9	18.1	38.5	17.2	39.1	15.9	39.9		
			18.2	29.7	1.2	0.7	17.3	30.1	16.7	30.5	16.0	30.9	15.1	31.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	28.0	28.3	29.1	29.9	29.6	28.5	27.7	27.7	27.5	28.0	28.6	28.4
	DBStd	1.42	1.37	1.26	1.36	1.34	1.42	1.31	1.16	1.03	0.95	0.99	1.10	1.30
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6732	557	513	591	596	608	556	549	550	526	558	558	569
	CDD18.3	3690	298	280	333	346	349	306	291	292	276	300	308	311
	CDH23.3	41740	3122	3068	3982	4499	4459	3529	3041	3107	2779	3233	3493	3427
	CDH26.7	16067	1102	1200	1751	2222	2097	1346	920	940	763	1092	1358	1276
Wind	WSAvg	2.8	3.2	3.3	3.5	3.2	2.6	2.4	2.4	2.5	2.4	2.3	2.9	3.3
Precipitation	PrecAvg	2372	20	17	16	35	183	331	483	472	429	234	104	76
	PrecMax	3412	144	124	81	187	460	987	1197	1015	936	815	233	376
	PrecMin	1384	1	0	0	0	5	52	39	127	112	42	3	3
	PrecStd	439	28	27	20	47	129	192	206	181	194	149	69	93
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	34.4	35.3	36.2	36.4	34.9	33.3	32.5	32.4	33.6	34.2	33.9
		MCWB	26.0	25.8	26.2	26.3	26.9	27.2	27.8	28.2	27.9	27.6	26.8	26.4
	2%	DB	32.6	33.4	34.3	35.2	35.1	33.5	32.0	31.6	31.5	32.5	33.3	33.0
		MCWB	25.7	25.6	26.0	26.4	27.3	27.8	27.8	28.0	27.8	27.6	26.8	26.5
	5%	DB	31.9	32.6	33.5	34.5	34.0	32.5	31.2	31.0	30.9	31.7	32.6	32.2
		MCWB	25.5	25.4	25.9	26.6	27.7	27.8	27.5	27.7	27.6	27.5	26.8	26.4
	10%	DB	31.1	31.7	32.5	33.6	33.1	31.6	30.4	30.4	30.1	30.9	31.8	31.4
		MCWB	25.4	25.4	26.0	26.9	27.8	27.6	27.2	27.5	27.2	27.3	26.7	26.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.2	28.1	28.9	29.1	29.4	29.1	28.7	29.0	28.8	28.7	28.8	28.9
		MCDB	32.0	32.3	33.3	33.3	33.4	32.5	31.6	31.6	31.3	31.9	32.4	32.4
	2%	WB	27.2	27.4	28.0	28.6	29.0	28.6	28.2	28.4	28.2	28.2	28.1	28.0
		MCDB	31.1	31.6	32.5	33.1	33.1	32.0	31.2	31.0	30.8	31.3	31.9	31.5
	5%	WB	26.6	26.8	27.3	28.1	28.5	28.1	27.7	28.0	27.7	27.8	27.6	27.3
		MCDB	30.6	31.1	31.7	32.7	32.6	31.6	30.6	30.6	30.3	30.9	31.4	30.9
	10%	WB	26.0	26.2	26.7	27.5	28.0	27.7	27.3	27.5	27.2	27.4	27.1	26.7
		MCDB	30.0	30.5	31.1	32.1	32.1	31.0	30.0	29.9	29.7	30.4	30.8	30.4
Mean Daily Temperature Range	5% DB	MDBR	7.0	7.7	7.8	7.8	7.1	5.9	5.1	4.9	5.2	6.1	6.9	6.7
		MCDBR	7.6	8.4	8.6	8.7	8.2	7.3	6.4	6.0	6.4	7.4	7.8	7.4
		MCWBR	3.8	3.8	3.8	3.7	3.8	3.4	3.4	3.4	3.6	4.0	3.8	3.6
	5% WB	MCDBR	7.4	7.7	7.9	8.0	7.6	6.7	6.0	5.8	6.1	6.8	7.4	7.0
		MCWBR	4.7	4.7	4.7	4.5	4.2	3.7	3.5	3.5	3.7	4.0	4.3	4.2
Clear-Sky Solar Irradiance	taub	0.427	0.420	0.436	0.451	0.449	0.442	0.447	0.457	0.448	0.464	0.439	0.441	
	taud	2.438	2.442	2.400	2.360	2.397	2.431	2.416	2.376	2.396	2.336	2.412	2.396	
	Ebn at Noon	875	896	884	862	850	846	844	846	861	844	857	851	
	Edh at Noon	113	116	123	128	121	115	118	124	122	128	115	116	
All-Sky Solar Radiation	RadAvg	4.90	5.71	6.28	6.68	5.86	5.08	4.56	4.64	4.71	4.90	4.92	4.50	
	RadStd	0.35	0.44	0.43	0.33	0.56	0.48	0.55	0.41	0.56	0.37	0.38	0.35	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page