

GUIUAN, Philippines

WMO: 985580

Lat: 11.0278N

Lon: 125.7340E

Elev: 7

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	74.6	75.2	70.5	112.4	77.9	71.8	117.5	77.7	46.5	76.9	41.3	77.5	12.3	40	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	8.7	91.3	83.6	90.1	83.1	89.1	82.7	84.8	89.3	84.0	88.6	83.4	87.9	7.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
83.7	176.2	88.2	82.8	170.9	87.8	82.0	166.7	87.1	49.2	89.5	48.2	89.1	47.4	88.3	89.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.8	26.7	22.5	67.5	95.3	5.0	3.0	63.9	97.4	60.9	99.1	58.1	100.8	54.5	103.0		
(5)			66.7	86.6	4.1	1.4	63.8	87.6	61.4	88.4	59.1	89.2	56.2	90.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.9	79.4	79.8	81.0	82.4	84.0	83.2	82.4	83.4	82.8	82.4	81.3	80.6
	DBStd	2.37	1.65	1.73	1.79	1.68	1.97	2.30	1.99	2.05	2.25	1.89	1.85	1.80
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11646	912	836	962	972	1053	995	1004	1035	984	1006	940	947
	CDD65	6171	447	416	497	522	588	545	539	570	534	541	490	482
	CDH74	65821	3884	3702	4931	5739	7038	6271	5984	6590	5977	5915	5066	4724
	CDH80	18475	430	519	1048	1671	2693	2210	1868	2350	1957	1742	1157	830
Wind	WSAvg	9.7	15.0	13.7	12.0	9.8	7.0	6.0	7.6	8.5	7.7	7.6	9.5	12.6
Precipitation	PrecAvg	136.1	18.5	13.6	11.7	6.8	7.1	8.9	8.2	6.3	7.0	10.7	16.1	21.4
	PrecMax	229.9	41.0	56.4	44.4	18.3	15.2	15.0	19.5	11.9	16.3	21.1	30.4	40.2
	PrecMin	78.6	8.5	2.7	2.5	1.9	1.7	3.7	2.3	1.1	2.4	4.3	6.8	10.7
	PrecStd	37.9	8.7	11.0	8.3	4.1	3.3	3.3	3.3	3.0	2.8	3.9	6.0	7.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.5	86.9	89.1	90.0	93.4	93.2	90.7	91.6	91.6	90.6	88.9	87.0
		MCWB	80.6	81.2	81.9	82.9	84.5	84.8	83.3	83.0	83.5	83.3	82.4	82.3
	2%	DB	84.3	85.1	87.0	88.3	90.9	90.7	89.1	90.0	89.9	89.0	87.1	85.5
		MCWB	79.8	80.0	81.1	82.2	83.9	83.6	82.7	82.6	82.7	82.6	81.7	81.4
	5%	DB	83.3	84.0	85.7	87.2	89.5	89.1	87.9	88.9	88.5	87.7	85.8	84.4
		MCWB	79.2	79.5	80.3	81.6	83.3	83.0	82.2	82.2	82.2	82.1	81.2	80.7
	10%	DB	82.3	83.0	84.6	86.2	88.2	87.7	86.8	87.7	87.1	86.4	84.7	83.5
		MCWB	78.7	78.8	79.7	81.2	82.7	82.4	81.6	81.7	81.6	81.5	80.6	80.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	82.6	83.6	84.5	86.3	85.9	84.8	84.6	84.5	84.5	83.5	83.0
		MCDB	84.6	85.5	86.8	87.9	90.8	90.8	88.7	89.3	89.7	88.7	87.3	85.5
	2%	WB	80.7	81.0	82.2	83.2	84.9	84.4	83.5	83.5	83.4	83.4	82.5	81.9
		MCDB	83.2	84.1	85.9	87.0	89.4	89.4	87.9	88.5	88.6	87.7	86.1	84.6
	5%	WB	79.9	80.1	81.0	82.3	83.8	83.5	82.6	82.7	82.6	82.5	81.7	81.1
		MCDB	82.3	83.1	84.7	86.4	88.5	88.3	87.2	87.7	87.7	86.9	85.1	83.7
	10%	WB	79.1	79.3	80.1	81.5	83.0	82.6	81.8	81.9	81.8	81.7	80.9	80.5
		MCDB	81.5	82.1	83.7	85.5	87.6	87.3	86.1	86.7	86.5	85.8	84.0	83.0
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.0	6.9	7.4	8.7	8.7	8.2	8.7	8.7	8.0	6.7	5.6
		MCDBR	6.5	7.4	8.4	8.9	10.5	10.8	10.0	10.3	10.4	9.7	8.1	6.6
		MCWBR	4.4	4.9	5.8	5.9	6.3	6.3	6.0	5.8	5.9	5.8	5.3	4.5
	5% WB	MCDBR	6.2	7.0	8.0	8.5	9.9	10.1	9.5	9.8	9.9	9.1	7.8	6.3
		MCWBR	4.6	5.2	6.1	6.2	6.7	6.7	6.4	6.1	6.1	6.0	5.6	4.7
Clear-Sky Solar Irradiance	taub	0.472	0.447	0.436	0.424	0.416	0.412	0.415	0.434	0.426	0.439	0.441	0.460	
	taud	2.282	2.371	2.428	2.467	2.509	2.533	2.518	2.445	2.463	2.433	2.423	2.337	
	Ebn at Noon	265	277	281	281	278	276	276	275	279	276	272	266	
	Edh at Noon	42	40	38	36	34	33	34	37	36	37	36	39	
All-Sky Solar Radiation	RadAvg	1208	1491	1730	1880	1831	1643	1559	1623	1579	1531	1365	1229	
	RadStd	182	181	173	131	129	117	124	106	148	119	124	108	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page