

GUIUAN, Philippines

WMO: 985580

Lat: 11.0278N

Lon: 125.7340E

Elev: 2

StdP: 101.30

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.7	24.0	21.4	16.1	25.5	22.1	16.8	25.4	20.8	25.0	18.5	25.3	5.5	40	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	4.8	32.9	28.7	32.3	28.4	31.7	28.2	29.3	31.8	28.9	31.4	28.6	31.1	3.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.7	25.2	31.2	28.2	24.4	31.0	27.8	23.8	30.6	96.5	31.9	94.2	31.7	92.5	31.3	32.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	11.9	10.1	19.7	35.2	2.8	1.6	17.7	36.3	16.1	37.3	14.5	38.2	12.5	39.4		
(5)			19.3	30.3	2.3	0.8	17.7	30.9	16.3	31.3	15.1	31.8	13.4	32.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	26.4	26.6	27.2	28.0	28.9	28.4	28.0	28.6	28.2	28.0	27.4	27.0	(6)
(7)		DBStd	1.32	0.91	0.96	1.00	0.93	1.10	1.28	1.11	1.14	1.25	1.05	1.03	1.00	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6470	507	464	534	540	585	553	558	575	547	559	522	526	(10)
(11)		CDD18.3	3428	248	231	276	290	327	303	299	317	297	301	272	268	(11)
(12)		CDH23.3	36567	2158	2057	2739	3188	3910	3484	3324	3661	3321	3286	2814	2624	(12)
(13)		CDH26.7	10264	239	288	582	928	1496	1228	1038	1306	1087	968	643	461	(13)
(14)	Wind	WSAvg	4.3	6.7	6.1	5.4	4.4	3.1	2.7	3.4	3.8	3.4	4.2	5.6	(14)	
(15)	Precipitation	PrecAvg	3456	471	345	296	172	180	227	209	161	178	272	410	543	(15)
(16)		PrecMax	5839	1041	1433	1127	464	386	381	495	303	415	537	771	1020	(16)
(17)		PrecMin	1996	215	68	63	49	44	94	59	28	61	110	172	271	(17)
(18)		PrecStd	962	222	279	210	104	83	83	84	76	70	98	153	199	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.7	30.5	31.7	32.2	34.1	34.0	32.6	33.1	33.1	32.5	31.6	30.6	(19)
MCWB			27.0	27.3	27.7	28.3	29.2	29.3	28.5	28.3	28.6	28.5	28.0	27.9	(20)	
2%		DB	29.1	29.5	30.6	31.3	32.7	32.6	31.7	32.2	32.2	31.6	30.6	29.7	(21)	
		MCWB	26.6	26.7	27.3	27.9	28.9	28.6	28.2	28.1	28.2	28.1	27.6	27.4	(22)	
5%		DB	28.5	28.9	29.8	30.7	31.9	31.7	31.1	31.6	31.4	31.0	29.9	29.1	(23)	
		MCWB	26.2	26.4	26.9	27.6	28.5	28.4	27.9	27.9	27.9	27.8	27.3	27.1	(24)	
10%		DB	28.0	28.3	29.2	30.1	31.2	31.0	30.4	30.9	30.6	30.2	29.3	28.6	(25)	
		MCWB	25.9	26.0	26.5	27.3	28.2	28.0	27.5	27.6	27.6	27.5	27.0	26.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	28.1	28.7	29.2	30.2	30.0	29.3	29.2	29.2	29.1	28.6	28.3	(27)
MCD B			29.2	29.7	30.4	31.0	32.7	32.7	31.5	31.8	32.0	31.5	30.7	29.7	(28)	
2%		WB	27.0	27.2	27.9	28.4	29.4	29.1	28.6	28.6	28.6	28.5	28.0	27.7	(29)	
		MCD B	28.5	28.9	30.0	30.5	31.9	31.9	31.1	31.4	31.4	31.0	30.1	29.2	(30)	
5%		WB	26.6	26.7	27.2	27.9	28.8	28.6	28.1	28.2	28.1	28.1	27.6	27.3	(31)	
		MCD B	28.0	28.4	29.3	30.2	31.4	31.3	30.7	30.9	30.9	30.5	29.5	28.7	(32)	
10%		WB	26.2	26.3	26.7	27.5	28.3	28.1	27.7	27.7	27.7	27.6	27.2	27.0	(33)	
		MCD B	27.5	27.8	28.7	29.7	30.9	30.7	30.1	30.4	30.3	29.9	28.9	28.4	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	2.9	3.3	3.8	4.1	4.8	4.8	4.6	4.8	4.4	3.7	3.1	(35)	
MCDBR			3.6	4.1	4.6	4.9	5.9	6.0	5.6	5.7	5.8	5.4	4.5	3.7	(36)	
MCWBR			2.4	2.7	3.2	3.3	3.5	3.5	3.3	3.2	3.3	3.2	2.9	2.5	(37)	
5% WB		MCDBR	3.4	3.9	4.4	4.7	5.5	5.6	5.3	5.4	5.5	5.1	4.4	3.5	(38)	
		MCWBR	2.6	2.9	3.4	3.4	3.7	3.7	3.5	3.4	3.4	3.3	3.1	2.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.472	0.447	0.436	0.424	0.416	0.412	0.415	0.434	0.426	0.439	0.441	0.460	(40)	
taud		2.282	2.371	2.428	2.467	2.509	2.533	2.518	2.445	2.463	2.433	2.423	2.337	(41)		
Ebn at Noon		835	873	886	886	877	871	871	866	881	870	859	837	(42)		
Edh at Noon		133	126	120	115	108	104	106	116	115	116	115	124	(43)		
(44)	All-Sky Solar Radiation	RadAvg	3.81	4.70	5.46	5.93	5.77	5.18	4.92	5.12	4.98	4.83	4.30	3.87	(44)	
(45)		RadStd	0.57	0.57	0.55	0.41	0.41	0.37	0.39	0.33	0.47	0.38	0.39	0.34	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page