

CUYO, Philippines

WMO: 986300

Lat: 10.854N

Lon: 121.008E

Elev: 13

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 89-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	76.2	77.0	70.9	113.8	79.4	71.8	117.7	79.9	22.6	79.7	19.0	81.0	3.8	N/A	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	9.7	92.4	82.5	91.4	82.3	90.5	81.9	83.6	90.1	83.0	89.6	82.5	89.2	4.2	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.8	165.5	88.7	81.1	161.8	88.0	80.6	159.2	87.5	47.7	90.3	47.0	90.0	46.4	89.4	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.6	17.0	13.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	83.7	82.5	82.7	84.0	85.4	85.5	83.9	83.1	83.6	83.1	83.5	84.3	83.2
	DBStd	1.91	1.35	1.51	1.69	1.60	1.64	1.79	1.85	1.75	1.80	1.83	1.44	1.70
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12312	1006	916	1055	1061	1100	1018	1025	1041	993	1038	1030	1029
	CDD65	6837	541	496	590	611	635	568	560	576	543	573	580	564
	CDH74	78027	5570	5294	6712	7601	7908	6575	6215	6568	6021	6550	6802	6211
	CDH80	27172	1311	1489	2359	3328	3469	2389	1979	2262	1904	2264	2544	1874
(14) Wind	WSAvg	5.2	8.2	7.2	5.6	3.8	2.7	2.8	4.7	5.7	3.4	3.7	6.1	9.2
(15) Precipitation	PrecAvg	87.4	0.5	0.4	1.1	1.7	7.8	13.0	16.4	15.9	13.0	9.9	4.4	2.6
	PrecMax	106.9	2.2	2.0	10.2	13.1	17.6	25.5	25.9	34.8	18.7	20.5	15.0	7.8
	PrecMin	56.1	0.0	0.0	0.0	0.0	2.0	6.7	6.5	6.9	5.1	2.4	0.2	0.0
	PrecStd	12.3	0.7	0.6	2.2	2.7	4.1	4.7	5.0	6.2	4.1	4.8	3.8	2.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.0	89.8	92.2	93.6	93.8	92.6	91.2	91.3	90.9	90.9	91.5	90.0
		MCWB	80.8	80.5	81.9	82.4	83.0	83.2	82.9	83.0	82.3	82.8	81.8	81.3
	2%	DB	87.4	88.4	90.2	92.0	92.4	91.0	89.8	89.8	89.7	89.7	90.0	88.8
		MCWB	80.4	79.9	81.4	82.1	82.5	82.7	81.9	82.1	81.9	82.2	81.3	80.8
	5%	DB	86.3	87.3	88.9	90.8	91.4	89.7	88.7	88.7	88.5	88.7	89.1	87.5
		MCWB	80.0	79.4	81.0	81.8	82.1	82.1	81.3	81.5	81.3	81.7	81.0	80.5
	10%	DB	85.2	86.2	87.6	89.7	90.2	88.4	87.4	87.5	87.2	87.6	88.1	86.3
		MCWB	79.5	79.1	80.5	81.6	81.8	81.4	80.7	80.9	80.7	81.1	80.8	80.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.4	81.6	82.8	83.6	84.6	84.2	83.5	83.9	83.2	84.1	82.6	82.2
		MCDB	87.3	87.7	89.1	90.6	91.6	91.0	89.9	89.8	89.6	89.5	88.8	88.1
	2%	WB	80.8	80.8	81.9	82.8	83.3	83.2	82.5	82.7	82.2	83.0	81.9	81.5
		MCDB	86.1	86.7	88.3	90.0	90.6	89.8	88.7	88.7	88.5	88.5	88.2	87.1
	5%	WB	80.4	80.2	81.5	82.4	82.6	82.3	81.6	81.8	81.5	82.1	81.6	80.9
		MCDB	85.1	85.8	87.6	89.6	90.0	88.7	87.6	87.6	87.4	87.6	87.7	86.4
	10%	WB	79.9	79.7	80.9	81.8	81.9	81.5	80.8	81.0	80.8	81.4	81.0	80.4
		MCDB	84.3	85.0	86.7	88.5	88.9	87.5	86.6	86.5	86.3	86.6	87.0	85.6
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	8.2	8.8	9.6	9.7	9.1	8.2	8.2	8.2	8.2	8.7	7.6
		MCDBR	8.1	9.2	9.8	10.7	11.2	10.8	10.2	9.6	10.2	9.5	9.5	8.5
	5% WB	MCWBR	3.7	4.1	4.0	4.6	4.4	5.0	5.1	4.6	4.6	4.5	4.1	3.8
		MCWBR	7.4	8.4	9.3	10.0	10.6	10.5	9.7	9.5	9.8	9.0	9.2	8.0
(40) Clear-Sky Solar Irradiance	taub	0.433	0.421	0.431	0.444	0.436	0.427	0.428	0.443	0.434	0.448	0.440	0.441	0.441
		taud	2.460	2.474	2.459	2.420	2.464	2.502	2.497	2.434	2.455	2.415	2.438	2.426
	Ebn at Noon	278	285	283	276	273	272	272	272	278	273	273	273	272
		Edh at Noon	36	36	37	38	36	34	34	37	36	38	36	36
(44) All-Sky Solar Radiation	RadAvg	1654	1890	2078	2153	1851	1586	1467	1532	1532	1615	1660	1547	1547
	RadStd	128	138	147	115	189	131	148	132	159	127	114	116	116

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page