

ILOILO, Philippines

WMO: 986370

Lat: 10.7728N

Lon: 122.5794E

Elev: 19

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	73.0	73.8	68.9	106.3	75.0	69.7	109.3	75.6	18.9	82.6	17.5	83.3	5.7	20	0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.4	94.4	82.3	93.1	81.9	91.8	81.5	83.4	91.7	82.7	91.0	82.3	90.4	8.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.0	161.2	89.0	80.4	158.2	88.8	79.9	155.2	88.3	47.3	92.3	46.6	91.4	46.1	90.8	94.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.5	14.3	12.6	68.5	98.8	4.6	2.6	65.2	100.7	62.5	102.2	59.9	103.7	56.5	105.6		
			66.2	85.7	4.4	3.5	63.0	88.2	60.5	90.3	58.0	92.3	54.9	94.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.4	80.1	81.2	82.4	84.7	84.9	83.4	82.2	82.2	82.0	82.3	82.1	81.0	
	DBStd	2.35	1.84	1.93	2.07	1.94	2.37	2.08	1.85	1.76	1.88	1.68	1.73	1.72	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11815	932	874	1004	1042	1083	1001	997	997	959	1002	964	960	
	CDD65	6340	467	454	539	592	618	551	532	532	509	537	514	495	
	CDH74	68356	4082	4395	5826	7390	7755	6405	5636	5656	5302	5742	5437	4730	
	CDH80	24732	1111	1457	2231	3410	3564	2519	1796	1824	1658	1940	1821	1401	
Wind	WSAvg	5.3	7.3	7.1	6.3	5.7	4.9	3.6	4.2	5.2	4.7	3.6	5.1	6.2	
Precipitation	PrecAvg	79.7	1.6	1.0	1.3	1.9	5.2	11.5	13.6	14.1	9.7	9.7	6.9	3.5	
	PrecMax	120.7	7.3	4.8	6.0	8.9	20.2	25.5	38.5	35.1	20.4	27.8	19.1	12.6	
	PrecMin	46.7	0.0	0.0	0.0	0.0	0.0	3.4	3.2	2.0	1.3	1.0	1.5	0.4	
	PrecStd	17.3	1.7	1.1	1.3	2.0	4.6	5.3	6.8	7.1	4.8	5.9	4.3	2.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.5	91.9	93.1	96.0	96.5	93.8	93.1	91.4	91.8	91.7	91.2	90.2	
		MCWB	79.8	81.2	81.9	82.5	82.7	82.5	81.8	81.8	81.6	82.2	81.5	80.8	
	2%	DB	88.0	90.0	91.6	94.1	94.7	92.0	90.4	89.7	89.9	90.3	89.9	88.8	
		MCWB	79.3	80.3	81.0	82.1	82.3	81.9	81.2	81.0	81.0	81.4	80.8	80.1	
	5%	DB	86.8	88.8	90.4	92.8	93.3	90.8	88.9	88.6	88.6	89.2	89.0	87.6	
		MCWB	78.8	79.8	80.5	81.7	82.1	81.5	80.6	80.5	80.6	80.8	80.3	79.5	
	10%	DB	85.6	87.5	89.2	91.6	91.7	89.4	87.4	87.4	87.4	87.9	87.8	86.3	
		MCWB	78.2	79.1	79.9	81.2	81.7	81.1	79.9	80.0	80.1	80.2	79.8	78.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.2	82.2	82.7	83.7	84.1	83.9	82.8	83.0	82.9	82.8	82.3	81.9
			MCDB	87.9	90.5	91.5	93.2	93.5	91.4	89.4	89.6	89.5	89.9	89.7	88.3
2%		WB	80.0	80.9	81.6	83.0	83.3	82.8	81.9	81.9	81.9	81.9	81.5	80.9	
		MCDB	86.5	88.8	90.4	92.5	92.6	90.2	89.1	88.1	88.3	89.0	88.7	87.5	
5%		WB	79.3	80.1	80.9	82.3	82.6	82.0	81.1	81.2	81.0	81.1	80.8	80.1	
		MCDB	85.7	87.7	89.5	91.9	91.8	89.3	87.9	87.3	87.4	88.1	87.9	86.5	
10%		WB	78.5	79.4	80.1	81.6	81.9	81.3	80.2	80.4	80.3	80.4	80.0	79.2	
		MCDB	84.8	86.6	88.4	90.8	90.7	88.3	86.4	86.4	86.4	87.2	86.8	85.3	
Mean Daily Temperature Range	5% DB	MDBR	10.9	12.1	13.3	14.6	13.4	12.1	10.6	10.7	10.7	11.6	11.6	11.3	
		MCDBR	12.7	14.3	15.1	16.2	15.9	14.0	13.3	12.4	12.9	13.4	13.4	12.8	
		MCWBR	6.7	7.5	7.8	7.7	7.7	7.1	7.0	6.7	7.0	7.2	6.9	6.7	
	5% WB	MCDBR	12.1	13.6	14.5	15.5	14.5	13.4	12.5	11.6	11.9	12.9	12.7	12.0	
		MCWBR	7.0	7.7	8.0	7.9	7.5	7.2	6.9	6.6	6.8	7.1	6.9	6.9	
Clear-Sky Solar Irradiance	taub	0.426	0.419	0.428	0.441	0.442	0.434	0.432	0.446	0.439	0.452	0.437	0.432		
	taud	2.430	2.433	2.416	2.376	2.395	2.431	2.439	2.383	2.397	2.358	2.403	2.409		
	Ebn at Noon	279	285	283	276	271	270	272	272	276	272	274	274		
	Edh at Noon	36	37	39	40	38	36	36	39	39	40	37	36		
All-Sky Solar Radiation	RadAvg	1412	1673	1873	1998	1790	1607	1479	1515	1528	1522	1513	1367		
	RadStd	145	158	168	87	154	115	126	121	147	101	115	99		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)		+0.43	+0.38	N/A	+0.77	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page