

SURIGAO, Philippines

WMO: 986530

Lat: 9.783N

Lon: 125.489E

Elev: 39

StdP: 100.85

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	23.8	21.4	16.1	25.2	22.0	16.7	25.5	7.9	26.8	6.8	26.7	1.9	180	0.347

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	5.9	33.8	27.8	33.3	27.7	32.9	27.6	28.8	32.4	28.4	32.1	28.1	31.9	1.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.9	24.1	31.6	27.3	23.3	31.1	27.0	22.8	30.9	94.2	32.5	91.8	32.2	90.3	32.1	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	5.3	4.6	22.1	35.6	1.5	1.6	21.0	36.7	20.1	37.7	19.3	38.5	18.2	39.7		
(5)			21.2	29.8	1.0	0.9	20.5	30.4	19.9	30.9	19.3	31.4	18.5	32.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.2	26.6	26.9	27.6	28.3	29.2	29.0	28.9	29.3	29.0	28.5	27.8	27.4	(6)
(7)		DBStd	1.47	1.21	1.17	1.15	1.08	1.00	1.24	1.20	1.23	1.15	1.14	1.17	1.12	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6646	513	472	545	548	595	571	585	597	571	574	533	540	(10)
(11)		CDD18.3	3604	255	239	287	298	337	321	327	339	321	316	283	282	(11)
(12)		CDH23.3	40259	2232	2188	2937	3362	4177	3901	3908	4187	3894	3656	2990	2828	(12)
(13)		CDH26.7	14242	422	483	849	1168	1784	1624	1562	1811	1596	1346	882	714	(13)
(14)	Wind	WSAvg	1.7	2.2	2.3	2.2	1.9	1.5	1.4	1.5	1.4	1.5	1.5	1.5	1.8	(14)
(15)	Precipitation	PrecAvg	3631	623	437	367	236	135	150	160	154	166	254	398	499	(15)
(16)		PrecMax	4768	1286	1106	1239	808	501	449	429	502	388	628	881	1279	(16)
(17)		PrecMin	2690	81	19	37	37	23	30	20	9	12	29	36	179	(17)
(18)		PrecStd	591	289	284	208	149	89	85	74	103	91	109	186	199	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.3	31.6	32.3	33.0	34.0	34.2	34.0	34.3	34.2	33.3	32.6	32.0	(19)
(20)			MCWB	26.8	26.9	27.1	27.6	27.9	28.1	27.9	27.8	27.9	27.6	27.5	27.4	(20)
(21)		2%	DB	30.5	30.7	31.6	32.3	33.2	33.4	33.2	33.6	33.4	32.7	31.8	31.2	(21)
(22)			MCWB	26.5	26.6	26.8	27.3	27.7	27.8	27.7	27.6	27.8	27.5	27.3	27.0	(22)
(23)		5%	DB	29.7	30.1	31.0	31.7	32.7	32.8	32.6	33.0	32.8	32.1	31.1	30.5	(23)
(24)			MCWB	26.3	26.3	26.7	27.1	27.6	27.6	27.5	27.5	27.7	27.4	27.1	26.8	(24)
(25)		10%	DB	28.9	29.4	30.3	31.1	32.1	32.0	31.8	32.2	32.1	31.4	30.4	29.8	(25)
(26)			MCWB	26.0	26.0	26.5	26.9	27.5	27.5	27.3	27.3	27.4	27.2	26.9	26.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.6	27.6	28.0	28.4	29.1	29.4	29.1	29.1	29.6	28.6	28.3	28.1	(27)
(28)			MCD B	30.4	30.5	31.2	31.7	32.5	32.8	32.8	32.9	32.2	32.1	31.3	30.9	(28)
(29)		2%	WB	27.0	27.0	27.4	27.9	28.5	28.5	28.2	28.3	28.4	28.1	27.7	27.5	(29)
(30)			MCD B	29.5	30.1	30.6	31.4	32.1	32.3	32.2	32.4	32.3	31.8	30.8	30.3	(30)
(31)		5%	WB	26.6	26.6	27.0	27.5	28.0	28.0	27.7	27.8	27.9	27.6	27.3	27.1	(31)
(32)			MCD B	28.9	29.4	30.2	30.9	31.9	31.9	31.6	31.9	32.1	31.2	30.3	29.8	(32)
(33)		10%	WB	26.2	26.2	26.6	27.1	27.7	27.6	27.4	27.4	27.5	27.3	27.0	26.7	(33)
(34)			MCD B	28.4	28.7	29.6	30.4	31.4	31.3	31.1	31.4	31.4	30.7	29.9	29.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.1	4.6	5.1	5.5	5.9	5.9	5.6	5.9	5.8	5.4	4.7	4.5	(35)
(36)			MCDBR	5.5	5.8	6.3	6.4	6.6	6.9	6.7	6.9	6.8	6.4	6.0	5.7	(36)
(37)			MCWBR	2.8	2.9	3.0	2.9	3.0	3.1	3.1	3.1	3.2	3.1	3.0	2.9	(37)
(38)		5% WB	MCD BR	5.0	5.5	5.8	6.0	6.4	6.5	6.3	6.3	6.5	6.1	5.5	5.3	(38)
(39)			MCWBR	2.9	3.1	3.1	3.1	3.2	3.3	3.3	3.3	3.4	3.2	3.0	2.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.453	0.435	0.425	0.420	0.415	0.410	0.414	0.434	0.429	0.437	0.428	0.440	(40)	
(41)		taud	2.359	2.411	2.457	2.471	2.499	2.531	2.510	2.433	2.443	2.420	2.458	2.409	(41)	
(42)		Ebn at Noon	857	887	897	890	877	872	871	865	880	873	875	860	(42)	
(43)		Edh at Noon	124	121	117	114	109	104	107	117	117	118	112	116	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.65	4.49	5.23	5.76	5.66	5.13	4.96	5.17	5.11	4.83	4.21	3.83	(44)	
(45)		RadStd	0.59	0.54	0.47	0.41	0.37	0.35	0.35	0.32	0.44	0.36	0.38	0.38	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page