

MALAYBALAY, Philippines

WMO: 987510

Lat: 8.1514N

Lon: 125.1339E

Elev: 627

StdP: 94.02

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.6	18.4	16.1	12.4	19.7	17.1	13.2	20.1	4.4	27.0	3.5	27.0	0.2	30	0.178

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	9.3	32.2	25.6	31.5	25.5	30.9	25.3	27.1	30.7	26.6	30.3	26.1	29.8	1.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	23.2	30.2	25.6	22.5	29.7	25.1	21.8	29.2	90.2	30.8	87.8	30.4	85.4	29.9	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
							Mean		Standard Deviation		n=5 years		n=10 years		n=20 years	
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
3.4	2.6	2.3	DB	15.6	33.6	1.1	0.9	14.9	34.3	14.3	34.8	13.7	34.8	13.7	35.4	12.9
			WB	15.0	28.5	1.0	0.5	14.3	28.9	13.7	29.1	13.1	29.4	12.3	29.8	29.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.7	24.0	24.2	24.7	25.4	25.7	25.0	24.4	24.5	24.5	24.8	24.8	24.6
	DBStd	1.19	1.24	1.16	1.09	1.14	1.02	1.10	1.08	0.97	0.99	1.07	1.08	1.17
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5375	434	398	457	462	487	451	447	450	436	458	443	453
	CDD18.3	2333	176	164	199	212	228	201	188	192	186	200	193	195
	CDH23.3	14277	969	1053	1443	1653	1601	1186	950	999	951	1111	1172	1191
Wind	WSAvg	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.6	0.6	0.5	0.5	0.6
	PrecAvg	2632	182	136	126	132	246	304	320	287	300	249	195	154
	PrecMax	3600	409	288	337	566	482	541	522	471	458	518	344	308
	PrecMin	1917	52	26	24	24	90	210	174	135	127	51	67	35
	PrecStd	442	105	74	70	117	87	74	91	92	83	98	77	85
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.1	31.6	32.6	33.2	32.8	31.7	31.0	31.1	31.4	31.9	31.7	31.6
		MCWB	24.9	25.0	24.5	25.7	26.0	26.0	25.8	25.5	25.7	26.0	25.8	25.8
	2%	DB	30.0	30.5	31.5	32.1	31.7	30.5	29.8	29.9	30.0	30.6	30.7	30.5
		MCWB	24.5	24.7	24.7	25.5	26.0	25.6	25.3	25.2	25.4	25.6	25.4	25.2
	5%	DB	29.1	29.7	30.6	31.2	30.8	29.7	28.8	29.0	29.0	29.6	29.8	29.7
		MCWB	24.2	24.3	24.5	25.2	25.7	25.3	24.9	24.8	25.0	25.2	25.1	24.9
	10%	DB	28.1	28.8	29.7	30.2	29.8	28.7	27.8	28.0	28.0	28.5	28.9	28.8
		MCWB	23.9	23.9	24.3	24.9	25.3	25.0	24.5	24.5	24.5	24.8	24.7	24.4
	0.4%	WB	26.6	27.0	27.2	27.6	27.7	27.0	26.7	26.7	26.8	27.1	27.1	27.0
		MCDB	29.8	30.6	31.0	31.7	31.5	30.4	29.9	29.9	30.2	30.5	30.6	30.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	25.5	25.9	26.2	26.7	26.7	26.2	25.7	25.7	25.9	26.2	26.2	26.0
		MCDB	28.9	29.4	30.1	30.9	30.6	29.7	29.0	29.0	29.2	29.7	29.8	29.6
	5%	WB	24.8	25.0	25.3	25.9	26.0	25.6	25.1	25.1	25.2	25.5	25.6	25.2
		MCDB	28.3	28.7	29.4	30.2	30.0	29.0	28.2	28.3	28.4	28.9	29.1	28.8
	10%	WB	24.1	24.2	24.6	25.1	25.4	25.0	24.5	24.5	24.6	24.8	24.9	24.7
		MCDB	27.4	27.8	28.6	29.5	29.2	28.3	27.4	27.5	27.6	28.1	28.3	28.1
Mean Daily Temperature Range	5% DB	MDBR	8.3	9.4	10.4	10.5	9.3	8.0	7.2	7.6	7.7	8.1	8.8	8.7
		MCDBR	10.5	11.3	12.4	12.2	10.8	9.5	9.1	9.5	9.5	10.0	10.5	10.3
		MCWBR	5.9	6.4	6.8	6.5	5.8	5.3	5.2	5.3	5.5	5.7	6.0	5.8
	5% WB	MCDBR	9.5	10.3	11.1	11.2	10.0	9.1	8.4	8.6	8.8	9.3	10.0	9.5
		MCWBR	6.1	6.7	7.2	7.1	6.1	5.5	5.3	5.4	5.6	5.9	6.4	6.0
Clear-Sky Solar Irradiance	taub		0.378	0.376	0.377	0.386	0.394	0.385	0.388	0.408	0.407	0.417	0.383	0.379
	taud		2.521	2.504	2.512	2.479	2.482	2.513	2.499	2.419	2.413	2.385	2.506	2.518
	Ebn at Noon		936	946	943	921	895	892	893	888	901	893	923	927
	Edh at Noon		106	111	111	113	110	105	108	119	121	123	107	105
All-Sky Solar Radiation	RadAvg		4.00	4.66	5.24	5.55	5.28	4.95	4.88	5.06	5.04	4.84	4.43	4.16
	RadStd		0.47	0.48	0.42	0.35	0.34	0.25	0.28	0.33	0.35	0.33	0.39	0.33

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	+0.24	N/A	N/A	N/A	N/A

Nomenclature: See separate page