

GENERAL SANTOS, Philippines

WMO: 988510

Lat: 6.0572N

Lon: 125.1030E

Elev: 133

StdP: 99.74

Time Zone: 8.00 (E08)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.8	23.0	20.3	15.2	24.7	20.8	15.7	24.5	5.9	31.0	5.3	30.9	0.9	270	0.328

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	8.8	35.0	27.3	34.3	27.1	33.8	27.0	28.2	33.2	27.9	32.8	27.6	32.4	3.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.7	31.6	26.5	22.4	31.4	26.2	22.0	31.2	91.4	33.4	90.1	33.0	88.9	32.7	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.0	5.3	4.8	DB	20.2	36.8	2.8	1.0	18.1	37.5	16.5	38.1	14.9	38.6	12.8	39.3
			WB	19.2	28.9	1.9	0.5	17.9	29.2	16.8	29.5	15.8	29.8	14.4	30.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	27.7	28.1	28.6	29.0	28.4	27.7	27.4	27.5	27.7	28.0	28.2	28.3
	DBStd	1.16	1.16	1.16	1.32	1.09	1.14	1.07	0.90	0.93	1.02	0.89	0.93	1.10
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6590	550	506	577	569	572	532	538	544	531	558	546	566
	CDD18.3	3548	292	273	319	319	313	282	280	286	281	300	296	307
	CDH23.3	37466	2942	2887	3571	3727	3446	2873	2748	2863	2858	3131	3151	3269
	CDH26.7	14559	1091	1132	1540	1656	1384	1017	918	991	1046	1222	1267	1295
Wind	WSAvg	1.7	2.0	2.0	2.1	1.9	1.7	1.4	1.4	1.5	1.5	1.6	1.7	1.8
Precipitation	PrecAvg	1057	107	61	63	62	89	112	102	98	91	98	88	81
	PrecMax	1454	263	208	154	156	233	234	198	226	239	184	187	167
	PrecMin	662	14	13	6	8	22	45	27	23	39	19	28	21
	PrecStd	220	62	41	39	38	43	47	42	48	43	47	45	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.4	34.8	35.7	35.9	35.2	34.2	33.3	33.4	34.2	34.5	34.7	34.9
		MCWB	26.8	27.0	26.9	27.9	27.6	27.4	27.2	27.3	27.2	27.1	27.2	27.0
	2%	DB	33.4	33.7	34.6	34.9	34.1	33.0	32.2	32.5	32.9	33.4	33.9	33.8
		MCWB	26.6	26.9	26.9	27.5	27.4	27.2	26.9	27.1	27.2	27.1	27.1	26.8
	5%	DB	32.5	32.9	33.8	34.0	33.1	32.1	31.5	31.7	32.0	32.5	33.0	33.0
		MCWB	26.4	26.6	26.8	27.2	27.2	27.0	26.7	26.9	27.0	27.0	27.0	26.7
	10%	DB	31.6	32.0	32.9	33.0	32.0	31.2	30.7	30.9	31.2	31.7	32.1	32.0
		MCWB	26.2	26.4	26.7	27.0	27.0	26.7	26.5	26.6	26.7	26.8	26.8	26.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	28.1	28.2	28.6	28.2	28.2	27.8	27.9	28.1	28.2	28.2	28.0
		MCDB	32.8	33.2	34.2	34.4	33.2	32.7	31.8	32.2	32.5	32.9	32.9	33.0
	2%	WB	27.2	27.5	27.7	28.0	27.8	27.6	27.3	27.4	27.5	27.7	27.7	27.5
		MCDB	32.0	32.4	33.4	33.5	32.6	32.0	31.3	31.6	31.8	32.2	32.4	32.3
	5%	WB	26.8	27.0	27.2	27.6	27.4	27.2	27.0	27.0	27.1	27.2	27.3	27.1
		MCDB	31.3	31.9	32.7	32.8	32.2	31.4	31.0	31.2	31.3	31.7	32.0	31.8
	10%	WB	26.3	26.6	26.9	27.1	27.1	26.8	26.6	26.6	26.7	26.9	26.9	26.7
		MCDB	30.6	31.2	32.0	32.2	31.7	30.8	30.3	30.6	30.7	31.2	31.5	31.1
Mean Daily Temperature Range	5% DB	MDBR	7.8	8.0	8.7	8.8	7.9	7.3	7.1	7.2	7.7	8.2	8.4	8.1
		MCDBR	9.4	9.5	10.2	10.3	9.4	8.6	8.2	8.4	8.8	9.4	9.7	9.5
		MCWBR	4.5	4.5	4.7	4.8	4.6	4.6	4.6	4.6	4.6	4.8	4.7	4.3
	5% WB	MCDBR	8.5	8.8	9.4	9.4	8.6	8.1	7.8	7.9	8.0	8.7	9.0	8.6
MCWBR		4.5	4.7	4.8	4.7	4.7	4.6	4.6	4.6	4.7	4.9	4.8	4.5	
Clear-Sky Solar Irradiance	taub	0.406	0.405	0.408	0.415	0.402	0.394	0.401	0.421	0.423	0.444	0.407	0.405	
	taud	2.505	2.487	2.487	2.465	2.510	2.546	2.514	2.437	2.416	2.357	2.490	2.500	
	Ebn at Noon	913	920	915	893	886	882	879	876	887	873	905	906	
	Edh at Noon	109	114	114	115	107	101	105	117	121	128	110	108	
All-Sky Solar Radiation	RadAvg	4.60	5.29	5.67	5.82	5.37	4.93	4.91	5.10	5.38	5.29	4.95	4.71	
	RadStd	0.42	0.43	0.48	0.45	0.27	0.24	0.32	0.25	0.29	0.30	0.36	0.38	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	+0.24	+0.27	N/A	+0.41	+0.45	+0.40	N/A	N/A	N/A	N/A

Nomenclature: See separate page