

GULF OF AK BUOY 46001, USA

WMO: 992030

Lat: 56.232N

Lon: 147.949W

Elev: 0

StdP: 14.70

Time Zone: -10.00 (W10)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	24.5	27.3	N/A	N/A	N/A	N/A	N/A	N/A	40.5	33.2	38.6	33.9	23.8	250	0.930

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.1	58.9	N/A	57.7	N/A	56.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	14.9	90

Dehumidification DP/MCDB and HR

	0.4%			1%			2%			0.4%			1%			2%			Extreme Max WB
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	Enth	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	(p)	(q)
38.0	35.0	32.4	DB	21.3	57.3	3.5	1.2	18.8	58.2	16.7	58.9	14.7	59.6	12.2	60.4	60.4
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.4	36.6	36.7	36.1	38.3	42.2	47.0	51.9	54.6	51.7	46.3	41.1	37.9
	DBStd	7.06	4.00	3.24	2.84	1.98	2.24	2.11	2.29	2.02	2.07	3.35	3.72	3.92
	HDD50	2681	416	373	431	351	242	92	7	0	8	119	267	375
	HDD65	7885	881	793	896	801	707	539	407	323	400	581	717	840
	CDD50	271	0	0	0	0	0	3	65	142	58	3	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	17.0	19.7	18.7	17.8	16.1	14.3	13.0	13.0	14.2	16.9	18.8	20.0	21.4
	PrecAvg	45.7	4.7	3.9	2.9	2.4	2.5	2.8	3.5	3.7	4.8	4.8	4.5	5.2
Precipitation	PrecMax	56.3	7.4	6.0	5.0	4.0	5.0	4.6	4.8	5.7	7.6	7.0	7.1	7.6
	PrecMin	34.6	1.7	1.8	1.1	1.2	0.8	1.1	1.6	1.1	3.1	2.4	2.4	2.7
	PrecStd	4.2	1.4	1.1	1.0	0.7	1.1	0.8	0.8	1.1	1.0	1.5	1.4	1.3
	PrecStd	4.2	1.4	1.1	1.0	0.7	1.1	0.8	0.8	1.1	1.0	1.5	1.4	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	43.4	42.6	41.5	43.5	48.3	54.1	58.2	60.3	57.5	53.3	50.2	46.0	46.0
	0.4% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2% DB	42.6	41.7	41.1	42.3	47.0	52.2	57.2	59.4	55.6	52.2	48.3	44.3	44.3
	2% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% DB	41.6	41.1	40.3	41.4	46.2	50.9	56.3	58.8	55.1	51.3	47.1	43.2	43.2
	5% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10% DB	41.0	40.4	39.5	41.1	45.5	50.0	55.3	57.9	54.5	50.4	45.7	42.3	42.3
	10% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	0.4% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	0.4% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	MDBR	3.5	3.4	3.4	2.7	2.4	2.3	2.1	2.1	2.3	3.0	3.7	4.0	4.0
	5% DB	3.1	3.1	3.0	2.6	2.9	3.1	2.7	2.4	2.4	2.7	3.3	3.9	3.9
	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.307	0.333	0.346	0.387	0.391	0.376	0.380	0.378	0.378	0.343	0.322	0.311	0.311
	taud	2.297	2.340	2.354	2.249	2.306	2.429	2.463	2.471	2.375	2.363	2.226	2.149	2.149
	Ebn at Noon	187	230	259	263	269	275	272	265	245	222	173	144	144
	Edh at Noon	16	23	29	37	37	34	32	30	29	23	17	15	15
All-Sky Solar Radiation	RadAvg	145	350	767	1225	1479	1541	1371	1186	870	464	193	100	100
	RadStd	17	30	56	93	145	101	133	112	84	33	18	8	8

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page