

GULF OF AK BUOY 46001, USA

WMO: 992030

Lat: 56.232N

Lon: 147.949W

Elev: 0

StdP: 101.33

Time Zone: -10.00 (W10)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-4.1	-2.6	N/A	N/A	N/A	N/A	N/A	N/A	18.1	0.6	17.3	1.1	10.6	250	0.930

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.2	14.9	N/A	14.3	N/A	13.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	15.6	14.5	-5.9	14.1	2.0	0.7	-7.4	14.5	-8.5	14.9	-9.6	15.3	-11.0	15.8
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.3	2.5	2.6	2.3	3.5	5.7	8.3	11.0	12.5	10.9	7.9	5.1	3.3
	DBStd	3.92	2.22	1.80	1.58	1.10	1.24	1.17	1.27	1.12	1.15	1.86	2.07	2.18
	HDD10.0	1489	231	207	239	195	134	51	4	0	4	66	148	208
	HDD18.3	4381	489	441	498	445	393	299	226	179	222	323	398	467
	CDD10.0	151	0	0	0	0	0	2	36	79	32	2	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.6	8.8	8.4	7.9	7.2	6.4	5.8	5.8	6.3	7.6	8.4	8.9	9.6
Precipitation	PrecAvg	1160	119	99	74	60	64	71	90	94	123	121	114	131
	PrecMax	1429	189	153	127	101	128	117	121	145	194	179	180	194
	PrecMin	880	43	45	29	31	21	28	41	28	78	60	60	68
	PrecStd	107	36	27	25	17	28	20	20	28	26	37	35	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.3	5.9	5.3	6.4	9.0	12.3	14.6	15.7	14.1	11.9	10.1	7.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	5.9	5.4	5.0	5.7	8.3	11.2	14.0	15.2	13.1	11.2	9.1	6.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	5.3	5.1	4.6	5.2	7.9	10.5	13.5	14.9	12.8	10.7	8.4	6.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	5.0	4.7	4.2	5.0	7.5	10.0	12.9	14.4	12.5	10.2	7.6	5.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.9	1.9	1.9	1.5	1.4	1.3	1.2	1.2	1.3	1.7	2.0	2.2
		MCDBR	1.7	1.7	1.7	1.5	1.6	1.7	1.5	1.3	1.4	1.5	1.8	2.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.307	0.333	0.346	0.387	0.391	0.376	0.380	0.378	0.378	0.343	0.322	0.311	
	taud	2.297	2.340	2.354	2.249	2.306	2.429	2.463	2.471	2.375	2.363	2.226	2.149	
	Ebn at Noon	591	726	815	828	848	867	856	834	771	700	545	453	
	Edh at Noon	52	74	92	118	118	106	101	94	90	71	55	47	
All-Sky Solar Radiation	RadAvg	0.46	1.10	2.42	3.86	4.66	4.86	4.32	3.74	2.74	1.46	0.61	0.32	
	RadStd	0.05	0.09	0.18	0.29	0.46	0.32	0.42	0.35	0.26	0.10	0.06	0.03	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page