

MID GULF BUOY 42001, USA

WMO: 992040

Lat: 25.942N

Lon: 89.657W

Elev: 0

StdP: 101.33

Time Zone: -6.00 (W06)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 14.2	(c) 15.4	(d) 5.6	(e) 5.6	(f) 15.5	(g) 6.9	(h) 6.2	(i) 16.4	(j) 15.5	(k) 19.6	(l) 14.8	(m) 19.4	(n) 8.0	(o) 0	(p) 0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 1.9	(c) 30.2	(d) 25.4	(e) 30.1	(f) 25.4	(g) 29.8	(h) 25.4	(i) 26.9	(j) 28.7	(k) 26.6	(l) 28.8	(m) 26.3	(n) 28.9	(o) 2.8	(p) 100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 26.4	(b) 21.9	(c) 28.0	(d) 25.8	(e) 21.1	(f) 28.3	(g) 25.5	(h) 20.6	(i) 28.4	(j) 84.5	(k) 28.7	(l) 82.6	(m) 28.9	(n) 81.3	(o) 28.9	(p) 28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.1	(b) 12.0	(c) 11.0	(e) 13.5	(f) 31.3	(g) 1.3	(h) 0.6	(i) 12.5	(j) 31.7	(k) 11.7	(l) 32.1	(m) 11.0	(n) 32.4	(o) 10.0	(p) 32.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	24.9	20.8	21.1	22.1	23.7	25.7	27.6	28.6	28.7	28.1	26.2	23.7	21.8	(6)
(7)		DBStd	3.39	2.63	2.46	2.25	1.69	1.22	0.95	0.79	0.83	0.98	1.60	1.89	2.56	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	26	11	7	4	0	0	0	0	0	0	0	0	4	(9)
(10)		CDD10.0	5427	333	311	376	412	488	528	576	581	543	502	411	366	(10)
(11)		CDD18.3	2412	86	84	121	162	229	278	317	322	293	244	162	112	(11)
(12)		CDH23.3	21348	137	132	256	709	1863	3163	3969	4154	3579	2268	789	328	(12)
(13)		CDH26.7	5727	0	0	0	6	90	831	1504	1689	1223	367	18	0	(13)
(14)	Wind	WSAvg	6.0	7.1	7.0	6.7	6.6	5.8	5.0	4.1	4.3	5.3	6.7	6.9	6.9	(14)
(15)	Precipitation	PrecAvg	1043	89	62	79	82	53	90	84	105	131	117	71	80	(15)
(16)		PrecMax	1589	204	168	246	219	180	343	297	259	397	315	205	222	(16)
(17)		PrecMin	589	15	5	7	2	2	4	21	16	32	13	2	12	(17)
(18)		PrecStd	250	50	43	59	53	45	73	56	65	81	83	53	54	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	25.7	26.0	27.3	28.2	30.1	30.6	30.8	30.3	30.0	28.3	26.3	(19)
(20)			MCWB	22.3	23.1	22.7	24.5	24.5	25.7	25.3	25.4	25.6	25.9	24.8	23.1	(20)
(21)		2%	DB	25.3	25.2	25.5	26.8	27.9	29.5	30.2	30.3	30.0	29.4	27.1	25.9	(21)
(22)			MCWB	22.4	23.0	22.6	24.0	24.4	25.6	25.3	25.4	25.5	25.6	23.4	22.7	(22)
(23)		5%	DB	24.7	24.8	25.0	26.2	27.5	29.1	29.9	30.1	29.7	28.9	26.6	25.4	(23)
(24)			MCWB	21.9	22.6	22.4	23.5	24.4	25.4	25.2	25.4	25.4	25.2	22.8	22.3	(24)
(25)		10%	DB	24.1	24.2	24.6	25.7	27.2	28.9	29.6	29.9	29.5	28.4	26.1	25.0	(25)
(26)			MCWB	21.4	21.9	22.0	23.0	24.3	25.2	25.1	25.4	25.3	24.7	22.2	21.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.2	24.6	24.5	25.3	27.3	27.8	26.8	27.1	27.1	26.9	25.4	24.3	(27)
(28)			MCDWB	25.3	25.1	24.8	26.8	27.3	28.3	29.3	29.6	29.0	29.1	27.8	25.9	(28)
(29)		2%	WB	23.3	23.9	24.0	24.8	26.4	26.8	26.4	26.8	26.4	26.3	24.4	23.5	(29)
(30)			MCDWB	24.6	24.8	24.5	26.3	26.5	28.3	29.3	29.5	29.1	28.5	26.5	25.4	(30)
(31)		5%	WB	22.7	23.4	23.5	24.4	25.8	26.3	26.1	26.4	26.1	25.7	23.5	23.1	(31)
(32)			MCDWB	24.3	24.5	24.4	25.9	26.6	28.5	29.1	29.4	29.0	28.2	26.0	25.1	(32)
(33)		10%	WB	22.0	22.9	23.0	24.0	25.3	25.9	25.8	26.2	25.8	25.1	22.8	22.6	(33)
(34)			MCDWB	24.0	24.2	24.2	25.5	26.6	28.3	29.0	29.4	28.9	27.8	25.7	24.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	2.4	2.2	1.8	1.6	1.2	1.5	1.7	1.9	1.9	1.8	2.0	2.4	(35)
(36)			MCDBR	2.2	1.8	1.6	1.3	1.3	1.7	1.9	2.0	1.9	2.3	2.3	2.4	(36)
(37)			MCWBR	2.8	2.3	2.1	1.4	1.4	1.4	1.4	1.5	1.6	2.6	2.8	3.0	(37)
(38)		5% WB	MCDWB	2.4	1.4	1.7	1.5	1.3	1.5	1.7	1.9	1.9	2.7	2.6	2.3	(38)
(39)			MCWBR	3.1	1.9	2.2	1.6	1.4	1.7	1.6	1.7	1.8	2.8	3.4	3.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.369	0.379	0.389	0.425	0.438	0.445	0.454	0.440	0.426	0.404	0.382	0.373	(40)	
(41)		taud	2.520	2.497	2.447	2.342	2.338	2.394	2.373	2.432	2.435	2.472	2.491	2.516	(41)	
(42)		Ebn at Noon	884	900	907	878	860	848	839	853	860	863	861	862	(42)	
(43)		Edh at Noon	93	102	113	128	128	121	123	116	113	103	95	91	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.45	4.29	5.42	6.40	7.06	6.77	6.59	6.17	5.30	4.87	3.77	3.26	(44)	
(45)		RadStd	0.31	0.46	0.52	0.52	0.26	0.40	0.27	0.30	0.38	0.33	0.39	0.26	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page