

HOTEL BUOY 44004, USA

WMO: 992070

Lat: 38.484N

Lon: 70.433W

Elev: 0

StdP: 14.70

Time Zone: -5.00 (W05)

Period: 94-09

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	29.1	32.5	N/A	N/A	N/A	N/A	N/A	N/A	42.0	44.8	39.6	44.3	25.0	300	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.5	82.4	N/A	81.8	N/A	80.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	13.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.7	33.8	31.2	DB	28.0	81.4	3.1	2.2	25.7	82.9	23.9	84.2	22.2	85.4	19.9	87.0	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.5	49.9	48.8	50.8	54.9	60.2	68.7	75.1	76.0	72.7	66.5	58.9	54.3	(6)	
	DBStd	11.74	9.82	9.02	8.03	7.40	4.92	4.73	3.17	3.10	4.21	6.43	7.70	8.23	(7)	
	HDD50	423	124	119	86	34	0	0	0	0	0	0	11	49	(8)	
	HDD65	2493	474	457	446	311	163	21	0	0	1	60	213	347	(9)	
	CDD50	4609	122	86	110	181	315	560	777	807	680	511	279	181	(10)	
	CDD65	1204	7	3	5	8	13	131	312	342	231	107	30	15	(11)	
	CDH74	5155	0	0	0	0	0	175	1558	2050	882	393	93	4	(12)	
	CDH80	348	0	0	0	0	0	0	70	141	108	29	0	0	(13)	
(14) Wind	WSAvg	16.0	19.7	19.5	18.4	16.7	14.9	12.8	12.1	12.7	13.7	16.1	17.0	18.9	(14)	
(15) Precipitation	PrecAvg	73.0	7.3	6.7	7.4	5.8	5.3	4.3	5.1	5.4	5.2	5.8	6.6	8.2	(15)	
	PrecMax	93.6	12.0	10.8	11.4	9.5	9.2	7.8	9.7	9.5	11.4	8.7	10.7	12.7	(16)	
	PrecMin	54.2	4.4	3.9	3.5	3.0	2.0	1.3	2.1	1.9	1.1	2.6	1.5	4.5	(17)	
	PrecStd	7.6	1.7	1.5	1.7	1.7	1.7	1.6	1.4	1.9	2.5	1.7	2.1	2.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.0	70.1	71.1	71.3	71.7	79.2	82.9	83.1	83.3	82.4	78.1	74.2	(19)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)	
	2%	DB	70.0	68.1	69.2	69.7	70.0	77.3	81.7	82.3	82.5	80.8	77.0	71.3	(21)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)	
	5%	DB	66.8	65.0	67.2	68.4	68.7	76.2	80.8	81.7	81.7	78.4	73.6	69.9	(23)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)	
	10%	DB	63.9	61.8	63.5	65.7	67.5	74.7	79.9	80.8	78.3	76.1	69.3	66.9	(25)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.6	8.4	8.2	6.5	5.3	3.8	3.5	3.5	4.1	5.1	6.6	7.8	(35)	
		MCDBR	6.5	6.6	6.7	5.4	5.5	3.1	3.7	3.3	2.6	3.7	3.8	5.7	(36)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.354	0.366	0.372	0.408	0.444	0.463	0.477	0.458	0.405	0.385	0.358	0.350	(40)	
	taud		2.412	2.378	2.414	2.317	2.252	2.247	2.235	2.285	2.407	2.449	2.475	2.444	(41)	
	Ebn at Noon		258	271	281	276	267	261	256	259	267	261	255	250	(42)	
	Edh at Noon		28	32	34	40	43	44	44	41	34	30	26	25	(43)	
(44) All-Sky Solar Radiation	RadAvg		477	724	1107	1531	1809	1969	1922	1770	1441	1034	642	433	(44)	
	RadStd		68	83	98	122	172	145	112	146	130	71	83	45	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page