

BILOXI BUOY 42007, MS, USA

WMO: 992120

Lat: 30.090N

Lon: 88.769W

Elev: 0

StdP: 14.70

Time Zone: -6.00 (NAC)

Period: 94-09

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.0	40.0	21.0	15.8	40.4	25.2	19.2	43.6	34.6	46.3	32.6	46.8	20.0	10	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.7	87.7	78.9	86.9	78.4	86.2	77.9	81.4	84.7	80.5	84.3	79.8	84.0	9.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.6	159.1	83.0	79.8	154.6	82.6	78.6	148.3	82.8	45.0	84.6	44.2	84.0	43.3	83.7	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
30.9	26.1	23.7	29.2	89.1	3.6	1.8	26.6	90.4	24.5	91.4	22.4	92.4	19.8	93.7
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.6	54.0	55.9	62.0	68.1	75.8	80.4	82.5	82.8	79.5	72.2	63.8	56.9
	DBStd	11.52	7.03	6.46	5.70	5.06	3.45	2.54	2.04	2.38	3.11	5.52	6.04	7.32
	HDD50	100	44	23	5	0	0	0	0	0	0	0	1	27
	HDD65	1108	342	257	116	29	0	0	0	0	0	12	92	260
	CDD50	7244	168	187	378	544	799	913	1008	1017	886	690	414	240
	CDD65	2777	0	1	24	123	334	463	543	552	436	237	55	9
	CDH74	25962	0	0	0	133	2026	4901	6584	6817	4328	1142	31	0
	CDH80	6906	0	0	0	0	95	1105	2248	2508	895	55	0	0
Wind	WSAvg	12.7	14.1	13.3	13.2	13.3	12.4	11.0	10.4	10.1	12.7	13.9	13.6	14.0
Precipitation	PrecAvg	66.3	5.5	4.4	5.8	5.0	5.3	6.5	7.8	6.6	6.3	3.2	4.1	4.9
	PrecMax	90.4	17.5	10.7	12.2	16.3	12.8	17.3	15.8	14.8	29.1	9.4	13.0	15.4
	PrecMin	43.1	0.4	0.4	0.3	0.4	0.9	0.7	2.9	2.1	1.4	0.0	0.4	0.7
	PrecStd	10.6	3.8	2.6	3.1	3.7	3.0	3.6	3.0	3.0	5.5	2.6	2.9	2.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.5	68.6	72.2	78.4	83.5	86.9	89.2	89.5	86.9	83.2	76.4	72.7
		MCWB	65.2	66.6	69.3	72.6	73.0	78.2	79.1	79.8	78.6	77.3	72.4	70.6
	2%	DB	65.3	66.5	70.8	76.8	82.2	85.9	87.7	88.1	85.6	81.5	75.1	70.0
		MCWB	64.1	64.5	67.8	71.7	74.2	77.4	78.7	79.1	75.8	75.9	70.6	68.1
	5%	DB	64.1	65.1	69.6	75.7	81.0	84.9	86.8	87.1	84.4	80.2	73.5	68.0
		MCWB	62.8	63.1	66.5	70.7	74.7	76.8	78.2	78.6	76.0	74.8	69.7	66.0
	10%	DB	62.9	63.8	68.7	74.4	80.2	84.0	86.0	86.4	83.5	79.2	71.8	66.4
		MCWB	61.3	61.7	65.6	70.0	74.5	76.5	77.7	78.2	76.3	73.8	67.2	64.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.3	67.7	70.5	74.4	80.3	81.9	82.4	83.2	80.4	79.5	74.2	71.6
		MCDB	66.4	68.5	71.5	76.3	80.4	83.0	85.3	87.7	84.6	82.7	76.2	72.9
	2%	WB	64.9	66.0	68.9	73.4	79.5	81.0	81.4	81.3	78.9	77.7	71.5	69.2
		MCDB	65.1	66.7	69.9	75.6	79.7	82.8	84.7	86.8	83.0	80.8	74.3	70.3
	5%	WB	63.7	63.9	67.8	72.6	77.8	80.1	80.5	80.2	78.2	76.5	69.9	67.2
		MCDB	64.2	64.8	69.2	74.9	79.4	82.6	84.3	86.2	82.7	79.6	72.9	68.2
	10%	WB	62.4	62.2	66.6	71.5	75.9	79.0	79.6	79.3	77.6	75.0	68.4	65.2
		MCDB	63.1	63.4	68.1	73.9	78.6	82.4	84.0	85.7	82.4	78.4	71.4	66.3
Mean Daily Temperature Range	5% DB	MDBR	8.1	7.7	6.3	5.2	4.3	4.6	5.0	4.7	5.3	5.9	7.3	8.2
		MCDBR	5.9	6.3	5.2	4.9	4.5	5.0	5.8	5.0	5.8	5.1	5.9	7.1
		MCWBR	6.8	7.5	6.0	5.9	4.3	4.0	4.9	4.3	4.7	4.9	6.6	7.9
	5% WB	MCDBR	5.2	6.5	5.5	4.3	3.5	5.0	5.4	4.5	4.4	4.8	6.1	6.0
MCWBR		6.3	7.7	6.4	5.1	3.7	4.4	4.9	4.6	4.3	5.0	7.0	7.1	
Clear-Sky Solar Irradiance	taub	0.340	0.355	0.376	0.405	0.436	0.460	0.505	0.500	0.450	0.389	0.358	0.347	
	taud	2.547	2.510	2.442	2.360	2.312	2.289	2.188	2.201	2.300	2.466	2.492	2.536	
	Ebn at Noon	284	289	289	282	272	264	252	252	262	273	274	275	
	Edh at Noon	27	31	35	39	42	43	47	46	40	32	29	27	
All-Sky Solar Radiation	RadAvg	970	1157	1560	1890	2095	2012	1879	1764	1661	1450	1110	861	
	RadStd	79	158	127	160	108	148	131	134	107	144	98	74	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+259	+173

Nomenclature: See separate page