

BILOXI BUOY 42007, MS, USA

WMO: 992120

Lat: 30.090N

Lon: 88.769W

Elev: 0

StdP: 101.33

Time Zone: -6.00 (NAC)

Period: 94-09

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.2	4.5	-6.1	2.3	4.7	-3.8	2.7	6.4	15.5	8.0	14.6	8.2	8.9	10	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.6	30.9	26.0	30.5	25.8	30.1	25.5	27.5	29.3	26.9	29.0	26.6	28.9	4.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.7	28.4	26.5	22.1	28.1	25.9	21.2	28.2	86.8	29.2	84.8	28.9	82.7	28.7	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.8	11.7	10.6	-1.5	31.7	2.0	1.0	-3.0	32.4	-4.2	33.0	-5.3	33.6	-6.8	34.3		
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.9	12.2	13.3	16.7	20.1	24.3	26.9	28.1	28.2	26.4	22.4	17.6	13.8
	DBStd	6.40	3.90	3.59	3.17	2.81	1.91	1.41	1.13	1.32	1.73	3.06	3.35	4.06
	HDD10.0	56	24	13	3	0	0	0	0	0	0	0	1	15
	HDD18.3	616	190	143	64	16	0	0	0	0	0	7	51	144
	CDD10.0	4024	93	104	210	302	444	507	560	565	492	383	230	133
	CDD18.3	1543	0	1	13	68	186	257	302	307	242	132	31	5
	CDH23.3	14423	0	0	0	74	1126	2723	3658	3787	2404	634	17	0
	CDH26.7	3837	0	0	0	0	53	614	1249	1393	497	31	0	0
Wind	WSAvg	5.7	6.3	5.9	5.9	5.9	5.6	4.9	4.7	4.5	5.7	6.2	6.1	6.3
Precipitation	PrecAvg	1683	140	112	148	127	134	164	197	167	161	81	105	124
	PrecMax	2296	445	271	311	415	326	439	401	375	739	238	329	391
	PrecMin	1094	9	10	7	10	22	19	74	53	36	1	10	19
	PrecStd	268	96	67	79	93	77	91	77	77	140	66	73	74
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.1	20.3	22.3	25.8	28.6	30.5	31.8	31.9	30.5	28.4	24.7	22.6
		MCWB	18.4	19.2	20.7	22.5	22.8	25.7	26.2	26.5	25.9	25.2	22.4	21.4
	2%	DB	18.5	19.2	21.6	24.9	27.9	30.0	30.9	31.2	29.8	27.5	23.9	21.1
		MCWB	17.9	18.1	19.9	22.1	23.4	25.2	25.9	26.2	24.4	24.4	21.4	20.1
	5%	DB	17.8	18.4	20.9	24.3	27.2	29.4	30.4	30.6	29.1	26.8	23.0	20.0
		MCWB	17.1	17.3	19.2	21.5	23.7	24.9	25.7	25.9	24.5	23.8	20.9	18.9
	10%	DB	17.2	17.7	20.4	23.6	26.8	28.9	30.0	30.2	28.6	26.2	22.1	19.1
		MCWB	16.3	16.5	18.7	21.1	23.6	24.7	25.4	25.6	24.6	23.2	19.6	17.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.1	19.8	21.4	23.6	26.9	27.7	28.0	28.4	26.9	26.4	23.4	22.0
		MCDB	19.1	20.3	21.9	24.6	26.9	28.3	29.6	30.9	29.2	28.2	24.6	22.7
	2%	WB	18.3	18.9	20.5	23.0	26.4	27.2	27.5	27.4	26.0	25.4	22.0	20.7
		MCDB	18.4	19.3	21.1	24.2	26.5	28.2	29.3	30.4	28.3	27.1	23.5	21.3
	5%	WB	17.6	17.7	19.9	22.6	25.4	26.7	26.9	26.8	25.7	24.7	21.1	19.5
		MCDB	17.9	18.2	20.6	23.8	26.3	28.1	29.0	30.1	28.2	26.5	22.7	20.1
	10%	WB	16.9	16.8	19.2	22.0	24.4	26.1	26.5	26.3	25.3	23.9	20.2	18.5
		MCDB	17.3	17.5	20.1	23.3	25.9	28.0	28.9	29.8	28.0	25.8	21.9	19.1
Mean Daily Temperature Range	5% DB	MDBR	4.5	4.3	3.5	2.9	2.4	2.5	2.8	2.6	3.0	3.3	4.0	4.6
		MCDBR	3.3	3.5	2.9	2.7	2.5	2.8	3.2	2.8	3.2	2.8	3.3	4.0
		MCWBR	3.8	4.2	3.3	3.3	2.4	2.2	2.7	2.4	2.6	2.7	3.7	4.4
	5% WB	MCDBR	2.9	3.6	3.1	2.4	1.9	2.8	3.0	2.5	2.4	2.7	3.4	3.3
		MCWBR	3.5	4.3	3.6	2.8	2.1	2.4	2.7	2.6	2.4	2.8	3.9	3.9
Clear-Sky Solar Irradiance	taub	0.340	0.355	0.376	0.405	0.436	0.460	0.505	0.500	0.450	0.389	0.358	0.347	
	taud	2.547	2.510	2.442	2.360	2.312	2.289	2.188	2.201	2.300	2.466	2.492	2.536	
	Ebn at Noon	896	910	910	890	859	833	795	796	826	861	864	867	
	Edh at Noon	86	97	111	124	131	134	147	144	126	100	90	84	
All-Sky Solar Radiation	RadAvg	3.06	3.65	4.92	5.96	6.60	6.34	5.92	5.56	5.24	4.57	3.50	2.71	
	RadStd	0.25	0.50	0.40	0.50	0.34	0.47	0.41	0.42	0.34	0.45	0.31	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+144	+96

Nomenclature: See separate page