

OREGON BUOY 46002, USA

WMO: 992160

Lat: 42.612N

Lon: 130.537W

Elev: 0

StdP: 101.33

Time Zone: -9.00 (W09)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.4	7.0	N/A	N/A	N/A	N/A	N/A	N/A	16.4	9.9	15.3	9.7	8.7	320	0.744

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	1.3	19.6	N/A	19.1	N/A	18.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.0	0

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.6	14.2	13.1	4.9	19.7	1.5	0.8	3.8	20.3	3.0	20.8	2.1	21.2	1.0	21.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	10.7	9.8	9.5	10.0	11.4	13.3	15.6	17.3	17.3	15.6	13.5	11.5
	DBStd	3.09	1.57	1.51	1.49	1.23	1.31	1.23	1.24	1.05	0.94	1.42	1.60	1.58
	HDD10.0	80	11	19	27	14	3	0	0	0	0	0	1	5
	HDD18.3	1958	236	238	274	249	216	152	84	36	32	85	145	213
	CDD10.0	1168	34	14	12	16	46	98	174	226	221	173	106	50
	CDD18.3	5	0	0	0	0	0	0	0	3	2	1	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.2	8.1	8.0	7.1	7.1	6.2	6.5	6.2	6.1	6.8	7.1	8.1	8.7
Precipitation	PrecAvg	975	167	117	94	51	46	36	20	22	35	78	148	161
	PrecMax	1230	306	220	139	108	121	79	68	73	125	205	243	269
	PrecMin	770	85	35	41	16	8	6	0	0	1	4	77	44
	PrecStd	111	55	49	25	24	28	22	21	22	27	53	40	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.1	14.0	13.6	13.4	15.0	17.2	19.1	20.2	20.0	19.2	17.3	15.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	13.6	13.2	13.0	12.8	14.3	16.3	18.3	19.7	19.4	18.6	16.8	15.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	13.2	12.6	12.2	12.3	13.7	15.6	17.8	19.3	19.0	18.0	16.4	14.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	12.9	11.9	11.6	11.8	13.3	15.0	17.4	19.0	18.7	17.6	15.8	13.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.8	1.7	1.8	1.6	1.4	1.3	1.3	1.3	1.3	1.6	2.0	2.2
		MCDBR	1.9	1.8	1.7	1.7	1.6	1.4	1.4	1.6	1.5	1.7	2.2	2.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.346	0.352	0.373	0.411	0.403	0.383	0.367	0.373	0.375	0.368	0.350	0.352	
	taud	2.449	2.450	2.403	2.264	2.340	2.459	2.535	2.530	2.488	2.466	2.467	2.390	
	Ebn at Noon	786	846	869	857	872	889	901	886	858	816	774	735	
	Edh at Noon	77	89	105	130	123	110	101	98	96	87	75	75	
All-Sky Solar Radiation	RadAvg	1.47	2.33	3.48	4.65	5.35	5.65	5.39	5.03	4.30	2.88	1.73	1.25	
	RadStd	0.13	0.13	0.25	0.35	0.41	0.44	0.44	0.34	0.22	0.19	0.10	0.12	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page