

MIDDLE NOMAD BUOY 46004, Canada

WMO: 992190

Lat: 50.930N

Lon: 136.100W

Elev: 10

StdP: 14.69

Time Zone: -9.00 (W09)

Period: 02-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	35.3	36.8	N/A	N/A	N/A	N/A	N/A	N/A	42.6	42.3	39.5	42.2	20.8	290	0.897

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.2	62.1	N/A	61.3	N/A	60.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	14.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.1	34.6	31.6	DB	33.5	61.4	2.2	2.3	32.0	63.0	30.7	64.4	29.5	65.7	27.9	67.3	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.5	43.3	43.1	42.2	43.5	46.5	50.2	54.5	57.7	56.9	52.6	46.9	44.3	(6)	
	DBStd	6.10	3.07	2.91	3.08	2.25	2.57	2.58	2.62	2.22	2.29	2.85	3.28	3.01	(7)	
	HDD50	1262	207	193	241	196	113	27	0	0	0	8	100	177	(8)	
	HDD65	6019	672	613	706	646	574	444	325	226	244	385	542	642	(9)	
	CDD50	719	0	0	0	0	4	34	140	239	206	88	8	0	(10)	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	WSAvg	17.7	20.3	19.9	18.6	17.8	14.6	14.0	13.6	14.3	16.9	19.6	21.7	21.4	(14)	
	PrecAvg	52.0	6.3	4.6	3.9	3.2	2.5	2.6	2.3	3.3	4.2	6.3	6.2	6.6	(15)	
(16) Precipitation	PrecMax	62.1	10.5	9.8	6.5	4.8	4.6	3.8	3.9	6.0	6.3	8.9	10.1	8.9	(16)	
	PrecMin	43.1	3.0	1.6	2.4	1.4	0.9	1.8	0.6	1.3	1.2	3.4	2.8	3.7	(17)	
	PrecStd	4.9	1.7	1.7	1.1	0.8	0.7	0.6	0.8	1.1	1.3	1.3	1.5	1.5	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.9	50.1	50.3	49.5	53.8	58.7	60.8	62.8	63.9	61.0	54.7	51.1	(19)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)	
	2%	DB	49.4	49.0	49.4	48.4	52.2	56.6	59.8	62.1	62.5	59.5	53.3	50.2	(21)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)	
	5%	DB	48.2	47.8	48.1	47.6	51.2	54.9	59.0	61.6	61.4	57.9	52.3	49.4	(23)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)	
	10%	DB	47.1	46.7	46.8	46.8	50.2	53.8	58.2	60.9	60.2	56.5	51.5	48.5	(25)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
(36) Mean Daily Temperature Range	5% DB	MDBR	3.5	3.0	3.6	2.7	2.2	2.1	2.1	2.2	2.6	3.2	3.9	3.6	(35)	
		MCDBR	3.0	3.1	3.7	3.0	2.5	2.6	2.4	2.4	3.1	3.5	4.2	3.8	(36)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.340	0.339	0.371	0.412	0.404	0.384	0.378	0.392	0.391	0.371	0.344	0.323	(40)	
	taud		2.314	2.421	2.315	2.197	2.285	2.418	2.490	2.445	2.384	2.338	2.300	2.334	(41)	
	Ebn at Noon		210	251	261	262	270	277	277	266	252	232	205	198	(42)	
	Edh at Noon		22	25	33	42	40	35	32	32	31	27	22	18	(43)	
(44) All-Sky Solar Radiation	RadAvg		233	474	853	1265	1489	1515	1368	1221	994	586	297	194	(44)	
	RadStd		24	44	74	86	125	109	110	77	79	47	26	16	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page