

MIDDLE NOMAD BUOY 46004, Canada

WMO: 992190

Lat: 50.930N

Lon: 136.100W

Elev: 3

StdP: 101.29

Time Zone: -9.00 (W09)

Period: 02-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	1.8	2.7	N/A	N/A	N/A	N/A	N/A	N/A	19.0	5.7	17.7	5.6	9.3	290	0.897

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.2	16.7	N/A	16.3	N/A	15.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.0	15.5	14.1	DB	0.8	16.3	1.2	1.3	0.0	17.2	-0.7	18.0	-1.4	18.7	-2.3	19.6	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.2	6.3	6.2	5.7	6.4	8.0	10.1	12.5	14.3	13.8	11.4	8.3	6.8
	DBStd	3.39	1.70	1.62	1.71	1.25	1.43	1.43	1.46	1.23	1.27	1.59	1.82	1.67
	HDD10.0	701	115	107	134	109	63	15	0	0	0	4	56	98
	HDD18.3	3344	373	341	392	359	319	247	181	126	136	214	301	357
	CDD10.0	399	0	0	0	0	2	19	78	133	114	49	4	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.9	9.1	8.9	8.3	7.9	6.5	6.3	6.1	6.4	7.6	8.8	9.7	9.6
Precipitation	PrecAvg	1321	159	117	100	81	63	66	59	85	106	159	158	167
	PrecMax	1578	267	248	166	121	116	97	100	153	161	226	257	225
	PrecMin	1094	76	40	60	35	24	45	15	33	30	87	71	93
	PrecStd	124	42	44	27	20	18	14	21	27	32	34	39	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	10.1	10.2	9.7	12.1	14.8	16.0	17.1	17.7	16.1	12.6	10.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	9.7	9.4	9.6	9.1	11.2	13.6	15.4	16.7	16.9	15.3	11.9	10.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	9.0	8.8	8.9	8.7	10.6	12.7	15.0	16.4	16.3	14.4	11.3	9.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	8.4	8.2	8.2	8.2	10.1	12.1	14.6	16.1	15.6	13.6	10.8	9.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.9	1.7	2.0	1.5	1.2	1.2	1.2	1.2	1.4	1.8	2.2	2.0
		MCDBR	1.7	1.7	2.1	1.6	1.4	1.5	1.3	1.3	1.7	1.9	2.4	2.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.340	0.339	0.371	0.412	0.404	0.384	0.378	0.392	0.391	0.371	0.344	0.323	
	taud	2.314	2.421	2.315	2.197	2.285	2.418	2.490	2.445	2.384	2.338	2.300	2.334	
	Ebn at Noon	663	790	823	825	852	873	873	840	795	730	646	624	
	Edh at Noon	68	79	104	131	125	111	102	101	97	84	68	57	
All-Sky Solar Radiation	RadAvg	0.73	1.50	2.69	3.99	4.70	4.78	4.31	3.85	3.13	1.85	0.94	0.61	
	RadStd	0.07	0.14	0.23	0.27	0.40	0.34	0.35	0.24	0.25	0.15	0.08	0.05	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page