

SOUTHEAST PAPA BUOY 46006, USA

WMO: 992200

Lat: 40.782N

Lon: 137.397W

Elev: 0

StdP: 14.70

Time Zone: -9.00 (W09)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	44.5	45.7	N/A	N/A	N/A	N/A	N/A	N/A	42.6	47.8	39.4	48.7	21.8	330	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	2.7	69.1	N/A	68.3	N/A	67.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	15.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.1	34.0	31.4	DB	41.4	69.7	1.4	1.4	40.4	70.7	39.6	71.6	38.8	72.4	37.7	73.4	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.4	52.8	50.9	50.3	51.0	52.8	56.5	61.1	64.4	64.7	61.5	56.9	53.8
	DBStd	5.69	2.74	2.77	2.69	2.36	2.20	2.42	2.42	2.07	1.96	2.63	3.13	2.98
	HDD50	86	9	22	30	16	3	0	0	0	0	0	0	6
	HDD65	3176	380	394	457	420	377	256	124	38	28	112	242	348
	CDD50	2428	94	48	38	46	91	194	343	446	441	355	209	123
	CDD65	42	0	0	0	0	0	0	2	19	18	3	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.6	20.6	19.0	19.2	18.3	15.0	13.3	12.4	12.5	13.4	16.1	19.2	20.9
Precipitation	PrecAvg	41.4	7.2	5.1	4.5	2.3	1.9	1.6	0.7	1.1	1.3	3.3	5.4	6.9
	PrecMax	53.2	12.3	9.2	8.1	5.4	4.9	3.8	2.4	5.2	5.1	8.0	9.5	12.0
	PrecMin	28.7	2.4	0.9	1.1	0.4	0.3	0.2	0.0	0.0	0.0	0.4	3.0	2.4
	PrecStd	6.0	2.6	2.0	1.5	1.4	1.2	1.0	0.7	1.1	1.3	2.1	1.6	2.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.2	57.4	57.0	57.4	59.7	62.9	67.4	70.5	70.3	68.6	64.5	61.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	58.3	56.4	55.8	56.4	58.3	61.9	66.4	69.3	69.0	67.2	63.8	60.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	57.3	55.7	55.1	55.4	57.0	61.0	65.4	68.5	68.3	66.1	62.7	59.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	56.6	55.0	54.4	54.7	56.1	59.9	64.4	67.6	67.7	65.3	61.8	58.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.5	3.4	3.5	3.1	2.7	2.7	2.6	2.6	2.7	3.3	4.0	4.1
		MCDBR	3.9	3.8	4.0	3.5	3.1	3.0	2.9	3.1	3.2	4.0	4.9	4.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.354	0.366	0.391	0.436	0.418	0.385	0.377	0.374	0.375	0.365	0.361	0.363	
	taud	2.448	2.400	2.345	2.185	2.310	2.466	2.529	2.547	2.517	2.508	2.440	2.370	
	Ebn at Noon	252	266	272	266	273	282	284	282	275	264	247	235	
	Edh at Noon	25	30	36	45	41	35	32	31	30	27	25	25	
All-Sky Solar Radiation	RadAvg	496	759	1069	1416	1604	1698	1709	1629	1375	957	584	428	
	RadStd	41	53	61	108	105	121	100	98	72	58	30	30	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page