

WASHINGTON BUOY 46005, USA

WMO: 992210

Lat: 46.134N

Lon: 131.079W

Elev: 0

StdP: 14.70

Time Zone: -9.00 (W09)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	39.6	41.1	N/A	N/A	N/A	N/A	N/A	N/A	39.2	45.6	35.9	45.1	21.2	340	0.802

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.5	65.7	N/A	64.7	N/A	63.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	14.0	0

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		Extreme Max WB	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
36.6	33.5	30.9	DB	37.3	66.3	3.1	3.0	35.1	68.5	33.3	70.2	31.5	71.9	29.3	74.1	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.5	48.2	46.8	46.0	47.3	49.6	53.3	57.4	60.8	60.6	57.2	52.8	49.3
	DBStd	5.82	3.25	2.88	3.03	2.16	2.41	2.42	2.61	2.29	1.96	2.88	3.19	3.04
	HDD50	478	72	95	129	84	38	2	0	0	0	0	10	48
	HDD65	4574	522	508	589	531	478	351	234	133	133	242	367	486
	CDD50	1380	16	6	5	4	24	101	231	333	317	223	93	27
	CDD65	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.7	19.1	17.8	17.7	16.1	14.1	14.1	13.6	13.4	14.8	17.8	20.1	21.3
Precipitation	PrecAvg	45.9	6.7	4.7	4.2	3.2	2.3	2.1	1.3	1.1	2.3	5.0	6.4	6.6
	PrecMax	52.1	12.5	8.6	6.5	7.1	4.3	5.1	3.4	3.5	5.5	9.4	10.3	10.9
	PrecMin	39.5	4.1	1.3	2.0	1.5	0.5	0.9	0.2	0.1	0.5	1.4	2.8	2.7
	PrecStd	3.1	1.8	1.7	1.3	1.2	0.9	0.9	0.7	0.9	1.1	2.0	1.7	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.4	55.2	55.1	54.3	55.7	62.2	64.3	67.2	66.2	65.3	61.3	57.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	54.5	53.4	53.5	52.8	54.8	60.0	63.0	66.2	65.1	64.0	59.9	56.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	53.4	52.3	51.5	51.3	53.9	58.0	62.0	65.3	64.3	62.5	58.7	55.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	52.6	50.7	50.2	50.3	53.0	56.7	61.0	64.3	63.7	61.6	57.3	53.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	3.4	3.1	3.3	2.7	2.4	2.4	2.3	2.5	2.5	3.2	3.8	3.8
		MCDBR	3.3	2.6	3.2	3.2	2.4	2.6	2.5	2.8	2.8	3.4	4.3	4.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.341	0.348	0.375	0.411	0.414	0.384	0.368	0.381	0.382	0.368	0.352	0.342	
	taud	2.427	2.438	2.365	2.237	2.277	2.436	2.526	2.493	2.454	2.424	2.388	2.362	
	Ebn at Noon	238	262	269	268	271	280	283	275	265	249	229	220	
	Edh at Noon	23	27	33	41	41	35	32	32	30	27	23	22	
All-Sky Solar Radiation	RadAvg	352	624	989	1424	1632	1723	1591	1504	1212	774	427	307	
	RadStd	32	50	71	92	101	140	126	103	64	52	28	31	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page