

GEORGES BANK BUOY 44011, USA

WMO: 992360

Lat: 41.070N

Lon: 66.588W

Elev: 0

StdP: 14.70

Time Zone: -4.00 (W04)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.7	27.3	14.2	11.3	25.6	16.5	12.7	27.7	42.3	39.3	39.4	34.5	25.7	280	0.676

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.9	75.0	73.1	73.0	71.8	71.4	70.2	74.0	74.6	72.2	72.6	70.6	71.1	13.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.8	125.8	74.4	72.0	118.4	72.4	70.4	112.0	70.9	37.5	74.3	35.7	72.4	34.4	71.3	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.5	33.5	30.6	DB	22.2	75.4	1.9	2.3	20.9	77.1	19.8	78.5	18.7	79.8	17.4	81.5	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.3	40.0	38.3	39.2	43.2	49.3	55.9	63.8	66.4	63.9	57.3	51.1	45.7	(6)	
	DBStd	10.95	6.80	5.88	4.75	3.60	3.77	4.28	3.58	3.47	4.43	5.13	6.25	6.43	(7)	
	HDD50	1473	315	330	335	205	58	3	0	0	0	3	58	166	(8)	
	HDD65	5161	774	748	800	654	487	275	65	25	72	245	417	599	(9)	
	CDD50	1930	7	1	0	1	36	179	427	508	417	230	92	32	(10)	
	CDD65	144	0	0	0	0	0	1	27	68	39	7	2	0	(11)	
	CDH74	86	0	0	0	0	0	0	3	23	57	3	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	Wind	WSAvg	14.6	19.4	19.4	17.2	14.8	11.9	10.8	9.2	10.0	12.5	15.3	16.7	18.7	(14)
	Precipitation	PrecAvg	66.5	6.8	5.8	5.6	5.3	4.5	4.3	5.0	4.8	4.7	5.9	6.3	7.6	(15)
(16)		PrecMax	78.9	13.2	8.8	9.5	11.0	8.4	10.0	10.7	11.8	8.1	12.3	11.3	11.7	(16)
(17)		PrecMin	50.6	3.3	2.4	2.5	1.3	1.5	0.5	1.5	0.9	2.5	2.0	4.9	(17)	
(18)		PrecStd	7.2	2.0	1.7	1.7	1.9	1.7	2.4	2.2	2.1	2.3	1.8	1.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.8	57.8	53.6	54.7	65.4	69.2	74.3	76.4	77.8	73.9	70.9	66.7	(19)	
		MCWB	61.4	55.7	53.5	54.3	64.3	68.1	72.2	75.7	75.9	73.9	64.3	65.4	(20)	
	2%	DB	55.0	53.3	50.2	52.1	59.7	66.4	71.9	74.3	76.0	70.2	66.8	63.7	(21)	
		MCWB	53.7	52.0	49.5	51.3	58.1	65.4	71.4	73.8	73.3	67.9	63.6	62.7	(22)	
	5%	DB	52.2	49.5	48.3	50.2	57.3	64.4	70.2	72.9	73.3	66.6	61.8	57.3	(23)	
		MCWB	51.0	48.5	47.5	49.3	56.1	63.5	69.7	72.3	70.0	65.0	60.7	56.7	(24)	
	10%	DB	50.0	46.2	46.4	48.5	55.2	62.3	68.9	71.6	70.7	64.3	59.2	54.7	(25)	
		MCWB	48.6	44.9	45.3	47.7	54.6	61.7	68.3	70.6	67.5	62.4	57.9	53.5	(26)	
	0.4%	WB	55.2	53.1	53.1	51.9	62.3	69.5	72.4	75.6	77.1	68.3	63.3	60.1	(27)	
		MCDB	55.9	54.0	53.2	52.1	62.7	69.8	72.4	75.9	77.4	68.5	63.8	60.2	(28)	
(29) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	52.9	49.8	49.0	50.1	58.8	66.4	71.0	74.0	75.0	65.9	61.3	58.1	(29)	
		MCDB	53.7	50.6	49.2	50.4	59.1	66.8	71.1	74.1	76.4	66.4	61.6	58.3	(30)	
	5%	WB	51.0	46.8	46.8	48.6	56.0	64.4	69.6	72.7	71.3	64.0	59.5	56.2	(31)	
		MCDB	51.8	47.7	47.5	49.1	56.5	64.8	69.8	72.8	73.7	64.9	59.9	56.6	(32)	
	10%	WB	48.8	43.9	44.2	47.2	54.1	62.5	68.4	71.3	68.3	62.4	57.9	53.9	(33)	
		MCDB	50.0	45.0	45.0	47.8	54.5	62.9	68.7	71.5	69.5	63.6	58.7	54.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	7.8	6.5	4.9	5.4	5.3	5.1	4.9	5.0	5.1	6.0	7.5	(35)	
		MCDBR	11.3	12.5	10.1	7.6	8.8	7.5	6.4	6.0	7.2	7.2	7.8	9.9	(36)	
		MCWBR	13.1	13.2	11.3	8.5	9.8	7.9	6.2	5.7	6.4	9.2	10.8	12.3	(37)	
	5% WB	MCDBR	11.3	11.1	9.9	7.7	8.9	8.1	6.3	5.9	6.7	6.9	7.6	10.1	(38)	
		MCWBR	13.3	12.6	10.8	8.4	9.2	8.1	6.1	5.7	7.0	8.2	9.0	12.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.350	0.349	0.363	0.392	0.417	0.448	0.476	0.434	0.382	0.373	0.352	0.341	(40)	
	taud		2.375	2.409	2.406	2.348	2.319	2.275	2.214	2.338	2.446	2.457	2.457	2.423	(41)	
	Ebn at Noon		251	272	281	279	273	264	255	263	271	260	249	245	(42)	
	Edh at Noon		27	30	34	38	40	42	44	38	32	29	25	24	(43)	
	RadAvg		429	686	1109	1513	1736	1917	1845	1744	1457	957	568	389	(44)	
(45) All-Sky Solar Radiation	RadStd		48	86	100	136	183	154	119	102	92	78	76	43	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page