

EAST GULF BUOY 42003, USA

WMO: 992440

Lat: 25.925N

Lon: 85.615W

Elev: 0

StdP: 14.70

Time Zone: -6.00 (W06)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 57.9	(c) 60.1	(d) 42.7	(e) 40.4	(f) 59.3	(g) 44.7	(h) 43.7	(i) 60.8	(j) 35.3	(k) 66.6	(l) 33.3	(m) 66.9	(n) 18.5	(o) 350	(p) 0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 3.5	(c) 86.6	(d) 78.5	(e) 86.3	(f) 78.5	(g) 85.8	(h) 78.5	(i) 83.2	(j) 84.5	(k) 81.6	(l) 83.7	(m) 80.3	(n) 83.9	(o) 6.4	(p) 60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
82.8	171.2	84.2	81.1	161.4	83.3	79.2	151.7	82.9	47.0	84.5	45.2	83.6	43.7	83.8	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.4	26.6	24.5	DB	56.2	88.1	1.8	1.2	54.9	88.9	53.8	89.6	52.8	90.3	51.5	91.2
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.0	69.7	70.1	72.2	75.2	78.5	81.8	83.2	83.7	82.6	79.6	75.1	72.2
	DBStd	5.98	4.90	4.74	4.20	2.97	2.24	1.87	1.60	1.50	1.66	2.45	3.48	4.63
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	42	18	12	6	0	0	0	0	0	0	0	0	6
	CDD50	9863	611	562	687	756	884	954	1030	1046	977	916	753	687
	CDD65	4430	164	154	228	306	419	504	565	581	527	451	303	228
	CDH74	40203	371	382	706	1544	3558	5771	7077	7522	6438	4318	1643	873
	CDH80	10468	1	0	1	11	238	1581	2655	3082	2183	641	58	17
(14) Wind	WSAvg	13.3	15.9	15.0	15.5	14.0	12.6	10.0	8.7	9.4	12.1	14.9	16.0	16.0
(15) Precipitation	PrecAvg	42.3	3.9	3.2	3.6	3.5	2.3	4.1	2.8	3.9	5.6	4.2	2.4	3.0
	PrecMax	65.9	11.5	10.2	10.6	8.0	5.7	13.4	7.7	9.2	17.5	12.4	7.8	8.1
	PrecMin	21.9	0.4	0.6	0.1	0.2	0.2	0.6	0.2	0.3	0.9	0.0	0.2	0.3
	PrecStd	10.7	2.5	2.3	2.6	1.9	1.6	3.4	1.5	2.3	3.9	2.9	1.9	2.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.1	79.3	80.1	81.3	83.3	86.4	87.3	87.5	86.8	85.2	82.4	81.4
		MCWB	75.0	74.9	75.6	76.1	76.8	78.5	78.9	78.3	78.3	76.4	76.7	75.4
	2%	DB	78.5	78.4	79.1	80.3	82.5	85.5	86.4	86.9	86.1	84.3	81.7	80.6
		MCWB	73.5	74.1	74.5	75.4	76.5	78.7	78.7	78.4	78.3	77.1	76.3	74.8
	5%	DB	77.4	77.6	78.3	79.7	82.1	84.9	86.0	86.4	85.4	83.5	80.6	79.1
		MCWB	72.6	73.6	73.6	74.9	76.3	78.5	78.6	78.4	78.2	77.7	74.9	73.6
	10%	DB	76.2	76.6	77.6	78.9	81.5	84.3	85.4	86.0	85.1	82.7	79.8	77.9
		MCWB	71.6	72.3	72.8	74.1	76.1	78.2	78.4	78.5	78.1	76.9	73.6	72.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.3	77.1	77.2	78.2	80.7	83.5	84.4	84.8	81.3	80.9	78.2	77.3
		MCDB	78.9	78.3	78.8	79.4	80.9	83.6	85.5	85.4	84.1	82.3	81.4	79.6
	2%	WB	74.8	75.4	75.7	77.3	79.1	82.4	82.8	83.5	80.3	79.9	77.3	76.1
		MCDB	77.2	77.7	78.5	79.3	80.1	83.3	84.5	85.1	84.0	82.5	81.2	79.7
	5%	WB	73.3	74.2	74.5	76.5	78.1	80.8	81.1	80.8	79.5	78.8	76.3	75.0
		MCDB	75.6	77.2	77.9	78.8	80.3	83.2	84.1	84.8	84.0	82.3	80.7	79.3
	10%	WB	72.2	72.7	73.3	75.3	77.3	79.7	79.7	79.7	79.2	77.8	74.8	73.7
		MCDB	75.0	76.1	77.1	78.1	80.3	83.5	84.5	85.0	83.9	81.9	79.7	78.3
(35) Mean Daily Temperature Range	5% DB	MDBR	4.6	4.6	3.9	3.5	2.7	2.9	3.4	3.5	3.6	2.8	3.4	4.0
		MCDBR	5.0	4.8	4.6	3.8	2.9	3.0	3.5	3.6	3.7	3.3	4.0	4.6
		MCWBR	5.7	6.2	4.6	4.0	3.1	2.6	2.8	2.9	3.1	3.6	4.2	5.0
	5% WB	MCDBR	4.6	5.3	4.4	3.8	2.8	3.1	3.7	4.0	3.4	4.2	5.1	5.1
		MCWBR	6.2	7.0	5.1	5.0	3.7	3.4	3.5	3.9	3.3	3.6	4.7	6.0
(40) Clear-Sky Solar Irradiance	taub	0.368	0.379	0.385	0.408	0.425	0.436	0.453	0.436	0.422	0.406	0.376	0.369	
	taud	2.517	2.496	2.466	2.399	2.376	2.426	2.376	2.446	2.453	2.472	2.517	2.537	
	Ebn at Noon	281	285	289	283	276	271	266	272	274	273	276	275	
	Edh at Noon	30	32	35	38	39	37	39	36	35	33	30	28	
(44) All-Sky Solar Radiation	RadAvg	1090	1375	1715	2043	2191	2070	2049	1938	1668	1508	1221	1036	
(45)	RadStd	123	145	144	100	121	150	108	95	119	104	102	98	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page