

HALF MOON BAY BUOY 46012, USA

WMO: 992480

Lat: 37.356N

Lon: 122.881W

Elev: 0

StdP: 14.70

Time Zone: -8.00 (W08)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	46.1	47.5	N/A	N/A	N/A	N/A	N/A	N/A	35.4	50.4	33.4	50.5	14.3	330	0.654

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	3.1	64.4	N/A	63.4	N/A	62.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.7	320

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
32.6	29.7	24.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.5	52.7	52.4	52.0	52.0	53.0	54.3	56.1	57.7	58.0	57.1	55.1	53.2
	DBStd	3.25	2.47	2.60	2.34	2.00	2.16	1.95	2.37	2.70	2.78	2.56	2.32	2.64
	HDD50	29	6	6	7	5	0	0	0	0	0	0	0	5
	HDD65	3844	382	353	404	390	372	322	276	226	212	246	297	364
	CDD50	1662	89	73	68	66	93	128	189	239	240	219	153	105
	CDD65	2	0	0	0	0	0	0	0	0	2	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.7	12.9	14.4	14.0	14.7	14.2	13.7	10.8	10.4	9.9	11.3	12.3	13.4
Precipitation	PrecAvg	25.1	5.0	4.7	3.3	1.7	0.8	0.3	0.0	0.1	0.1	1.3	2.7	5.2
	PrecMax	42.2	13.2	15.6	9.8	5.8	3.4	1.6	0.1	0.8	0.5	4.3	8.0	13.1
	PrecMin	12.8	0.3	0.0	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.5
	PrecStd	6.9	3.5	3.2	2.8	1.3	0.9	0.4	0.0	0.2	0.1	1.1	1.9	3.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.5	60.1	59.4	58.2	61.5	60.4	63.9	65.2	71.9	65.1	62.3	61.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	58.2	58.8	57.4	56.4	58.9	59.2	62.5	64.1	64.9	63.6	60.8	60.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	57.1	57.3	56.4	55.4	57.3	58.3	61.2	63.2	63.0	62.3	59.6	58.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	56.0	56.0	55.3	54.9	56.2	57.3	59.7	62.1	61.5	61.1	58.5	56.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.2	3.1	3.0	2.8	2.6	2.5	2.8	3.0	3.1	3.2	3.2	3.2
		MCDBR	3.9	4.2	3.8	3.5	3.8	3.3	3.0	3.4	3.7	4.6	4.4	4.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.322	0.333	0.341	0.363	0.368	0.359	0.371	0.342	0.347	0.338	0.321	0.325	
	taud	2.584	2.550	2.529	2.433	2.447	2.475	2.452	2.540	2.498	2.568	2.593	2.582	
	Ebn at Noon	276	287	294	291	290	291	286	294	287	281	275	267	
	Edh at Noon	24	28	31	36	36	35	35	32	31	27	23	23	
All-Sky Solar Radiation	RadAvg	770	1061	1485	1914	2107	2248	1935	1725	1583	1227	896	672	
	RadStd	94	119	117	140	171	130	120	137	111	83	59	89	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)		N/A	N/A	-2.18	N/A	N/A	N/A	N/A	-198	+245	N/A

Nomenclature: See separate page