

PT ARENA BUOY 46014, CA, USA

WMO: 992500

Lat: 39.231N

Lon: 123.974W

Elev: 0

StdP: 14.70

Time Zone: -8.00 (NAP)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	43.9	45.3	N/A	N/A	N/A	N/A	N/A	N/A	36.7	51.1	34.9	51.0	9.6	70	0.708

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	3.5	62.4	N/A	61.1	N/A	59.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
34.0	31.5	29.3	41.5	64.6	2.4	2.3	39.8	66.2	38.4	67.5	37.1	68.8	35.4	70.5		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.8	51.3	50.8	50.5	50.8	52.1	53.0	53.6	55.3	55.8	54.7	53.7	51.6
	DBStd	3.02	2.61	2.60	2.38	2.07	2.30	1.89	1.99	2.54	2.64	2.42	2.70	2.95
	HDD50	97	17	19	21	14	4	1	0	0	0	1	3	17
	HDD65	4459	424	397	448	427	401	359	353	301	276	319	338	416
	CDD50	1115	57	42	38	38	68	92	112	164	174	148	115	67
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	13.5	13.3	14.0	14.9	14.8	15.7	16.0	12.8	12.0	10.5	11.6	12.4	13.9
Precipitation	PrecAvg	45.7	8.5	7.2	5.9	3.6	2.0	0.6	0.1	0.2	0.1	2.3	4.9	10.0
	PrecMax	72.7	25.7	19.6	16.1	11.5	7.9	3.0	0.4	1.1	0.9	8.3	12.1	23.4
	PrecMin	29.3	0.7	1.1	0.7	0.9	0.0	0.0	0.0	0.0	0.0	0.1	0.8	2.0
	PrecStd	13.6	6.2	4.5	4.5	2.8	2.1	0.8	0.1	0.2	0.2	2.0	3.1	6.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.0	58.4	57.3	57.2	62.3	59.4	60.4	64.3	64.2	62.5	61.7	59.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	57.0	56.8	55.9	55.5	58.4	57.7	58.8	62.1	62.5	60.6	59.9	57.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	55.9	55.4	55.0	54.7	56.2	56.9	57.5	60.2	61.1	59.2	58.8	56.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	55.1	54.5	54.0	53.7	55.1	55.9	56.7	59.1	59.6	58.0	57.7	55.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	3.9	3.8	3.4	3.3	2.9	2.8	3.1	3.5	3.5	3.6	3.9	4.1
		MCDBR	4.1	4.3	3.9	4.1	4.3	3.6	3.6	4.6	4.5	4.9	4.3	4.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.327	0.333	0.335	0.362	0.360	0.354	0.357	0.347	0.339	0.336	0.320	0.328	
	taud	2.552	2.537	2.553	2.436	2.483	2.502	2.503	2.530	2.534	2.573	2.596	2.550	
	Ebn at Noon	269	283	294	290	292	292	290	292	288	278	270	259	
	Edh at Noon	23	27	30	35	34	34	33	32	30	26	22	22	
All-Sky Solar Radiation	RadAvg	668	950	1360	1819	2142	2368	2190	1891	1632	1180	783	569	
	RadStd	102	132	124	139	155	126	122	101	99	85	73	94	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	N/A	N/A	-1.85	N/A	N/A	N/A	N/A	N/A	+221	N/A

Nomenclature: See separate page