

PT ARGUELLO BUOY 46023, USA

WMO: 992580

Lat: 34.714N

Lon: 120.967W

Elev: 0

StdP: 14.70

Time Zone: -8.00 (W08)

Period: 94-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 4	(b) 48.1	(c) 49.5	(d) 32.8	(e) 27.3	(f) 51.1	(g) 36.5	(h) 31.7	(i) 51.4	(j) 39.0	(k) 51.5	(l) 37.0	(m) 52.0	(n) 16.0	(o) 340	(p) 0.722

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	3.1	65.8	61.9	64.5	61.2	63.3	60.5	63.1	64.7	62.2	63.8	61.3	62.8	13.5	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.3	83.9	63.9	61.3	81.1	63.0	60.5	78.6	62.0	28.5	64.8	27.9	64.0	27.3	62.8	67.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 34.3	(b) 31.9	(c) 29.8	(e) 45.4	(f) 69.4	(g) 2.9	(h) 4.7	(i) 43.3	(j) 72.8	(k) 41.6	(l) 75.6	(m) 40.0	(n) 78.2	(o) 37.9	(p) 81.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.0	54.4	54.4	54.0	53.0	53.6	55.5	57.1	58.7	59.7	58.9	57.5	55.0
	DBStd	3.13	2.50	2.24	2.29	2.04	1.70	2.09	1.67	2.20	2.31	2.49	2.61	2.41
	HDD50	5	2	0	1	1	0	0	0	0	0	0	0	1
	HDD65	3292	329	296	342	360	354	286	243	196	160	189	227	310
	CDD50	2190	138	124	124	91	111	164	222	269	290	277	224	156
	CDD65	3	0	0	0	0	0	0	0	0	1	1	1	0
	CDH74	1	0	0	0	1	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	15.5	14.6	15.0	17.0	17.2	17.5	16.1	15.0	15.1	13.6	14.4	14.5	15.3
Precipitation	PrecAvg	16.6	3.6	3.7	2.7	1.1	0.4	0.1	0.0	0.0	0.1	0.8	1.3	2.8
	PrecMax	32.6	16.3	15.7	12.6	4.3	2.4	0.7	0.3	0.1	0.4	4.0	4.5	9.3
	PrecMin	6.2	0.2	0.1	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.2
	PrecStd	6.6	3.5	3.3	2.8	1.1	0.6	0.2	0.1	0.0	0.1	0.9	1.1	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.9	63.7	61.4	61.7	59.3	62.2	62.3	65.9	67.0	68.4	68.6	62.2
		MCWB	54.7	51.4	55.5	55.5	56.4	59.3	59.9	62.7	63.2	60.6	62.1	56.4
	2%	DB	59.4	59.9	59.2	57.5	57.8	60.3	61.4	64.5	65.4	65.4	63.9	60.4
		MCWB	55.9	55.6	55.1	54.4	55.5	58.4	59.2	61.8	62.5	60.6	59.6	55.6
	5%	DB	58.5	58.6	58.1	56.5	57.0	59.2	60.4	63.5	64.3	63.9	62.1	59.3
		MCWB	55.1	55.0	54.8	53.7	54.8	57.4	58.7	61.4	61.8	60.0	57.8	55.0
	10%	DB	57.5	57.4	57.2	55.4	56.2	58.5	59.6	62.0	63.0	62.3	61.0	58.3
		MCWB	54.3	53.9	54.4	52.9	54.0	56.7	58.3	60.0	60.8	59.1	57.1	54.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.5	58.2	57.9	57.4	57.8	61.3	61.4	63.7	65.1	62.9	63.5	58.7
		MCDB	59.3	59.1	58.8	59.5	58.3	61.4	61.5	64.8	66.4	64.7	67.1	59.6
	2%	WB	57.2	57.0	56.6	55.9	56.6	59.4	60.2	62.6	63.5	61.9	60.7	57.8
		MCDB	58.6	58.3	57.7	57.2	57.3	59.8	60.6	63.9	64.9	63.6	63.1	58.9
	5%	WB	56.2	56.0	55.5	54.8	55.7	58.4	59.4	61.8	62.4	60.8	59.4	57.0
		MCDB	57.7	57.3	56.9	56.0	56.6	59.1	59.9	63.5	63.8	62.6	60.7	58.3
	10%	WB	55.3	55.1	54.7	53.8	54.8	57.2	58.8	60.5	61.5	59.8	58.5	55.9
		MCDB	56.9	56.6	56.2	55.2	55.9	58.2	59.4	61.9	62.9	61.6	60.1	57.4
Mean Daily Temperature Range	5% DB	MDBR	3.6	3.5	3.2	3.1	2.6	2.8	2.8	2.8	3.1	3.4	3.5	3.8
		MCDBR	4.6	5.3	4.4	4.7	3.7	3.5	3.5	3.7	4.0	5.5	4.5	4.8
		MCWBR	4.2	4.9	4.1	4.2	3.2	2.9	2.8	2.8	3.5	4.9	4.6	5.0
	5% WB	MCDBR	3.9	4.1	4.0	4.9	3.9	3.7	3.4	3.4	3.7	4.5	4.0	3.9
		MCWBR	4.0	4.4	3.9	4.6	3.5	3.2	2.9	2.8	3.5	4.2	4.2	4.5
Clear-Sky Solar Irradiance	taub	0.312	0.323	0.338	0.347	0.354	0.353	0.358	0.344	0.347	0.345	0.318	0.317	
	taud	2.594	2.573	2.527	2.492	2.493	2.488	2.532	2.547	2.535	2.543	2.588	2.590	
	Ebn at Noon	286	294	297	298	295	293	291	295	290	282	281	277	
	Edh at Noon	24	28	31	34	34	35	33	32	31	28	24	23	
All-Sky Solar Radiation	RadAvg	944	1213	1635	2020	2194	2216	1990	1852	1692	1343	1047	837	
	RadStd	69	121	109	136	173	132	114	134	122	112	64	77	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)	+0.97	N/A	-2.30	+1.35	N/A	N/A	N/A	N/A	-284	+387	+104

Nomenclature: See separate page