

SANTA MONICA BASIN BUOY 46025, CA, USA

WMO: 992600

Lat: 33.763N

Lon: 119.053W

Elev: 0

StdP: 14.70

Time Zone: -8.00 (W08)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	50.8	52.0	30.2	24.3	56.0	34.6	29.4	57.3	32.6	54.5	30.8	54.4	12.2	300	0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	3.4	72.2	67.7	70.8	66.4	69.5	65.0	70.1	72.6	68.6	71.2	67.3	69.9	6.9	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.1	106.9	72.1	67.5	101.0	70.7	66.1	96.2	69.4	34.1	72.9	32.8	71.2	31.7	70.0	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.3	22.5	19.1	DB	48.4	74.1	1.9	2.4	47.0	75.8	45.9	77.1	44.8	78.5	43.5	80.2	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	60.6	57.7	56.9	56.9	57.3	59.5	61.6	64.1	65.0	65.0	63.6	61.1	58.2	(6)
(7)		DBStd	4.08	3.06	2.49	2.77	2.40	2.51	2.18	2.33	2.60	2.88	3.19	2.87	2.72	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	1723	226	227	251	230	172	104	45	33	34	68	122	211	(9)
(10)		CDD50	3871	240	194	215	220	294	348	438	464	449	421	334	254	(10)
(11)		CDD65	116	1	0	0	0	2	2	17	32	33	24	5	0	(11)
(12)		CDH74	9	0	0	0	0	0	0	0	1	1	7	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	8.2	8.6	9.8	9.0	9.8	8.2	7.1	6.9	6.8	7.1	7.5	8.3	9.7	(14)
(15)	Precipitation	PrecAvg	15.0	3.4	3.7	2.2	0.9	0.4	0.1	0.1	0.0	0.2	0.6	1.2	2.3	(15)
(16)		PrecMax	30.0	15.5	15.4	9.2	3.3	3.4	0.8	0.6	0.2	1.0	4.9	2.8	8.7	(16)
(17)		PrecMin	6.4	0.1	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1	(17)
(18)		PrecStd	6.9	3.7	3.3	2.1	0.8	0.7	0.2	0.1	0.0	0.2	1.0	0.7	2.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.2	66.5	66.8	66.6	69.4	69.3	72.3	72.5	73.8	75.1	70.3	66.4	(19)
(20)			MCWB	53.7	58.2	59.9	58.1	59.6	66.1	69.1	68.6	69.1	70.0	60.6	59.0	(20)
(21)		2%	DB	65.2	62.9	64.0	63.4	65.7	66.9	70.0	70.6	71.9	72.0	68.2	64.6	(21)
(22)			MCWB	54.6	58.4	58.9	57.9	60.7	63.4	66.2	66.9	68.3	67.0	59.4	59.0	(22)
(23)		5%	DB	63.2	61.2	62.1	61.7	64.2	65.8	68.4	69.4	70.6	70.0	66.7	63.4	(23)
(24)			MCWB	55.4	57.1	58.1	57.4	60.2	62.3	64.8	65.9	67.2	65.2	58.9	58.5	(24)
(25)		10%	DB	61.8	60.0	60.5	60.3	62.8	64.6	67.4	68.4	69.2	68.2	65.3	62.1	(25)
(26)			MCWB	56.0	56.3	56.8	56.6	59.4	61.5	64.0	65.0	65.6	63.6	58.9	56.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.7	60.8	62.3	61.7	64.1	68.2	69.0	70.1	71.4	72.4	65.3	63.0	(27)
(28)			MCDWB	60.7	62.8	65.5	64.1	66.3	70.5	70.4	72.7	73.1	74.8	68.0	63.7	(28)
(29)		2%	WB	59.2	59.2	60.4	60.0	62.2	65.0	66.5	68.3	70.0	70.5	63.3	61.7	(29)
(30)			MCDWB	60.5	61.5	63.5	62.3	64.7	66.7	68.4	70.8	72.2	73.7	66.0	64.0	(30)
(31)		5%	WB	58.5	58.2	59.5	59.0	60.9	63.4	65.5	67.1	68.9	68.0	62.1	60.5	(31)
(32)			MCDWB	60.2	60.4	62.6	61.4	63.3	64.9	67.6	69.5	71.3	71.2	64.9	63.3	(32)
(33)		10%	WB	57.9	57.3	58.1	58.0	59.9	62.4	64.7	66.1	67.5	66.3	60.9	58.6	(33)
(34)			MCDWB	59.9	59.5	60.8	60.6	62.2	64.3	66.9	68.5	70.1	69.6	63.8	61.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.8	3.5	3.7	3.7	3.5	3.4	3.3	3.5	3.4	3.5	3.5	3.6	(35)
(36)			MCDBR	6.4	4.9	5.3	5.4	5.0	4.5	3.7	3.9	3.8	5.1	5.2	5.0	(36)
(37)			MCWBR	4.7	3.9	3.9	4.6	4.3	4.0	3.0	3.5	3.4	4.4	5.1	4.5	(37)
(38)		5% WB	MCDWB	4.0	3.9	4.2	5.5	4.9	4.4	3.5	3.7	3.6	4.0	4.3	3.2	(38)
(39)			MCWBR	3.8	4.0	3.7	4.8	4.3	4.3	3.3	3.8	3.7	4.1	4.6	3.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.300	0.311	0.323	0.354	0.371	0.372	0.392	0.369	0.362	0.339	0.304	0.305	(40)	
(41)		taud	2.632	2.619	2.571	2.463	2.443	2.436	2.443	2.479	2.504	2.564	2.641	2.631	(41)	
(42)		Ebn at Noon	293	300	303	296	290	288	282	287	286	286	290	285	(42)	
(43)		Edh at Noon	24	27	30	35	36	36	36	34	32	28	23	23	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1002	1282	1690	2082	2192	2179	2184	2085	1802	1392	1104	906	(44)	
(45)		RadStd	71	114	107	124	194	137	137	108	109	131	80	72	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (47 neighbors)	+1.19	N/A	-3.02	+1.28	N/A	N/A	N/A	-230	+425	+182

Nomenclature: See separate page