

SANTA MONICA BASIN BUOY 46025, CA, USA

WMO: 992600

Lat: 33.763N

Lon: 119.053W

Elev: 0

StdP: 101.33

Time Zone: -8.00 (W08)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	10.4	11.1	-1.0	3.5	13.3	1.4	4.2	14.0	14.6	12.5	13.8	12.4	5.5	300	0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	1.9	22.3	19.8	21.6	19.1	20.8	18.3	21.2	22.5	20.3	21.8	19.6	21.1	3.1	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.3	22.3	19.7	14.4	21.5	19.0	13.7	20.8	61.4	22.7	58.5	21.8	55.9	21.1	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.8	10.1	8.5	DB	9.1	23.4	1.1	1.3	8.3	24.3	7.7	25.1	7.1	25.8	6.4	26.8	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.9	14.3	13.8	13.8	14.1	15.3	16.4	17.8	18.3	18.3	17.6	16.2	14.5
	DBStd	2.27	1.70	1.38	1.54	1.33	1.39	1.21	1.29	1.44	1.60	1.77	1.60	1.51
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	957	126	126	139	128	96	58	25	18	19	38	68	117
	CDD10.0	2151	133	108	119	122	163	193	243	258	249	234	186	141
	CDD18.3	64	1	0	0	0	1	1	9	18	18	13	3	0
	CDH23.3	5	0	0	0	0	0	0	0	1	1	4	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	3.7	3.8	4.4	4.0	4.4	3.7	3.2	3.1	3.0	3.2	3.3	3.7	4.3
Precipitation	PrecAvg	380	86	93	55	23	10	2	2	1	4	16	30	58
	PrecMax	761	394	391	233	83	87	20	16	5	26	125	71	221
	PrecMin	162	2	0	0	2	0	0	0	0	0	0	4	2
	PrecStd	174	93	85	54	20	17	4	3	1	6	25	19	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	19.2	19.3	19.2	20.8	20.7	22.4	22.5	23.2	23.9	21.3	19.1
		MCWB	12.1	14.5	15.5	14.5	15.4	19.0	20.6	20.3	20.6	21.1	15.9	15.0
	2%	DB	18.4	17.2	17.8	17.5	18.7	19.4	21.1	21.5	22.2	22.2	20.1	18.1
		MCWB	12.6	14.7	15.0	14.4	15.9	17.4	19.0	19.4	20.2	19.4	15.2	15.0
	5%	DB	17.3	16.2	16.7	16.5	17.9	18.8	20.2	20.8	21.5	21.1	19.3	17.5
		MCWB	13.0	14.0	14.5	14.1	15.7	16.8	18.2	18.8	19.5	18.4	14.9	14.7
	10%	DB	16.5	15.6	15.8	15.7	17.1	18.1	19.6	20.2	20.7	20.1	18.5	16.7
		MCWB	13.3	13.5	13.8	13.7	15.2	16.4	17.8	18.3	18.7	17.6	15.0	13.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.4	16.0	16.8	16.5	17.8	20.1	20.6	21.2	21.9	22.5	18.5	17.2
		MCDB	16.0	17.1	18.6	17.8	19.1	21.4	21.3	22.6	22.8	23.8	20.0	17.6
	2%	WB	15.1	15.1	15.8	15.5	16.8	18.3	19.2	20.2	21.1	21.4	17.4	16.5
		MCDB	15.8	16.4	17.5	16.8	18.2	19.3	20.2	21.6	22.3	23.2	18.9	17.8
	5%	WB	14.7	14.5	15.3	15.0	16.0	17.5	18.6	19.5	20.5	20.0	16.7	15.8
		MCDB	15.6	15.8	17.0	16.3	17.4	18.3	19.8	20.9	21.8	21.8	18.3	17.4
	10%	WB	14.4	14.0	14.5	14.4	15.5	16.9	18.2	18.9	19.7	19.1	16.1	14.8
		MCDB	15.5	15.3	16.0	15.9	16.8	17.9	19.4	20.3	21.2	20.9	17.7	16.4
Mean Daily Temperature Range	5% DB	MDBR	2.1	2.0	2.0	2.0	1.9	1.9	1.8	2.0	1.9	2.0	2.0	2.0
		MCDBR	3.6	2.7	2.9	3.0	2.8	2.5	2.1	2.2	2.1	2.9	2.9	2.8
		MCWBR	2.6	2.2	2.2	2.5	2.4	2.2	1.7	1.9	1.9	2.4	2.8	2.5
	5% WB	MCDBR	2.2	2.2	2.4	3.0	2.7	2.5	1.9	2.1	2.0	2.2	2.4	1.8
		MCWBR	2.1	2.2	2.1	2.7	2.4	2.4	1.8	2.1	2.1	2.3	2.6	2.1
Clear-Sky Solar Irradiance	taub	0.300	0.311	0.323	0.354	0.371	0.372	0.392	0.369	0.362	0.339	0.304	0.305	
	taud	2.632	2.619	2.571	2.463	2.443	2.436	2.443	2.479	2.504	2.564	2.641	2.631	
	Ebn at Noon	925	947	956	933	914	908	888	906	902	901	913	899	
	Edh at Noon	75	84	95	111	114	115	113	108	100	88	73	71	
All-Sky Solar Radiation	RadAvg	3.16	4.04	5.33	6.56	6.91	6.87	6.88	6.57	5.68	4.39	3.48	2.85	
	RadStd	0.22	0.36	0.34	0.39	0.61	0.43	0.43	0.34	0.34	0.41	0.25	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (47 neighbors)	+0.66	N/A	-1.68	+0.71	N/A	N/A	N/A	-128	+236	+101

Nomenclature: See separate page