

SEVENSTONES LIGHTSHIP 62107, United Kingdom

WMO: 992700

Lat: 50.102N

Lon: 6.100W

Elev: 0

StdP: 14.70

Time Zone: 0.00 (EUW)

Period: 01-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	37.2	39.7	23.3	17.5	44.6	25.6	19.6	44.0	50.9	47.6	47.9	47.2	21.4	60	0.899

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.7	65.3	62.4	64.3	61.6	63.5	60.8	63.5	64.5	62.4	63.6	61.6	62.9	15.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.9	85.7	64.1	61.8	82.6	63.2	61.0	80.0	62.5	28.8	64.7	28.1	63.7	27.5	63.0	69.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 45.0	40.9	36.5	34.6	66.9	3.4	2.8	32.1	68.9	30.1	70.5	28.2	72.1	25.7	74.1		
(5)			31.3	64.3	3.2	2.1	29.0	65.9	27.1	67.1	25.3	68.3	23.0	69.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.5	48.3	46.8	47.4	49.5	52.6	57.0	60.3	60.9	59.5	56.4	52.6	49.7
	DBStd	5.68	3.48	3.43	3.10	2.28	2.07	2.24	2.28	1.57	1.89	2.48	3.30	3.45
	HDD50	348	70	94	86	33	3	0	0	0	0	1	15	46
	HDD65	4215	519	509	546	465	385	241	147	126	165	265	373	474
	CDD50	1609	16	4	5	18	83	209	320	339	285	201	92	37
	CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	19.7	24.3	22.8	20.9	18.3	18.2	16.2	16.1	16.4	17.2	19.4	22.5	24.7
Precipitation	PrecAvg	45.7	5.0	3.8	3.3	3.0	2.8	2.9	3.0	3.4	3.3	5.0	5.2	5.0
	PrecMax	56.9	9.3	8.0	6.3	5.8	7.2	6.7	8.1	9.7	6.9	8.8	9.4	10.6
	PrecMin	38.3	1.3	1.0	0.8	0.9	0.2	0.8	0.7	0.7	0.8	2.0	1.9	1.7
	PrecStd	4.9	1.9	1.9	1.4	1.3	1.3	1.5	1.5	1.9	1.5	1.9	2.0	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.0	54.0	53.1	55.5	59.5	63.5	68.2	66.2	64.8	62.1	58.7	57.1
		MCWB	52.9	51.2	50.4	51.3	54.8	60.1	64.6	63.3	61.7	60.2	56.4	54.7
	2%	DB	54.1	52.7	52.2	53.9	57.2	62.1	66.1	64.9	63.7	61.0	57.9	56.1
		MCWB	52.1	49.6	49.9	51.3	54.3	59.2	63.0	62.1	61.1	59.1	55.7	53.9
	5%	DB	53.2	51.7	51.5	53.0	56.2	61.1	64.5	64.3	62.9	60.1	57.2	55.1
		MCWB	51.1	48.2	49.3	50.8	53.8	58.3	61.9	61.5	60.5	58.1	55.2	52.9
	10%	DB	52.4	50.9	50.9	52.3	55.4	60.1	63.5	63.5	62.1	59.4	56.5	54.1
		MCWB	50.2	47.3	48.7	50.3	53.4	57.5	61.1	60.7	59.7	57.3	54.2	51.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.8	52.3	51.9	53.4	56.2	61.2	65.3	64.5	63.0	61.2	57.6	55.7
		MCDB	54.5	53.0	52.3	53.8	57.4	62.4	66.7	65.0	63.5	61.7	58.2	56.5
	2%	WB	52.8	51.0	50.9	52.2	55.3	60.0	63.7	63.5	62.0	60.0	56.5	54.5
		MCDB	53.7	52.1	51.6	53.0	56.3	61.5	65.2	64.3	62.9	60.5	57.4	55.6
	5%	WB	51.9	49.9	50.0	51.5	54.6	59.1	62.6	62.4	61.3	59.1	55.7	53.5
		MCDB	52.9	51.2	51.0	52.4	55.7	60.5	64.0	63.4	62.3	59.7	56.9	54.8
	10%	WB	50.9	48.9	49.2	50.8	53.8	58.2	61.6	61.5	60.4	58.2	54.7	52.3
		MCDB	52.3	50.6	50.5	52.0	55.1	59.7	63.1	62.8	61.7	59.2	56.2	53.9
Mean Daily Temperature Range	5% DB	MDBR	4.1	3.8	3.4	2.9	2.7	2.7	2.7	2.7	2.7	3.1	3.9	4.1
		MCDBR	4.3	4.0	3.4	3.3	3.5	3.4	3.5	3.2	3.1	3.3	4.0	4.7
		MCWBR	5.8	4.9	4.3	3.5	3.2	3.5	3.5	3.8	3.8	4.5	5.6	6.3
	5% WB	MCDBR	4.0	4.1	3.3	2.9	3.5	3.3	3.1	3.2	3.0	3.2	3.9	4.6
		MCWBR	5.9	5.4	4.3	3.5	3.6	3.6	3.5	4.1	4.0	4.8	5.8	6.5
Clear-Sky Solar Irradiance	taub	0.344	0.356	0.384	0.386	0.395	0.381	0.388	0.371	0.369	0.364	0.342	0.336	
	taud	2.339	2.370	2.320	2.351	2.374	2.449	2.437	2.498	2.486	2.442	2.386	2.307	
	Ebn at Noon	215	246	259	272	274	279	274	275	263	240	214	196	
	Edh at Noon	22	27	33	36	36	34	34	31	28	25	21	20	
All-Sky Solar Radiation	RadAvg	273	522	886	1453	1744	1916	1743	1499	1127	655	349	219	
	RadStd	23	43	94	90	125	162	129	94	78	39	28	23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page