

WEST GULF BUOY 42002, USA

WMO: 992710

Lat: 26.055N

Lon: 93.646W

Elev: 0

StdP: 14.70

Time Zone: -6.00 (W06)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	57.3	59.7	42.2	39.7	60.7	44.9	44.0	63.0	36.7	65.4	35.1	64.8	22.4	0	0.597

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.4	87.0	78.7	86.4	78.7	86.1	78.7	81.9	84.3	81.3	84.2	80.7	84.0	7.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.1	161.5	83.6	80.3	157.4	83.5	79.7	154.3	83.4	45.5	84.3	44.8	84.2	44.2	84.0	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
33.0	30.2	25.7	56.6	89.3	1.5	0.9	55.6	90.0	54.7	90.5	53.8	91.0	52.7	91.7
			49.1	82.5	1.9	0.7	47.7	83.1	46.6	83.5	45.5	83.9	44.1	84.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.7	68.9	69.3	71.2	73.8	78.1	82.2	83.9	84.3	82.9	79.5	75.0	70.9
	DBStd	6.39	4.51	4.09	3.65	2.73	2.15	1.41	1.34	1.50	1.85	2.93	3.58	4.31
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	47	20	12	7	0	0	0	0	0	0	0	0	8
	CDD50	9747	585	542	656	713	871	965	1051	1064	987	915	749	649
	CDD65	4318	139	134	198	263	406	515	586	599	537	450	299	192
	CDH74	38616	94	63	153	728	3165	5943	7469	7864	6692	4366	1612	467
	CDH80	11551	0	0	0	3	117	1677	3023	3420	2453	828	30	0
Wind	WSAvg	14.8	17.3	16.7	16.1	16.0	15.1	13.0	11.4	10.7	12.7	15.4	16.0	16.9
Precipitation	PrecAvg	35.9	3.2	1.8	2.2	2.3	2.0	3.0	2.5	3.0	5.0	4.5	3.5	3.0
	PrecMax	50.9	8.5	4.5	5.6	6.3	6.9	6.3	7.7	7.5	10.7	12.0	8.2	8.5
	PrecMin	16.9	0.7	0.2	0.6	0.2	0.1	0.2	0.1	0.3	1.5	0.6	0.5	0.9
	PrecStd	8.2	2.0	1.1	1.4	1.8	1.8	2.0	1.8	1.6	2.1	3.2	2.1	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.5	76.5	77.1	80.4	82.5	85.8	87.5	88.0	86.9	86.2	82.2	78.4
		MCWB	74.3	72.8	73.9	77.3	77.8	78.7	78.6	78.6	78.9	78.8	77.4	74.9
	2%	DB	75.9	75.5	76.1	78.5	82.0	85.0	86.5	87.2	86.3	84.9	80.8	77.8
		MCWB	73.5	72.6	73.6	75.8	77.7	78.8	78.6	78.8	78.8	79.1	76.4	74.1
	5%	DB	75.2	75.0	75.4	77.7	81.3	84.4	86.2	86.6	85.9	84.1	80.2	77.2
		MCWB	72.6	72.3	73.3	74.9	77.6	78.7	78.6	78.7	78.8	78.5	75.5	73.4
	10%	DB	74.5	74.2	75.0	77.1	80.7	84.1	85.6	86.3	85.4	83.4	79.5	76.6
		MCWB	71.5	71.8	72.9	74.5	77.3	78.7	78.6	78.7	78.7	77.9	74.6	72.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.2	75.2	76.1	78.2	80.7	82.5	82.1	81.9	82.5	82.3	79.4	77.4
		MCDB	76.3	75.3	76.2	79.2	81.0	83.7	85.2	85.4	84.8	83.7	80.5	77.7
	2%	WB	75.1	74.2	75.2	77.2	80.1	81.6	81.2	81.2	81.7	80.5	78.2	76.0
		MCDB	75.4	74.6	75.4	78.1	80.6	83.3	84.5	85.3	84.8	83.0	80.2	76.9
	5%	WB	74.1	73.4	74.5	76.4	79.4	81.0	80.5	80.5	81.0	79.7	77.2	75.1
		MCDB	75.0	74.0	75.0	77.2	80.2	83.1	84.4	85.2	84.6	82.7	79.7	76.4
	10%	WB	72.9	72.9	74.0	75.7	78.6	80.3	80.2	80.2	80.3	78.8	75.9	74.1
		MCDB	74.3	73.7	74.6	76.5	79.8	83.0	84.4	85.1	84.4	82.2	78.7	76.1
Mean Daily Temperature Range	5% DB	MDBR	4.5	3.9	3.2	2.7	2.2	2.4	2.9	3.4	3.6	3.2	3.6	4.1
		MCDBR	4.1	3.4	2.9	2.5	2.5	2.8	3.3	3.5	3.6	3.7	3.7	4.0
		MCWBR	5.7	4.8	3.7	2.9	2.6	2.5	2.7	2.8	3.1	3.4	4.8	5.3
	5% WB	MCDBR	3.9	3.6	3.0	2.4	2.3	2.3	2.7	3.5	3.7	3.8	4.2	3.7
		MCWBR	5.8	5.0	3.9	3.1	2.7	2.9	2.9	3.1	3.3	3.9	5.8	5.5
Clear-Sky Solar Irradiance	taub	0.382	0.393	0.399	0.453	0.467	0.450	0.460	0.445	0.431	0.398	0.380	0.382	
	taud	2.475	2.446	2.416	2.258	2.253	2.381	2.358	2.413	2.412	2.491	2.506	2.483	
	Ebn at Noon	275	281	285	270	265	267	265	269	271	276	274	270	
	Edh at Noon	31	34	37	44	44	39	40	37	36	32	30	30	
All-Sky Solar Radiation	RadAvg	1020	1268	1647	1929	2152	2178	2147	1991	1662	1528	1176	952	
	RadStd	92	151	138	190	110	111	122	101	121	101	125	82	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page