

WEST GULF BUOY 42002, USA

WMO: 992710

Lat: 26.055N

Lon: 93.646W

Elev: 0

StdP: 101.33

Time Zone: -6.00 (W06)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.1	15.4	5.7	5.7	15.9	7.2	6.3	17.2	16.4	18.5	15.7	18.2	10.0	0	0.597

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.9	30.5	26.0	30.2	25.9	30.1	25.9	27.7	29.1	27.4	29.0	27.0	28.9	3.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.3	23.1	28.7	26.8	22.5	28.6	26.5	22.0	28.5	87.9	29.1	86.3	29.0	85.0	28.9	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.7	13.5	11.5	DB	13.7	31.8	0.8	0.5	13.1	32.2	12.6	32.5	12.1	32.8	11.5	33.2	
			WB	9.5	28.1	1.1	0.4	8.7	28.4	8.1	28.6	7.5	28.8	6.7	29.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.8	20.5	20.7	21.8	23.2	25.6	27.9	28.8	29.1	28.3	26.4	23.9	21.6
	DBStd	3.55	2.51	2.27	2.03	1.52	1.19	0.79	0.74	0.84	1.03	1.63	1.99	2.39
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	26	11	7	4	0	0	0	0	0	0	0	0	4
	CDD10.0	5415	325	301	364	396	484	536	584	591	548	508	416	361
	CDD18.3	2399	77	74	110	146	226	286	326	333	298	250	166	107
	CDH23.3	21453	52	35	85	404	1758	3302	4149	4369	3718	2426	896	259
	CDH26.7	6417	0	0	0	2	65	932	1679	1900	1363	460	17	0
Wind	WSAvg	6.6	7.7	7.4	7.2	7.2	6.8	5.8	5.1	4.8	5.7	6.9	7.2	7.6
Precipitation	PrecAvg	912	81	45	56	59	50	75	63	76	128	114	89	76
	PrecMax	1294	216	115	143	159	175	160	195	191	272	306	208	216
	PrecMin	430	18	6	14	4	2	5	3	8	37	14	13	22
	PrecStd	209	52	29	35	45	45	50	46	40	54	81	54	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.7	24.7	25.0	26.9	28.0	29.9	30.8	31.1	30.5	30.1	27.9	25.8
		MCWB	23.5	22.6	23.3	25.2	25.4	26.0	25.9	25.9	26.0	26.0	25.2	23.8
	2%	DB	24.4	24.2	24.5	25.8	27.8	29.4	30.3	30.7	30.2	29.4	27.1	25.5
		MCWB	23.1	22.5	23.1	24.3	25.4	26.0	25.9	26.0	26.0	26.2	24.7	23.4
	5%	DB	24.0	23.9	24.1	25.4	27.4	29.1	30.1	30.3	29.9	29.0	26.8	25.1
		MCWB	22.5	22.4	23.0	23.8	25.3	25.9	25.9	25.9	26.0	25.8	24.2	23.0
	10%	DB	23.6	23.5	23.9	25.0	27.1	29.0	29.8	30.2	29.7	28.5	26.4	24.8
		MCWB	22.0	22.1	22.7	23.6	25.2	25.9	25.9	25.9	26.0	25.5	23.7	22.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.6	24.0	24.5	25.7	27.1	28.0	27.8	27.7	28.0	28.0	26.3	25.2
		MCDB	24.6	24.1	24.6	26.2	27.2	28.7	29.5	29.6	29.4	28.7	27.0	25.4
	2%	WB	23.9	23.5	24.0	25.1	26.7	27.6	27.3	27.3	27.6	27.0	25.7	24.4
		MCDB	24.1	23.7	24.1	25.6	27.0	28.5	29.2	29.6	29.3	28.3	26.8	24.9
	5%	WB	23.4	23.0	23.6	24.7	26.3	27.2	26.9	26.9	27.2	26.5	25.1	24.0
		MCDB	23.9	23.3	23.9	25.1	26.8	28.4	29.1	29.5	29.2	28.1	26.5	24.7
	10%	WB	22.7	22.7	23.3	24.3	25.9	26.9	26.8	26.8	26.8	26.0	24.4	23.4
		MCDB	23.5	23.2	23.7	24.7	26.6	28.3	29.1	29.5	29.1	27.9	26.0	24.5
Mean Daily Temperature Range	5% DB	MDBR	2.5	2.2	1.8	1.5	1.2	1.3	1.6	1.9	2.0	1.8	2.0	2.3
		MCDBR	2.3	1.9	1.6	1.4	1.4	1.6	1.9	2.0	2.0	2.1	2.1	2.2
		MCWBR	3.1	2.7	2.0	1.6	1.5	1.4	1.5	1.5	1.7	1.9	2.7	3.0
	5% WB	MCDWR	2.2	2.0	1.7	1.3	1.3	1.3	1.5	2.0	2.0	2.1	2.3	2.0
MCWBR		3.2	2.8	2.2	1.7	1.5	1.6	1.6	1.7	1.8	2.2	3.2	3.1	
Clear-Sky Solar Irradiance	taub	0.382	0.393	0.399	0.453	0.467	0.450	0.460	0.445	0.431	0.398	0.380	0.382	
	taud	2.475	2.446	2.416	2.258	2.253	2.381	2.358	2.413	2.412	2.491	2.506	2.483	
	Ebn at Noon	868	885	897	852	836	843	835	848	854	869	863	850	
	Edh at Noon	98	107	116	139	140	122	125	118	115	101	94	94	
All-Sky Solar Radiation	RadAvg	3.22	4.00	5.19	6.08	6.79	6.87	6.77	6.28	5.24	4.82	3.71	3.00	
	RadStd	0.29	0.48	0.43	0.60	0.35	0.35	0.38	0.32	0.38	0.32	0.39	0.26	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page