

EEL RIVER BUOY 46022, CA, USAWMO: **992740**Lat: **40.712N**Lon: **124.529W**Elev: **0**StdP: **14.70**Time Zone: **-8.00 (W08)**Period: **94-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	43.1	44.4	N/A	N/A	N/A	N/A	N/A	N/A	40.4	54.1	37.2	52.1	11.8	0	0.704

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	3.5	63.1	N/A	61.8	N/A	60.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	11.4	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
35.5	32.2	29.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.8	51.0	50.0	49.7	50.5	52.0	54.0	55.0	56.2	56.3	54.4	52.9	51.4
	DBStd	3.44	3.10	2.85	2.41	2.08	2.10	2.10	2.29	2.54	3.03	2.64	2.70	3.02
	HDD50	141	25	32	34	18	5	0	0	0	0	1	7	19
	HDD65	4458	434	421	474	435	404	331	310	272	262	330	362	423
	CDD50	1159	56	31	25	34	65	119	155	193	188	137	95	61
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	13.4	15.4	15.5	15.7	14.3	13.5	12.8	11.6	10.0	10.2	11.6	13.7	16.2
Precipitation	PrecAvg	60.5	10.8	8.4	8.1	4.7	2.0	0.7	0.2	0.3	0.6	3.5	8.3	12.8
	PrecMax	90.4	24.4	18.8	17.0	14.0	6.3	4.5	0.7	0.9	3.6	12.4	17.6	29.0
	PrecMin	33.1	0.6	1.9	2.6	1.0	0.0	0.0	0.0	0.0	0.0	0.7	2.1	3.9
	PrecStd	14.2	5.7	4.0	4.1	2.6	1.7	1.0	0.2	0.2	0.9	2.4	3.6	6.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.8	58.0	57.4	56.6	59.8	60.2	62.2	65.0	65.9	62.4	60.1	60.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	57.3	56.5	55.5	55.2	57.5	59.2	60.6	62.5	63.8	60.5	58.9	58.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	56.3	55.2	54.2	54.3	55.9	58.2	59.5	61.2	62.2	59.5	57.8	56.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	55.3	53.9	53.2	53.5	55.0	57.1	58.5	60.0	61.0	58.3	56.9	55.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	4.1	3.9	3.7	3.3	2.7	2.9	3.0	3.4	3.5	3.6	4.1	4.3
		MCDBR	4.6	4.7	4.7	3.9	3.6	3.5	3.7	4.5	3.9	4.6	4.8	5.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.324	0.332	0.337	0.359	0.362	0.351	0.364	0.349	0.344	0.337	0.322	0.326	
	taud	2.562	2.542	2.545	2.444	2.477	2.514	2.483	2.535	2.521	2.573	2.592	2.557	
	Ebn at Noon	267	281	291	290	290	292	287	290	285	275	266	256	
	Edh at Noon	23	27	30	35	34	33	34	31	30	25	22	21	
All-Sky Solar Radiation	RadAvg	590	847	1236	1698	2032	2231	2122	1812	1535	1063	674	490	
	RadStd	82	115	113	133	125	121	126	102	84	78	67	82	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)		N/A	N/A	N/A	+0.92	N/A	N/A	N/A	N/A	+182	+4

Nomenclature: See separate page