

BERING SEA BUOY 46035, USA

WMO: 992820

Lat: 57.016N

Lon: 177.703W

Elev: 0

StdP: 101.33

Time Zone: -12.00 (W12)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -8.6	(c) -7.4	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 22.8	(k) -1.1	(l) 21.1	(m) -0.5	(n) 11.1	(o) 350	(p) 1.083

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 1.2	(c) 11.7	(d) N/A	(e) 11.2	(f) N/A	(g) 10.8	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 6.9	(p) 80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 19.2	(b) 17.7	(c) 16.3	(e) -9.6	(f) 11.6	(g) 2.1	(h) 1.1	(i) -11.0	(j) 12.4	(k) -12.2	(l) 13.1	(m) -13.4	(n) 13.7	(o) -14.9	(p) 14.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.2	-1.3	-1.2	-1.1	0.0	2.4	5.4	7.9	9.5	8.6	5.1	2.2	0.0
	DBStd	4.41	2.97	2.86	2.87	1.93	1.59	1.45	1.15	1.15	1.57	1.95	2.04	2.56
	HDD10.0	2508	351	313	346	299	234	138	67	22	45	152	233	309
	HDD18.3	5538	609	547	604	549	493	388	324	273	291	410	483	567
	CDD10.0	12	0	0	0	0	0	0	1	8	4	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.7	10.5	10.9	9.5	8.8	7.4	6.4	6.2	7.0	8.1	9.4	10.4	10.4
Precipitation	PrecAvg	983	86	86	81	52	51	67	87	95	95	85	103	96
	PrecMax	1211	139	162	184	111	95	101	126	164	144	127	187	166
	PrecMin	804	30	20	31	21	23	19	38	46	40	41	50	30
	PrecStd	113	27	36	32	20	19	20	24	26	25	24	35	34
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.4	3.6	3.8	3.8	6.6	9.9	11.6	12.4	12.2	10.0	6.9	4.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	3.9	3.0	3.1	3.2	5.6	8.5	10.6	11.9	11.5	8.9	6.2	4.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	3.3	2.7	2.7	2.9	5.1	7.9	10.1	11.5	11.0	8.0	5.6	3.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	2.6	2.3	2.2	2.5	4.6	7.4	9.5	11.0	10.7	7.6	5.1	3.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	2.3	2.3	2.3	2.0	1.5	1.4	1.2	1.2	1.3	1.9	2.3	2.3
		MCDBR	2.0	2.2	2.1	2.0	1.5	1.9	1.4	1.3	1.2	1.7	2.3	2.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.303	0.324	0.335	0.402	0.409	0.397	0.408	0.399	0.374	0.337	0.336	0.267
	taud		2.208	2.313	2.360	2.141	2.200	2.335	2.337	2.363	2.346	2.331	2.122	2.335
	Ebn at Noon		558	723	822	804	826	844	825	805	767	693	484	533
	Edh at Noon		53	73	90	130	131	116	114	104	91	71	58	36
All-Sky Solar Radiation	RadAvg		0.38	0.93	2.01	3.27	3.83	4.05	3.63	3.00	2.43	1.38	0.52	0.27
	RadStd		0.04	0.07	0.19	0.31	0.38	0.32	0.25	0.31	0.25	0.10	0.06	0.03

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page