

K1 BUOY 62029, United Kingdom

WMO: 992880

Lat: 48.720N

Lon: 12.430W

Elev: 0

StdP: 101.33

Time Zone: 0.00 (EUW)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.8	7.6	0.0	3.8	8.1	1.2	4.1	8.5	30.3	9.4	28.1	9.9	11.9	300	0.952

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.4	19.0	17.9	18.6	17.5	18.2	17.1	18.3	18.7	17.9	18.4	17.5	18.1	9.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.0	18.6	17.6	12.6	18.3	17.2	12.3	17.9	51.7	18.8	50.5	18.5	49.3	18.1	19.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.7	25.2	22.0	5.2	19.3	1.1	0.8	4.4	19.9	3.7	20.4	3.1	20.8	2.3	21.4
			3.3	18.7	1.0	0.7	2.6	19.2	2.0	19.6	1.5	20.0	0.7	20.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	10.8	10.6	10.5	11.0	12.5	14.4	16.1	16.8	16.3	14.8	12.7	11.5
	DBStd	2.62	1.40	1.29	1.26	1.23	1.12	1.16	1.11	0.97	1.14	1.33	1.45	1.47
	HDD10.0	36	8	9	9	4	0	0	0	0	0	0	1	5
	HDD18.3	1877	234	218	242	219	182	118	68	48	61	109	169	211
	CDD10.0	1202	33	24	26	36	77	132	190	211	189	149	82	52
	CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	10.2	11.7	11.2	9.9	9.4	9.6	8.5	8.4	8.6	9.6	10.8	11.9	12.6
Precipitation	PrecAvg	987	118	93	82	58	59	55	54	64	74	110	101	119
	PrecMax	1351	238	231	141	101	95	141	102	235	128	155	167	208
	PrecMin	757	51	32	36	20	11	21	19	12	23	42	37	41
	PrecStd	111	40	41	27	22	19	27	20	44	26	31	35	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.0	13.5	13.2	15.9	17.1	18.0	19.2	19.7	19.2	18.2	16.2	15.1
		MCWB	12.9	12.5	12.2	15.4	15.9	16.7	17.9	18.7	18.1	16.9	15.0	13.9
	2%	DB	13.5	13.0	12.8	13.3	15.1	17.2	18.6	19.2	18.7	17.5	15.6	14.4
		MCWB	12.4	11.9	11.7	12.2	13.9	16.1	17.5	18.1	17.6	16.2	14.6	13.2
	5%	DB	13.1	12.6	12.4	13.0	14.2	16.6	18.2	18.7	18.4	17.0	15.2	13.9
		MCWB	12.1	11.5	11.4	11.9	13.1	15.5	17.1	17.7	17.3	15.8	14.1	12.7
	10%	DB	12.7	12.2	12.1	12.6	13.9	16.1	17.8	18.4	18.0	16.7	14.7	13.5
		MCWB	11.6	11.1	11.0	11.5	12.8	14.9	16.7	17.3	16.9	15.4	13.5	12.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.2	12.9	12.6	15.3	16.0	17.1	18.2	19.1	18.7	17.2	15.6	14.3
		MCDB	13.6	13.1	12.8	15.9	17.1	17.6	18.6	19.4	18.9	17.6	15.9	14.7
	2%	WB	12.7	12.2	12.2	12.7	14.2	16.3	17.9	18.5	18.1	16.7	15.0	13.6
		MCDB	13.2	12.6	12.5	13.0	14.7	16.9	18.4	18.9	18.5	17.2	15.4	14.2
	5%	WB	12.4	11.9	11.7	12.2	13.6	15.7	17.5	18.1	17.7	16.2	14.4	13.1
		MCDB	13.0	12.4	12.2	12.8	14.1	16.4	18.0	18.6	18.2	16.8	15.0	13.7
	10%	WB	12.0	11.5	11.4	11.8	13.1	15.2	17.0	17.6	17.3	15.8	13.8	12.6
		MCDB	12.7	12.1	12.1	12.5	13.7	15.8	17.6	18.2	17.9	16.5	14.6	13.3
Mean Daily Temperature Range	5% DB	MDBR	2.1	1.9	1.7	1.6	1.4	1.3	1.3	1.4	1.5	1.7	2.0	2.0
		MCDBR	2.5	2.2	1.9	1.8	1.8	1.7	1.6	1.6	1.6	1.8	2.1	2.3
		MCWBR	3.3	3.0	2.5	2.2	2.2	2.1	1.8	2.0	2.3	2.4	3.0	3.0
	5% WB	MCDBR	2.5	2.1	1.9	1.9	1.8	1.6	1.5	1.6	1.6	1.8	2.0	2.2
		MCWBR	3.3	3.1	2.7	2.5	2.2	2.2	1.9	2.2	2.2	2.5	2.9	3.1
Clear-Sky Solar Irradiance	taub	0.357	0.363	0.386	0.384	0.393	0.377	0.384	0.370	0.368	0.365	0.354	0.354	
	taud	2.300	2.358	2.323	2.376	2.387	2.469	2.461	2.515	2.511	2.444	2.332	2.265	
	Ebn at Noon	677	778	822	866	869	884	872	871	837	769	676	619	
	Edh at Noon	75	88	107	111	115	106	106	96	88	80	72	69	
All-Sky Solar Radiation	RadAvg	0.99	1.67	2.89	4.44	5.20	5.72	5.25	4.71	3.48	2.15	1.18	0.76	
	RadStd	0.09	0.10	0.20	0.27	0.36	0.36	0.45	0.34	0.21	0.15	0.11	0.06	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	-0.86	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page